




HRS Services Ltd.

The Maltings, 81 Burton Road
Sheffield, South Yorkshire
S3 8BZ

0114 272 3004
info@hrsservices.co.uk
www.hrsservices.co.uk



Part L compliance Report, 'as-desgin'

Leybourne Village Hall, West Malling

Client: Fulkers


Project reference: 127119

Report date: 08/10/2018

Author: Miquel Garcia



Document prepared by

<i>Name</i>	<i>Signature</i>	<i>Date</i>
Miquel Garcia		08/10/2018

Revisions

<i>Revision ref.</i>	<i>Consultant</i>	<i>Date</i>	<i>Notes</i>
v01	MG	02/10/2018	inltial 'as-desig' stage simulation
v02	MG	08/10/2018	as-design' stage simulation

1. Introduction & Method

We have produced the Part L calculations to assess and demonstrate compliance of the proposed project with Part L of the Building Regulations. We have calculated the annual energy demand of the proposed building named the BER (Building Emission Rate) and compared it against a comparable target the notional building which is the TER (notional government Target Emission Rate). In order for the actual building to comply with Part L2A the (BER) should be lower than or at least equal the notional (TER) (Criterion 1). The calculation process is based on the National Calculation Methodology modelling guide (NCM) 2013. Part L2A (2010) compliance is achieved through five separate criteria, of which Criterion 1 in particular is compulsory. The five compliance criteria are:

- Criterion 1 – Achieving an Acceptable Building CO2 Emission Rate
- Criterion 2 – Limits on Design Flexibility
- Criterion 3 – Limiting the Effects of Solar Gains
- Criterion 4 – Quality of Construction and Commissioning (by contractor)
- Criterion 5 – Providing Information or Building Log book provision (by contractor)

Part L calculation assessment requires a wide variety of different influencing factors including:-

- a) The building's geometry,
- b) its orientation,
- c) thermal insulations,
- d) fabric performance,
- e) heating systems types and their efficiencies with types of controls,
- f) artificial lighting type and their efficacy, level of fabric's air leakage rate,
- g) ventilation strategy, natural ventilation or mechanical ventilation
- h) Renewable technologies if applicable.

Some of the energy model' inputs are already set by the NCM controlled by DCLG and cannot be amended such as the occupancy, systems operation times, hot water consumption, casual internal gains heat gains. However, the other building's energy inputs (a to h above) are also available to help achieve the Part L2A compliance PASS. The BRUKL certificate with the final EPC, which a copy of should be sent to the appointed Building's Controls Officer to be able to sign off the building near hand over.

2. Project Details

2.1 Address

Line 1	
Line 2	
Line 3	
Line 4	
Post Town	
Postcode	ME19 5QL

2.2 EPC lodgement info

EPC data confirmation	
EPC draft approved	

NCM Weather Postcode Area

ME	London
----	--------

2.3 Part L calculations settings



Building Type	Full fit out
Project stage	As designed
NCM Building Type	D2: General assembly & Leisure (Social Clu
Calculation Method	DSM - L5
Analysis Type	Part L2A England (EPC)

Project notes

New Extension only

2.4 IES 3D Thermal model

Site rotation (angle of North)	30.0 °
--------------------------------	--------



3. Calculations History

<i>Issue No.</i>	<i>Stage</i>	<i>KgCO₂/m²/y</i> <i>TER</i>	<i>KgCO₂/m²/y</i> <i>BER</i>	<i>%</i> <i>BER vs TER</i>	<i>Part L</i>	<i>EPC rating</i>	<i>Notes</i>	<i>Date</i>
1	As designed	22.6	23	-1.77%	FAIL		v01 initial simulation (all M&E specs assumed)	02/10/2018
2	As designed	22.6	22.6	0.00%	PASS		v02 amendments to achieve minimum 'as-design' pass	08/10/2018
3								

All assumptions (in red) must be reviewed by the design team and confirmed to HRS Services.

Variations made to the input parameters are likely to change the overall Building Emissions Rate and therefore may lead to non-compliance.

4. List of drawings

Name	revision	
	Issue date	Notes
17-1607-02A - Existing Floor Plans.pdf		received 04.07.2018
17-1607-03A - Fire Strategy Plan.pdf		received 04.07.2018
17-1607-04A - Proposed Floor Plan - 1 of 2.pdf		received 04.07.2018
17-1607-05A - Proposed Floor Plan - 2 of 2.pdf		received 04.07.2018
17-1607-06A - Proposed Roof Plan.pdf		received 04.07.2018
17-1607-07A - Proposed Sections.pdf		received 04.07.2018
17-1607-08A - Proposed Sections.pdf		received 04.07.2018
17-1607-09A - Proposed Elevations.pdf		received 04.07.2018
17-1607-10A - Proposed Elevations.pdf		received 04.07.2018

5. Opaque Elements

5.1 Ground Floors

ref.	Construction build up summary	U-value W/m ² K	Kappa	Source
	Floor Kingspan KS1000 RW Trapezoidal - U-value report	0.16	117.55	E-mail

5.2 Walls

ref.	Construction build up summary	U-value W/m ² K	Kappa	Source
	Wall Rockwool 100mm	0.29	105.07	
	Wall Kingspan Kooltherm k106 90mm- U-value report	0.17	105.07	TBC

5.3 Roofs & Ceilings

ref.	Construction build up summary	U-value W/m ² K	Kappa	Source
	Roof (Kingspan KS1000 RW Trapezoidal) - U-value report	0.18	1.49	E-mail

6. Openings

6.1 Solid opaque Doors

ref.	Build up	U-value W/m ² K	Source
	Door	1.6	TBC

6.2 Glazed Doors

ref.	Build up	U-value W/m ² K	G-value	LT value	Source
	(inputted as part of the glazing window system)				

6.3 Glazing windows & curtain walls

ref.	Build up	U-value W/m ² K	G-value	LT value	Source
	External glazing (including glazed doors)	2.0	0.65	0.82	TBC

6.4 Roof Windows & skylights

ref.	Build up	U-value W/m ² K	G-value	LT value	Source
	none				Drawings

6.5 Blinds

ref.	info	Source

7. Mechanical Ventilation

7.1 Supply and Extract AHU ref.	SFP (W/l/s)	thermal Heat recovery %	Notes	Source
none AHU				TBC

7.2 Zonal Extract or Supply Fan ref.	SFP (W/l/s)	Rates [ach]	Notes	Source
WCs	0.3	10.00		TBC
Bar	0.3	10.00	omitted	TBC
Kitchen	0.4	30.00		TBC

8. Space heating & cooling

8.1	System ref.	System description	Seas. eff	SCOP	SEER	EER	Source
	Sys 1	heating combi gas boiler Central heating using water: radiators	91.00%	-	-	-	TBC
	Sys 2						
	Sys 3						
	Sys 4						
	Sys 5						
	Sys 6						

9. DHWS (Domestic Hot Water System)

9.1	DHWS generator ref.	DHW heater type	Seasonal efficiency/C OP	delivery efficiency	System efficiency /COP	Notes	Source
	DHW 1	combi gas boiler	0.91			throughout the new extension	TBC
	DHW 2	electric heater	1.00			WCs	TBC
	DHW 3						
	DHW 4						
	DHW 5						

9.2	DHW Storage		Standing heat losses				
			Volume [L]	kWh/day	kWh/day/l	Notes	Source
	DHW 1	electric heater	15.00	0.62	0.04133	WCs (assumed Aquapoint AP3/15)	TBC
	DHW 2						
	DHW 3						
	DHW 4						
	DHW 5						

9.3	DHW Secondary Circulation data	y/n	Notes	Source
		No		TBC

9.3.1	pump power	Notes	Source
	<input type="text"/> W	<input type="text"/>	<input type="text"/>

9.3.2	loop (flow & return) length	Notes	Source
	<input type="text"/> m	<input type="text"/>	<input type="text"/>

9.3.4	Circulation losses	Notes	Source
	<input type="text"/> [w/m]	<input type="text"/>	<input type="text"/>

9.3.5	Timer switch	Notes	Source
	<input type="text"/>	<input type="text"/>	<input type="text"/>

10. Lighting system

10.1 NOTES: Extract from section 12.4 of the non-domestic building services compliance guide

"Lighting in new and existing buildings should meet the recommended minimum standards for:

i. efficacy (averaged over the whole area of the applicable type of space in the building) and controls in Table 42"

For general lighting in office, industrial and storage spaces:

The recommended minimum lighting efficacy with controls in new and existing buildings stipulates an initial luminaire lumens/circuit-watt of 55LL/cW under 2010 BR and 60LL/cW for 2013 BR

For general lighting in other types of space:

The average initial efficacy should be not less than 60 lamp lumens per circuit-watt under 2013 BR and 55 lamp lumens per circuit-watt under 2010 BR

10.2 Lighting efficacy

Input data method

Notes

Source

Total Average Lighting Efficacy (Lm/cW)

assumed 85Lm/W (instead of minimum 60Lm/W of Part L)

TBC

Notes

10.3 Lighting controls

Yes/No

Notes

Source

Photo-electric Daylight dimming and
PIR occ sens type + Man ON-Auto Dimm

PIR absence/occupancy sensors
(type Auto-ON-OFF)

Manual controls only

Display Manual Switching

Constant Illuminance controls

assumed PIR in WCs

assumed throughout the building (except above rooms with PIR)

TBC

TBC

11. Building Tests and Controls features

11.1 Fabric Air permeability

As designed m³/hr/m²@50Pa
Default Part L (area <500m²)

Measured (as-built) m³/hr/m²@50Pa

Source

11.2 Building Management System (BMS) & Controls features

	Controls & metering	Yes/No	Notes	Source
11.2.1	HVAC system metered (BMS)	No		Drawings
11.2.2	HVAC metered with 'out of range' values warn	No		Drawings
11.2.3	Lighting metered with 'out of range' values warn	No		Drawings
11.2.4	Power Factor Correction equipment	<0.9	none	Drawings
11.2.5	Demand Control Ventilation (DCV)	No		Drawings

11.3 Ductwork leakage pressure class

	Yes/No	Notes	Source
Low pressure A		n/a	
Low pressure B			
Low pressure C			

11.4 AHU casing leakage standards (Eurovent/CEN class)

	Yes/No	Notes	Source
class L1		n/a	
class L2			
class L3			

12. LZC's (Low or Zero Carbon Technologies)/Renewables

12.1	System ref.	LZC type	Yes/No	Notes	Source
	LZC 1	PV solar	No		
	LZC 2	CHP	No		
	LZC 3	Solar thermal	No		
	LZC 4	District heating scheme	No		
	LZC 5	Air source Heat pumps	No		

Notes - Brief description of the LZC system

Appendix A. Model Input Parameters

Room Name	Lighting and Controls												Systems		Mechanical Ventilation						
	Luminaire Efficacy (lm/W)	Light Power Density (W/m²/100lux)	Achieved Illuminance (lux)	Display Lighting Uses Efficient Lamps?	Display Lamp Efficacy (lm)	Display Lighting Time Switching?	Photoelectric Control?	Photoelectric Control Type	Photoelectric Sensor Time-swith?	Occupancy Sensing	Occupancy Time-swith?	Parasitic Power Lighting Controls (W/m²)	Heating / Cooling / Vent System	DHW System	Supply?	Supply SFP (W/l/s)	Extract?	Extract rate (l/s)	Extract SFP (W/l/s)	Extract Fan remote from zone?	DCV?
z0-A05 Bar	85.00	1.64		No		No	No			NONE			Heating gas boiler - Nat.Vent	DHW combi gas boiler	-	-	No				No
z0-A03 Corridor	85.00	2.01		No		No	No			NONE			None	DHW combi gas boiler	No		No				-
z0-A03b Corridor	85.00	2.89		No		No	No			NONE			None	DHW combi gas boiler	No		No				-
z0-A17 Corridors/Small Hall	85.00	1.63		No		No	No			NONE			None	DHW combi gas boiler	No		No				-
z0-A01 Small Hall/Meeting Room	85.00	1.43		No		No	No			NONE			Heating gas boiler - Nat.Vent	DHW combi gas boiler	-	-	No				No
z0-A04 Stage/Main Hall	85.00	1.73		No		No	No			NONE			Heating gas boiler - Nat.Vent	DHW combi gas boiler	-	-	No				No
z0-A02 Kitchen	85.00	1.80		No		No	No			NONE			Heating gas boiler - local extract fan	DHW combi gas boiler	No		Yes	253.76	0.40		No
z0-A18 Store bar	85.00	2.22		No		No	No			NONE			None	DHW combi gas boiler	No		No				-
z0-A23 Store	85.00	1.65		No		No	No			NONE			None	DHW combi gas boiler	No		No				-
z0-A24 Store	85.00	1.61		No		No	No			NONE			None	DHW combi gas boiler	No		No				-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
Roof Void	-	-		No		No	No			NONE			-	-	-	-	-	-	-		-
z0-A19 WC/Dis	85.00	2.56		No		No	No			AUTO-ON-OFF	No	0.10	Heating gas boiler - zonal extract fan	DHW combi gas boiler	No		Yes	23.34	0.40		No
z0-A20 WC/Male	85.00	1.88		No		No	No			AUTO-ON-OFF	No	0.10	Heating gas boiler - zonal extract fan	DHW combi gas boiler	No		Yes	52.89	0.40		No
z0-A21 WC/Female	85.00	3.48		No		No	No			AUTO-ON-OFF	No	0.10	Heating gas boiler - zonal extract fan	DHW combi gas boiler	No		Yes	14.09	0.40		No
z0-A22 WC/Female	85.00	3.58		No		No	No			AUTO-ON-OFF	No	0.10	Heating gas boiler - zonal extract fan	DHW combi gas boiler	No		Yes	12.67	0.40		No