



Provision of Heat Pumps and Ventilation.

GROUND FLOOR PLAN PHASE 1

- Key**
- Existing 4x 14 Watt T5 Luminaire
 - Proposed 4 x 14 Watt T5 or 4No required
 - 600mm x 600mm supply/extract grille
 - Fresh Air Vent within suspended ceiling
 - Wall mounted cassettes
 - 950mm x 950m Ceiling cassette
 - 600mm x 600mm Ceiling cassette
 - Route of refiring pipework on galv tray.

BUILDERS WORK
 Provide 1000mm x 1000mm x 150mm thick concrete base for external condenser.
 2 No 300mm dia holes in external wall
 1 No 100mm dia hole in external wall

Take down existing suspended ceiling on line of proposed galvanised tray, reinstaate and make good.

Rev. _____ Description _____ By _____ Date _____

Client _____

Maritime Coastguard Agency

Project
Crosskill House
Beverley

Drawing Title
M&E Proposals

Drawing No. **LEBS0789/M&E /01**

Scale **1:50 @ A1** Original Sheet Size A1

Drawing Status	
Drawn	Checked
JD	
Date	Rev.
06/17	A