

Fire Protection Notes:

- <u>Ductwork:</u> Where ductwork crossed a protected escape route or passes through a fire rated floor. Ducts shall be provided with fire dampers or for PVC flat duct, approved fire wrap.

- <u>Soil Pipework:</u> Where passing through fire rated floors shall be fitting with approved fire collars.

- Small Services: ie. Small bore pipework and cabling. All penetrations passing through fire rated structure shall be suitably fire stopped in accordance with approved details.



HEATRAE SADIA MULTIPOINT INSTANTANEOUS 7kW WATER HEATER Not to scale



HEATRAE SADIA MULTIPOINT 3kW 10 LITRE WATER HEATER Not to scale

GENERAL NOTES:

1. This drawing is not an Architects drawing and must not be interpreted as such.

2. Do not scale off this drawing.

3. This drawing must not be used for construction or

installation purposed unless stated. 4. All dimensions must be verified on site before

completing shop drawings or setting out the work.

5. This drawing to be read in conjunction with the relevant technical specifications.

6. This drawing is to be read in conjunction with Architectural and Structural Engineers drawings.

HW - Hot Water HL - High Level LL - Low Level TA - To Above TB - To Below FA - From Above FB - From Below SS - Stub Stack AAV - Air Admittance Valve

SVP - Soil Vent Pipe

SV - Solenoid Valve

Pipes Solid L/L

DCV - Double Check Valve

NRV - Non Return Valve

LSV - Lock Shield Valve IV - Isolation Valve STR - Strainer HTG - Heating CW - Cold Water TD - Tundish F - Flow R - Return

NRV - Non Return Valve

DRV - Double Regulating

S/C - Stop Cock

C/V - Control Valve

Pipes Hidden H/L ——————— Pipes Hidden L/L -----Pipes Exposed H/L ____ _ _ _ _ _ _

15/01/2020 17/12/2019 T0 TENDER ISSUE P1 UPDATED TO ARCHITECT'S COMMENTS. P0 INFORMATION 02/12/2019 REV MODIFICATIONS

CARNELL WARREN

ASSOCIATES DUKE HOUSE, DUKE STREET, WOKING, GU215BA

PROJECTS@CARNELLWARREN.CO.UK 01483 730995

The Almonry Battle

Ground Floor Domestic Water & Ventilation Services

Battle Town Council

SCALE @ A1 1:50 Nov '19

SLC

T0

1509/M/302