

LINEAR FITTINGS PROVIDED WITHIN VOIDS TO PROVIDE DIFFUSE LIGHTING ONTO LAY LIGHTS. TO BE COORDINATED WITH DUCTWORK TO PROVIDE THE MOST EVEN LIGHT DISTRIBUTION. LAY LIGHT GLASS TO BE SUITABLY OPAQUE, SO TO AVOID LINEAR HOT SPOTS OF LIGHT.

TRACK SUSPENDED ON SHORT WIRE LOCATED CENTRALLY ON FRIEZE WIDTH PANELS

TRACK TO BE SUSPENDED BY WIRE AS CONFIRMED BY MANUFACTURER, WHERE POSSIBLE WIRE CONNECTION AT HIGH POINT OF ROOF SHOWN TO BE AVOIDED.

- KEY:
- DO NOT SCALE FROM THIS DRAWINGS
 - TO BE READ IN CONJUNCTION WITH ALL MF SCHEDULES AND SPECIFICATIONS.
 - INSTALLATION TO BE IN ACCORDANCE WITH BS 7671: 18TH EDITION.
 - EMERGENCY LIGHTING TO BE ALLOWED WITH ON BOARD EMERGENCY BATTERY

- ⊗ ± SPOTLIGHT
- ⊗ DOWNLIGHT
- ⊗ WALL MOUNTED LUMINAIRE
- — — LINEAR LUMINAIRE
- ■ ■ LIGHTING TRACK
- - - LED TAPE
- LCP LIGHTING CONTROL PANEL
- CON LIGHTING INTERFACE PANEL

LINEAR LIGHTING LOCATED BEHIND LAY LIGHTS. LINEAR FITTINGS TO BE MOUNTED BETWEEN LAY LIGHT PANES TO IMPROVE DISTRIBUTION. FITTING TO BE COORDINATED WITH DUCT WORK AND TO BE MOUNTED AS HIGH AS FEASIBLE TO IMPROVE DIFFUSION OF LIGHT TO REDUCE LIGHTING HOT SPOTS

TRACK TO BE SHORT SUSPENDED OFF FRIEZE PANELS

TRACK PROVIDED TO ALLOW FOR LIGHTING OF BACK WALL. TRACK SUSPENDED BY WIRE FROM EDGES OF ALVOCE

TRACK SUSPENDED BY WIRE FROM TOP OF ALCOVE. TRACK LOCATED AWAY FROM WALL TO ALLOW FOR ILLUMINATION OF ART WORK MOUNTED ON WALLS. TRACK TO BE CONNECTED BY DALI CABLE. CABLE TO BE RUN WITHIN WALL BUILD UP AND ALONG SUPPORTING WIRES WHERE POSSIBLE TO MINIMISE VISUAL IMPACT

TRACK RUNS ALONG EACH TRUSS LINE WITHIN GALLERY TO PROVIDE A UNIFORM SPACING THAT TIES INTO ARCHITECTURE AND CAN PROVIDE LIGHTING FROM DIFFERENT ANGLE

LINEAR LIGHTING LOCATED BEHIND LAY LIGHTS. LINEAR FITTINGS TO BE MOUNTED BETWEEN LAY LIGHT PANES TO IMPROVE DISTRIBUTION. FITTING NOT BE COORDINATED WITH DUCT WORK AND TO BE MOUNTED AS HIGH AS FEASIBLE TO IMPROVE DIFFUSION OF LIGHT TO REDUCE LIGHTING HOT SPOTS

TRACK TO BE SHORT SUSPENDED OFF FRIEZE PANELS

NEW LIGHTING CONTROL PANEL LCP.1/2 TO CONTROL LIGHTING WITHIN GALLERIES 1 AND 2

ALLOWANCE TO BE MADE FOR EMERGENCY EXIT SIGNS. LOCATION OF EMERGENCY EXIT IS ASSUMED TO BE AND TO REMAIN STAIRCASE

LIGHTING TRACK TO BE RECESSED INTO SUSPENDED CEILING TO ALLOW FOR EXHIBITION LIGHTING TO ILLUMINATE RISER WALLS. TRACK LOCATION TO BE COORDINATED WITH VENTILATION SLOT.

P02	06/11/20	TENDER		LE
P01	16/10/20	STAGE 4 - DRAFT FOR COMMENT		LE
A	08/10/20	STAGE 4 - DRAFT FOR COMMENT		LE
*	21/08/20	STAGE 4 - DRAFT ISSUE		SH
rev	date	description		eng

MAX FORDHAM

Max Fordham LLP
Carver's Warehouse
77 Dale Street
Manchester
M1 2HG
T. +44 (0) 161 312 8071
F. +44 (0) 20 7482 0329
maxfordham.com

Registered Office 42-43 Gloucester Crescent London NW1 7PE

architect
DONALD INSALL ASSOCIATES

job title
WALKER ART GALLERY

project leader date scale (at A1)
MD AUG '20 1:50

drawing title
LIGHTING LAYOUT FIRST FLOOR 2/2

job no dwg no rev
6683 6683-MXF-XX-01-DR-E-30100 / P02

© Copyright Max Fordham LLP