

Grille and Louvre Schedule							
Reference	Description	Area	Manufacturer	Model	Duty/Size	Dimensions (WxLxH) mm	Notes
Grilles and Valves							
EG 01	Extract Linear Bar Grille with double deflection diffuser	Market Hall	GDL	Double Deflection grille	600 l/s	1200x300	S0200+1C RAL colour finish to match ceiling colour - Architect to confirm Bespoke plenum required with spigots for 2no. 3500x200mm ducts
EG 02	Extract Valve	WC areas	Gilberts	GX150	10 l/s 25 Pa P.D.	Ø202x95	White finish
EG 03	Extract Valve	WC areas	Gilberts	GX150	25 l/s 25 Pa P.D.	Ø202x95	White finish
SG 01	Supply Linear Bar Grille with double deflection diffuser	Market Hall	GDL	Double Deflection grille	600 l/s	1200x300	S0200+1C RAL colour finish to match ceiling colour - Architect to confirm Bespoke plenum required with spigots for 2no. 3500x200mm ducts
SG 02	Supply Valve	Offices and Counselling rooms	Gilberts	SX150	20 l/s 25 Pa P.D.	Ø202x95	White finish
Transfer Grilles							
TG01	Transfer Grille	Offices and Counselling rooms	Lorient	LVN20	30% free area	200x200 (with fixing flange)	- Polyester Powder coated to match door colour (see architects door schedule) - Grille Covers either side of door - Standard Grille with 40mm pitch