

	Clarification Question	
	Question	Response
1	Would you also want a service contract for these units following installation?	<ul style="list-style-type: none"> <li>- Please refer to ITT where information required from tenderers in respect of service contracts is set out in the Price Criteria.</li> </ul>
2	What is the required maximum load for the new exhibition lift?	<ul style="list-style-type: none"> <li>- As per the performance specification of the exhibition lift it is 2000kg/26 persons</li> </ul>
3	What is happening to the wooden beam that is currently blocking where the 8-person lift will go in the SE corner?	<ul style="list-style-type: none"> <li>- The wooden beam will be trimmed back to allow the shaft to pass by.</li> </ul>
4	Is there a secondary, back-up power supply available for the evacuation lift?	<ul style="list-style-type: none"> <li>- Secondary power supplies will be provided for lifts 2 and 3, and specified by the Electrical Services consultants. They will be UPS battery units.</li> </ul>
5	If there is no back-up supply has it been considered that batteries will require replacing periodically (I think they said every 5-7 years) which will be very costly (£10k).	<ul style="list-style-type: none"> <li>- Lift suppliers are not required to provide the back-up supplies with their installation</li> </ul>

Clarification Deadline is Monday 21<sup>st</sup> October 2024 at Midday (1200)