



CERTIFICATE OF IDENTIFICATION OF ASBESTOS FIBRES

SITE ADDRESS:	APEX HOUSE, 3 EMBASSY DRIVE, B15 1TR
SITE REF NO.	N/A

CERTIFICATE NUMBER	ATH/16/06/0762
DATE SAMPLED	UNKNOWN
DATE RECEIVED	14/06/16
DATE ANALYSED	14/06/16
NO. OF SAMPLES	8
PAGE NUMBER	1 OF 1
OBTAINED	DELIVERED

CLIENT	TES ENVIRONMENTAL SERVICES LTD
ADDRESS	UNIT 6 GRIFFIN BUSINESS PARK WALMER WAY BIRMINGHAM, B37 7UX
PHONE NUMBER	0121 244 0427

SAMPLE NUMBER	CLIENT NUMBER	SAMPLE LOCATION	MATERIAL TYPE	FIBRE TYPE DETECTED
1	001	BASEMENT LIFT LOBBY – WALL PANEL	INSULATING BOARD	NADIS
2	002	BASEMENT LIFT LOBBY CEILING FIRE PROTECTION	FIBREGLASS INSULATION	NADIS
3	003	BASEMENT CAR PARK – CEILING FIRE PROTECTION	FIBREGLASS INSULATION	NADIS
4	004	BASEMENT CAR PARK – CEILING FIRE PROTECTION	FIBREGLASS INSULATION	NADIS
5	005	BASEMENT CAR PARK – CEILING FIRE PROTECTION	FIBREGLASS INSULATION	NADIS
6	006	BASEMENT CAR PARK – CEILING FIRE PROTECTION	FIBREGLASS INSULATION	NADIS
7	007	GROUND FLOOR PIPE GASKET	GASKET	CHRYSTILE
8	008	1 ST FLOOR – PIPE GASKET	GASKET	CHRYSTILE

<p>KEY: CHRYSTILE – WHITE ASBESTOS CROCIDOLITE – BLUE ASBESTOS AMOSITE – BROWN ASBESTOS NADIS – NO ASBESTOS DETECTED IN SAMPLE</p> <p>TREMOLITE, ANTHOPHYLLITE & ACTINOLITE – LESS COMMON ASBESTOS FIBRE TYPES</p> <p>Note: When a trace of asbestos fibres are reported this represents one or two fibres only.</p> <p>Note: The material type reported is an opinion of the analyst only and does not form part of the ATHENA UKAS accreditation.</p> <p>Note: Samples will be kept for a minimum of 6 months.</p> <p>Note: This Certificate of Identification of Asbestos Fibres can only be reproduced in full unless written approval from Athena has been obtained.</p> <p>Note: If the sample condition or size is deemed unacceptable or unsatisfactory by the analyst, the client will be contacted.</p> <p>Note: The results relate only to the items tested.</p>			
ANALYST NAME AND SIGNATURE:	B. HOPSON 	AUTHORISER NAME AND SIGNATURE:	B. HOPSON 
<p>Samples have been analysed to determine the presence of asbestos fibres using Athena Environmental Solutions “in house” method of polarised light microscopy and central stop dispersion staining based on HSG 248. The site address and sample locations are given by the client and Athena are not responsible for the accuracy or competence of these details or of the sampling.</p> <p>BULK 001 VERSION 4 – 02/03/15</p>			