



Engineering Services Laboratory  
Radnor Road, Scorrier, Redruth TR16 5EH  
TEL : 01872 327381 FAX : 01209 821539



## **Asbestos Management Survey**

|                        |                                                              |                            |                            |
|------------------------|--------------------------------------------------------------|----------------------------|----------------------------|
| <b>Site Address:</b>   | New Polzeath Toilets<br>Gulland Road<br>Cornwall<br>PL27 6UG | <b>Surveyors:</b>          | Dave Matthews<br>Lin Noble |
| <b>UPRN number:</b>    | 14467                                                        | <b>Report prepared by:</b> | Victoria Colliver          |
| <b>Project number:</b> | 76917                                                        | <b>Date of survey:</b>     | 11/10/2012                 |
|                        |                                                              | <b>Report Date:</b>        | 25/10/2012                 |

### **Executive Summary**

A management survey has been undertaken within New Polzeath Toilets, in which asbestos was not detected within the areas surveyed.

Fixed ceilings were encountered (see Table 3, Appendix 2 for location); in order to inspect the ceiling void builder support will have to be organised to create access and make good any damage. It was also not possible to inspect within the boxing in the Mens & Ladies WC.

It should be assumed that asbestos materials exist within any non accessed areas until an inspection has been completed.

If any future refurbishment/ work is to be undertaken within the building a more comprehensive Refurbishment Survey may be required prior to the work commencing.

### **Introduction**

#### **Scope of work, purpose, aims and objectives:**

To complete an asbestos survey within New Polzeath Toilets in order to comply with Control of Asbestos Regulations 2012 (CAR 2012). The survey was carried out by CORMAC Solutions Engineering Services Laboratory on behalf of Roger Westcott, CORMAC Solutions.

The purpose and aim of this survey was to locate, as far as reasonably practicable, the presence and extent of any suspected Asbestos Containing Material's (ACM's) in the areas inspected/surveyed which could be damaged or disturbed during normal occupancy, including foreseeable maintenance and installation, and to assess their condition.

Representative samples are collected and analysed using polarised light microscopy. If, when tested, the material was found to contain asbestos, material assessment algorithms are assigned to assess the potential risk of fibre release (taken from HSG264). Other similar homogenous material used for the same purpose was also presumed to contain asbestos (strongly presumed).

## Method

A management survey, carried out in accordance with Health & Safety Executives publication HSG264 'Asbestos: The survey guide' and the in-house 'Asbestos Surveying Technical Procedure A1', has been conducted on the areas listed below at the above site.

### Areas Included In Survey (See attached plan Appendix 1)

The areas included in survey were:

- See Table 3

All other areas of the site, except those listed above, were not surveyed and are therefore not included within this report.

### Inaccessible/ Excluded Areas

The areas included in the survey brief that could not be accessed were:

- See Table 3

The areas excluded from the survey (i.e. not reasonably practicable to access during the survey):

- concealed spaces which may exist within the fabric of the building where the extent and presence of these is not evident due to inaccessibility or insufficient knowledge of the structure at the time of the survey;
- fixed voids (under floors, within walls or above fixed ceilings, where the act of surveying/sampling would damage the fabric of the building);
- within live electrical equipment/ general equipment where the act of sampling would endanger the surveyor or affect the functional integrity of the item concerned. For example; fuses within electrical boxes, gaskets, fire doors, ropes associated with heating, glazing or power plant etc.

**Any inaccessible/excluded areas must be presumed to contain asbestos, unless there is strong evidence that it does not. If access is required to these items the client must provide access/isolation certificates before areas/electrical appliances are inspected.**

### Survey Results/Findings

For survey results see Table 1 (within Appendix 2). This table shows all ACM's present (please note that only positive, Strongly Presumed and Presumed (highly likely to contain asbestos but not sampled) ACM's will be recorded) along with any areas not accessed. Samples of Non-ACM's are recorded on Table 2. Representative photographs of materials are shown in Appendix 3.

Where appropriate, samples of suspected ACM's were taken from the property, representative samples were also taken of any materials that may be confused with ACM's. Sample stickers, bearing the individual sample's unique number, were applied to the point of

sampling, for future reference (unless requested not to be used by the client). Products that were very unlikely to contain asbestos or have asbestos added were not sampled (e.g. wallpaper, plasterboard etc.).

Any samples taken were returned to the laboratory for analysis by Polarised Light Microscopy (PLM) using a documented In-House Procedure, No: A3 'Bulk Analysis', based on HSG 248 'Asbestos: The analysts' guide for sampling, analysis and clearance procedures' – results of which can be found in Appendix 4.

### **Variations/deviations**

No variations or deviations from the In-House Procedure were recorded at the time of the survey.

### **Conclusions and actions**

No asbestos containing materials were detected in the areas surveyed.

Fixed ceilings were encountered (see Table 3, Appendix 2 for location); in order to inspect the ceiling void builder support will have to be organised to create access and make good any damage. It was also not possible to inspect within the boxing in the Mens & Ladies WC.

It should be assumed that asbestos materials exist within any non accessed areas until an inspection has been completed.

If any future refurbishment/ work is to be undertaken within the building a more comprehensive Refurbishment Survey may be required prior to the work commencing.

Authorised by:



Paul Laban- Geo-environmental Engineer

Surveyed by:





Dave Matthews- Geoenvironmental Technician

## **APPENDIX 1**

### **PLAN**


# Legend



| ID | Rev | Description | Drawn | Check | Date |
|----|-----|-------------|-------|-------|------|
|    |     |             |       |       |      |

Property: New Polzeath Toilets  
UPRN: 14467  
Title: ACM Location Plan

| Scale  | WTS      | Drawn   | UC | Drawn   | UC |
|--------|----------|---------|----|---------|----|
| Date:  | 24/05/12 | Checked |    | Checked |    |
| Sample | 17/05/12 |         |    |         |    |
|        |          |         |    |         |    |



14467 - NEW POLZEATH TOILETS

## **APPENDIX 2**

### **TABLES 1, 2 & 3**



**Table 1: Asbestos Containing Materials (including presumed materials not sampled and no access areas)**

| B | F | R | Room Description | Sample Ref. No. | Material Location | Approx. Quantity (m <sup>2</sup> ) | Product Type | Asbestos Type | Surface Treatment | Condition | Material Assem't Score | Accessibility | Comments |
|---|---|---|------------------|-----------------|-------------------|------------------------------------|--------------|---------------|-------------------|-----------|------------------------|---------------|----------|
|   |   |   |                  |                 |                   |                                    |              |               |                   |           |                        |               |          |

No asbestos containing materials sampled during survey

**KEY:** P = PRESUMED; SP = STRONGLY PRESUMED. Accessibility - low, medium or high based on surveyors opinion. N/A = Not Applicable

**Table 2: Suspect Asbestos Containing Materials found not to contain asbestos**

| B | F | R | Room Description | Sample Ref No | Material Location | Material Type | Asbestos Not Detected | Comments |
|---|---|---|------------------|---------------|-------------------|---------------|-----------------------|----------|
|   |   |   |                  |               |                   |               |                       |          |

No non-asbestos containing materials sampled during survey

**Table 3: Areas inspected & areas not accessed**  
(please note if not on this table or in area not accessed assume asbestos may be present until proven otherwise)

| B | F | R   | Room Description | Area/s requested to be Inspected | Areas not accessed & reason                      | Comments |
|---|---|-----|------------------|----------------------------------|--------------------------------------------------|----------|
| 1 | 0 | 001 | Gents Toilet     | Full management survey           | Ceiling void, fixed ceiling & within wood boxing | -        |
| 1 | 0 | 002 | Ladies Toilet    | Full management survey           | Ceiling void, fixed ceiling & within wood boxing | -        |
| 1 | 0 | 003 | Disabled Toilet  | Full management survey           | Ceiling void, fixed ceiling                      | -        |
| 1 | - | EXT | Externals        | Full management survey           | -                                                | -        |

## **APPENDIX 3**

### **PHOTOS**





**Photo 1: Showing external area to New Polzeath Toilets**

## **APPENDIX 4**

### **BULK ANALYSIS REPORT**

**N/A**

## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations by an Approved Contractor or Confirming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU6 5ZK

Original (No the person ordering the work)

### A. DETAILS OF THE CLIENT

Client: *Cornwall Council*

Address: *New County Hall,  
Truro*

Postcode:

### B. PURPOSE OF THE REPORT

This report must be used only for reporting on the condition of an existing installation.

Purpose for which this report is required:

*Annual inspection & test due.*

Date(s) on which inspection and testing were carried out:

*23.6.14*

### C. DETAILS OF THE INSTALLATION

Occupier: *Cornwall Council*

Address: *New Polzeath Tolets,  
Gulland Rd.,  
Cornwall*

Postcode: *PL27 6UG*

Estimated age of the electrical installation:

*20 years*

Description of premises: domestic, commercial, industrial, other (Please state)

*Commercial*

Evidence of alterations or additions

☒

If yes, estimated age

*1 years*

Date of previous inspection:

*29.4.13*

Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No:

*IPN3/0218296*

Records of installation available:

*NO*

Records held by:

*NA*

### D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:

*Supply, consumer unit, circuits & accessories.*

Agreed limitations including the reasons, if any, on the inspection and testing:

*Unable to find Main water supply entry point.*

Agreed with:

Operational limitations including the reasons (see page No. )

*No I.R. tests (L-N & L-L 'Microwaves' sensors)*

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected.

### E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

*Good*

Summary of the condition of the installation continued on additional pages? No ☒ Yes ☐ Specify page

Overall assessment of the installation:

**SATISFACTORY / UNSATISFACTORY** (Delete as appropriate)

An 'Unsatisfactory' assessment indicates that dangerous and/or potentially dangerous conditions have been identified

This report should have been reviewed and confirmed by the registered Qualified Supervisor of the Approved Contractor responsible for issuing it. (See declaration on page 2)

This report is based on the model forms shown in Appendix 6 of BS 7671

Published by NICEIC, a part of the Ascotiva Group © Copyright The Electrical Safety Council (July 2011)

IPN3/1

Page 1 of

8

Please see the 'Notes for Recipients' on the reverse of this page.

## ELECTRICAL INSTALLATION CONDITION REPORT

### F. OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

Referring to the attached schedules of inspection and test results, and subject to the limitations at D:

There are no items adversely affecting electrical safety

or

The following observations and recommendations for  
action are made

| Item No                                | Observations                                            | Classification<br>code † | Further investigation<br>required (Y or ✓) |
|----------------------------------------|---------------------------------------------------------|--------------------------|--------------------------------------------|
| 1                                      | Main Switch RCD failed to operate.                      | C2                       |                                            |
| 2                                      | Socket RCD failed to operate by<br>test or test button. | C2                       |                                            |
| (Both items replaced at time of test). |                                                         |                          |                                            |

Additional pages? No Yes Specify page No(s):

† One of the following codes, as appropriate, has been allocated to each of the  
observations made above to indicate to the person(s) responsible for the installation  
the degree of urgency for remedial action:

Code C1 'Danger present'. Risk of injury. Immediate remedial action required.

Code C2 'Potentially dangerous'. Urgent remedial action required.

Code C3 'Improvement recommended'.

Please see the reverse of this page for guidance regarding the Classification codes.

Immediate remedial action  
required for items:

Urgent remedial action  
required for items:

1 & 2

Further investigation  
required for items:

Improvement  
recommended for items:

### G. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signature(s) below), particulars of which  
are described in page 1 (see C), having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information  
in this report, including the observations (see F) and the attached schedules (see H), provides an accurate assessment of the condition of the electrical  
installation taking into account the stated extent of the installation and the limitations of the inspection and testing (see D).

I/We further declare that in my/our  
judgment, the said installation was overall in

**SATISFACTORY / UNSATISFACTORY\***

condition (see F) at the time the inspection was carried out, and that it  
should be further inspected as recommended (see I).

\* Delete as appropriate

INSPECTION, TESTING AND ASSESSMENT BY:

Signature:

Name:  
(CAPITALS)

Position:

Date:

**D. MAHONEY**  
**ELECTRICIAN**

23.6.14

REPORT REVIEWED AND CONFIRMED BY:

Signature:

Name:  
(CAPITALS)

**JAMES ASSIE**  
(Registered Qualified Supervisor for the Approved Contractor at J)

Date:

5-11-14

# ELECTRICAL INSTALLATION CONDITION REPORT

## H. SCHEDULES AND ADDITIONAL PAGES

Inspection Schedule: Page(s) No 4, 5, 6

Additional pages, including additional source(s) data sheets:

Page No(s)

Schedule of Circuit Details for the Installation: Page No(s) 7

Schedule of Test Results for the Installation: Page No(s) 8

The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

## I. NEXT INSPECTION

If/We recommend that this installation is further inspected and tested after an interval of not more than

12 months

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or require further investigation are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

## J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading title:

Cornac Solutions Ltd.

Address:

Castle Caryke,  
Bodmin.

Telephone number:

Email address:



Enrolment number:  
(Essential information)

601499

Postcode: PL31 1DZ

Branch number:  
(if applicable)

## K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

| System type(s) | Number and type of live conductors |                  |        | Nature of supply parameters                         |                            | Characteristics of primary supply overcurrent protective device(s) |       |
|----------------|------------------------------------|------------------|--------|-----------------------------------------------------|----------------------------|--------------------------------------------------------------------|-------|
| TNS            | n.c.                               | ✓                | d.o.   | Nominal voltage(s):                                 | 230 V U <sub>0</sub> 234 V | BS(EN)                                                             | 88    |
| TNCS           | 1-phase (2-wire) ✓                 | 1-phase (3-wire) | 2-pole | Nominal frequency, f <sub>n</sub>                   | 50 Hz                      | Type                                                               | RHL   |
| TNC            | 2-phase (3-wire)                   |                  | 3-pole | Prospective fault current, I <sub>p</sub>           | 0.0067 kA                  | Rated current                                                      | 60 A  |
| TT ✓           | 3-phase (3-wire)                   | 3-phase (4-wire) | other  | External earth fault loop impedance, Z <sub>e</sub> | 34.1 Ω                     | Short-circuit capacity                                             | kA    |
| IT             | Other                              | Please state     |        | Number of sources                                   | 1                          | Confirmation of supply polarity                                    | ✓ (✓) |

## L. PARTICULARS OF INSTALLATION AT THE ORIGIN

| Means of earthing               |                                             | Details of installation earth electrode (where applicable) |  |
|---------------------------------|---------------------------------------------|------------------------------------------------------------|--|
| Distributor's facility:         | Type: (e.g. rod, tape(s) etc)               | Location:                                                  |  |
| Installation earth electrode: ✓ | Electrode resistance, R <sub>A</sub> : 34.1 | Method of measurement: (c) Loop tester                     |  |

| Main switch or circuit-breaker                    |                                                   | Earthing and protective bonding conductors |                                         |
|---------------------------------------------------|---------------------------------------------------|--------------------------------------------|-----------------------------------------|
| Type: BS(EN)                                      | Voltage rating                                    | Earthing conductor                         | Main protective bonding conductors      |
| 61009                                             | 230 V                                             | Conductor material: Copper                 | Conductor material: Copper              |
| No of poles: 2                                    | Rated current, I <sub>n</sub> : 80 A              | Conductor csa: 16 mm <sup>2</sup>          | Conductor csa: 10 mm <sup>2</sup>       |
| Primary supply conductors material: Copper        | RCD operating current, I <sub>Δn</sub> : 100 mA   | Connection/continuity verified: ✓ (✓)      | Connection/continuity verified: 1 m (✓) |
| Primary supply conductors csa: 25 mm <sup>2</sup> | Rated time delay: NA ms                           |                                            |                                         |
|                                                   | RCD operating time (at I <sub>Δn</sub> ): FAIL ms |                                            |                                         |

\* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

# ELECTRICAL INSTALLATION CONDITION REPORT

## INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

| Item | Description                                                                                                                            | Outcome* | Location reference |
|------|----------------------------------------------------------------------------------------------------------------------------------------|----------|--------------------|
| 1.0  | Condition/adequacy of distributor's/supply intake equipment                                                                            |          |                    |
| 1.1  | Service cable                                                                                                                          | ✓        |                    |
| 1.2  | Service cut-out/fuse(s)                                                                                                                | ✓        |                    |
| 1.3  | Meter tails - distributor                                                                                                              | ✓        |                    |
| 1.4  | Meter tails - consumer                                                                                                                 | ✓        |                    |
| 1.5  | Metering equipment                                                                                                                     | ✓        |                    |
| 1.6  | Means of main isolation (where present)                                                                                                | ✓        |                    |
| 2.0  | Presence of adequate arrangements for parallel or switched alternative sources                                                         | NA       |                    |
| 3.0  | Automatic disconnection of supply                                                                                                      |          |                    |
| 3.1  | Main earthing and bonding arrangements                                                                                                 |          |                    |
|      | • Presence and condition of distributor's earthing arrangement                                                                         | NA       |                    |
|      | • Presence and condition of earth electrode arrangement                                                                                | ✓        |                    |
|      | • Adequacy of earthing conductor size                                                                                                  | ✓        |                    |
|      | • Adequacy of earthing conductor connections                                                                                           | ✓        |                    |
|      | • Accessibility of earthing conductor connections                                                                                      | ✓        |                    |
|      | • Adequacy of main protective bonding conductor size(s)                                                                                | ✓        |                    |
|      | • Adequacy of main protective bonding conductor connections                                                                            | lim      |                    |
|      | • Accessibility of main protective bonding connections                                                                                 | lim      |                    |
|      | • Provision of earthing/bonding labels at all appropriate locations                                                                    | ✓        |                    |
| 3.2  | FELV                                                                                                                                   |          |                    |
|      | • Source providing at least simple separation                                                                                          | ✓        |                    |
|      | • Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises                               | NA       |                    |
| 3.3  | Reduced low voltage                                                                                                                    |          |                    |
|      | • Adequacy of source                                                                                                                   | ✓        |                    |
|      | • Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises                               | NA       |                    |
| 4.0  | Other methods of protection (where the methods of protection listed below are employed, details should be provided on separate sheets) |          |                    |
| 4.1  | Double insulation                                                                                                                      | NA       |                    |
| 4.2  | Reinforced insulation                                                                                                                  | NA       |                    |
| 4.3  | Use of obstacles                                                                                                                       | ✓        |                    |
| 4.4  | Placing out of reach                                                                                                                   | NA       |                    |
| 4.5  | Non-conducting location                                                                                                                | NA       |                    |
| 4.6  | Earth-free local equipotential bonding                                                                                                 | NA       |                    |
| 4.7  | Electrical separation for more than one item of equipment                                                                              | NA       |                    |
| 5.0  | Distribution equipment                                                                                                                 |          |                    |
| 5.1  | Adequacy of working space/accessibility of equipment                                                                                   | ✓        |                    |
| 5.2  | Security of fixing                                                                                                                     | ✓        |                    |
| 5.3  | Condition of insulation of live parts                                                                                                  | ✓        |                    |
| 5.4  | Adequacy/security of barriers                                                                                                          | ✓        |                    |
| 5.5  | Condition of enclosure(s) in terms of IP rating                                                                                        | ✓        |                    |
| 5.6  | Condition of enclosure(s) in terms of fire rating                                                                                      | ✓        |                    |
| 5.7  | Enclosure not damaged/deteriorated so as to impair safety                                                                              | ✓        |                    |
| 5.8  | Presence of main switch(es), linked where required                                                                                     | ✓        |                    |
| 5.9  | Operation of main switch(es) (functional check)                                                                                        | ✓        |                    |
| 5.10 | Correct identification of circuit protective devices                                                                                   | ✓        |                    |
| 5.11 | Adequacy of protective devices for prospective fault current                                                                           | ✓        |                    |
| 5.12 | RCD(s) provided for fault protection - includes RCBOs                                                                                  | ✓        |                    |

\* All boxes must be completed.

✓ Indicates Acceptable condition

'lim' indicates a Limitation

'NA' indicates Not applicable

Unacceptable condition state C1 or C2

Improvement recommended state C3

Further investigation required state F1  
(to determine whether danger or potential danger exists)

Outcome

Provide additional comment where appropriate on attached numbered sheets C1, C2 and C3 coded items to be recorded in section F of the report.

# ELECTRICAL INSTALLATION CONDITION REPORT

## INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

| Item | Description                                                                                                                                                                                                                                                                                                                                                                                                           | Outcome* | Location reference |
|------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|--------------------|
| 5.13 | RCD(s) provided for additional protection - Includes RCBOs                                                                                                                                                                                                                                                                                                                                                            | /        |                    |
| 5.14 | RCD(s) provided for protection against fire - Includes RCBOs                                                                                                                                                                                                                                                                                                                                                          | /        |                    |
| 5.15 | Manual operation of circuit-breakers and RCDs to prove disconnection                                                                                                                                                                                                                                                                                                                                                  | /        |                    |
| 5.16 | Presence of RCD retest notice at or near equipment where required                                                                                                                                                                                                                                                                                                                                                     | /        |                    |
| 5.17 | Presence of diagrams, charts or schedules at or near equipment where required                                                                                                                                                                                                                                                                                                                                         | /        |                    |
| 5.18 | Presence of non-standard (mixed) cable colour warning notice at or near equipment where required                                                                                                                                                                                                                                                                                                                      | /        |                    |
| 5.19 | Presence of alternative supply arrangement warning notice(s) at or near equipment where required                                                                                                                                                                                                                                                                                                                      | NA       |                    |
| 5.20 | Presence of replacement next inspection recommendation label                                                                                                                                                                                                                                                                                                                                                          | /        |                    |
| 5.21 | Presence of other required labelling (specify)                                                                                                                                                                                                                                                                                                                                                                        | NA       |                    |
| 5.22 | Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)                                                                                                                                                                                                                                                                             | /        |                    |
| 5.23 | Protection against mechanical damage where cables enter equipment                                                                                                                                                                                                                                                                                                                                                     | /        |                    |
| 5.24 | Protection against electromagnetic effects where cables enter metallic enclosures                                                                                                                                                                                                                                                                                                                                     | /        |                    |
| 6.0  | Distribution/final circuits                                                                                                                                                                                                                                                                                                                                                                                           |          |                    |
| 6.1  | Identification of conductors                                                                                                                                                                                                                                                                                                                                                                                          | /        |                    |
| 6.2  | Cables correctly supported throughout their length                                                                                                                                                                                                                                                                                                                                                                    | /        |                    |
| 6.3  | Condition of insulation of live parts                                                                                                                                                                                                                                                                                                                                                                                 | /        |                    |
| 6.4  | Non-sheathed cables protected by enclosure in conduit, duct or trunking                                                                                                                                                                                                                                                                                                                                               | NA       |                    |
| 6.5  | Suitability of containment systems for continued use (including flexible conduit)                                                                                                                                                                                                                                                                                                                                     | /        |                    |
| 6.6  | Cables correctly terminated in enclosures (indicate extent of sampling in Section D of report)                                                                                                                                                                                                                                                                                                                        |          |                    |
| 6.7  | Examination of cables for signs of unacceptable thermal and mechanical damage/deterioration                                                                                                                                                                                                                                                                                                                           | /        |                    |
| 6.8  | Adequacy of cables for current-carrying capacity with regard to the type and nature of installation                                                                                                                                                                                                                                                                                                                   | /        |                    |
| 6.9  | Adequacy of protective devices; type and rated current for fault protection                                                                                                                                                                                                                                                                                                                                           | /        |                    |
| 6.10 | Presence and adequacy of circuit-protective conductors                                                                                                                                                                                                                                                                                                                                                                | /        |                    |
| 6.11 | Co-ordination between conductors and overload protective devices                                                                                                                                                                                                                                                                                                                                                      | /        |                    |
| 6.12 | Cable installation methods/practices appropriate to the type and nature of installation and external influences                                                                                                                                                                                                                                                                                                       | /        |                    |
| 6.13 | Cables where exposed to direct sunlight, of a suitable type                                                                                                                                                                                                                                                                                                                                                           | /        |                    |
| 6.14 | Concealed cables installed in prescribed zones (see extent and limitations)                                                                                                                                                                                                                                                                                                                                           | /        |                    |
| 6.15 | Concealed cables incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage caused by nails, screws and the like where not in prescribed zones or not protected by 30 mA RCD (see extent and limitations)                                                                                                                                          | NA       |                    |
| 6.16 | Provision of additional protection by 30 mA RCD for cables concealed in walls or partitions                                                                                                                                                                                                                                                                                                                           | /        |                    |
| 6.17 | Provision of additional protection by 30 mA RCD <ul style="list-style-type: none"> <li>Where reasonably likely to be used to supply mobile equipment for use outdoors</li> <li>For all socket-outlets of rating 20 A or less provided for use by ordinary persons</li> </ul>                                                                                                                                          | /        |                    |
| 6.18 | Provision of fire barriers, sealing arrangements and protection against thermal effects                                                                                                                                                                                                                                                                                                                               | /        |                    |
| 6.19 | Band II cables segregated/separated from Band I cables                                                                                                                                                                                                                                                                                                                                                                | NA       |                    |
| 6.20 | Cables segregated/separated from non-electrical services                                                                                                                                                                                                                                                                                                                                                              | /        |                    |
| 6.21 | Termination of cables at enclosures (identify numbers and locations of items inspected in Section D) <ul style="list-style-type: none"> <li>Connections under no undue strain</li> <li>No basic insulation of a conductor visible outside an enclosure</li> <li>Connections of live conductors adequately enclosed</li> <li>Adequacy of connection at point of entry to enclosure (gland, bush or similar)</li> </ul> | /        |                    |
| 6.22 | General condition of wiring systems                                                                                                                                                                                                                                                                                                                                                                                   | /        |                    |
| 6.23 | Temperature rating of cable insulation                                                                                                                                                                                                                                                                                                                                                                                | /        |                    |
| 6.24 | Condition of accessories including socket-outlets, switches and joint boxes                                                                                                                                                                                                                                                                                                                                           | /        |                    |
| 6.25 | Suitability of accessories for external influences                                                                                                                                                                                                                                                                                                                                                                    | /        |                    |

\* All boxes must be completed.

✓ indicates Acceptable condition

NA indicates Not applicable

Unacceptable condition state C1 or C2

Improvement recommended state C3

Further investigation required state F/I (to determine whether danger or potential danger exists)

Outcome

Provide additional comment where appropriate on attached numbered sheets, C1, C2 and C3 coded items to be recorded in section F of the report.

Page 5 of

8

This report is based on the model forms shown in Appendix 6 of BS 7671

Published by NICEIC, a part of the Ascotiva Group © Copyright The Electrical Safety Council (July 2011)

IPN3/29

Original (to the person ordering the work)

# ELECTRICAL INSTALLATION CONDITION REPORT

## INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

| Item | Description                                                                                                                                              | Outcome* | Location reference |
|------|----------------------------------------------------------------------------------------------------------------------------------------------------------|----------|--------------------|
| 7.0  | Isolation and switching                                                                                                                                  |          |                    |
| 7.1  | Isolators                                                                                                                                                |          |                    |
|      | • presence and condition of appropriate devices                                                                                                          | ✓        |                    |
|      | • acceptable location                                                                                                                                    | ✓        |                    |
|      | • capable of being secured in the OFF position                                                                                                           | ✓        |                    |
|      | • correct operation verified                                                                                                                             | ✓        |                    |
|      | • clearly identified by position and/or durable marking(s)                                                                                               | ✓        |                    |
|      | • Warning label posted in situations where live parts cannot be isolated by the operation of a single device                                             | NA       |                    |
| 7.2  | Switching off for mechanical maintenance                                                                                                                 |          |                    |
|      | • presence and condition of appropriate devices                                                                                                          | ✓        |                    |
|      | • acceptable location                                                                                                                                    | ✓        |                    |
|      | • capable of being secured in the OFF position                                                                                                           | ✓        |                    |
|      | • correct operation verified                                                                                                                             | ✓        |                    |
|      | • clearly identified by position and/or durable marking(s)                                                                                               | ✓        |                    |
| 7.3  | Emergency switching/stopping                                                                                                                             |          |                    |
|      | • presence and condition of appropriate devices                                                                                                          | NA       |                    |
|      | • readily accessible for operation where danger might occur                                                                                              | NA       |                    |
|      | • correct operation verified                                                                                                                             | NA       |                    |
|      | • clearly identified by position and/or durable marking(s)                                                                                               | NA       |                    |
| 7.4  | Functional switching                                                                                                                                     |          |                    |
|      | • presence and condition of appropriate devices                                                                                                          | ✓        |                    |
|      | • correct operation verified                                                                                                                             | ✓        |                    |
| 8.0  | Current-using equipment (permanently connected)                                                                                                          |          |                    |
| 8.1  | Condition of equipment in terms of IP rating                                                                                                             | ✓        |                    |
| 8.2  | Equipment does not constitute a fire hazard                                                                                                              | ✓        |                    |
| 8.3  | Enclosure not damaged/deteriorated so as to impair safety                                                                                                | ✓        |                    |
| 8.4  | Suitability for the environment and external influences                                                                                                  | ✓        |                    |
| 8.5  | Security of fixing                                                                                                                                       | ✓        |                    |
| 8.6  | Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire (Indicate extent of sampling in Section D of report) | ✓        |                    |
| 8.7  | Recessed luminaires (e.g. downlighters)                                                                                                                  |          |                    |
|      | • correct type of lamps fitted                                                                                                                           | NA       |                    |
|      | • installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar                                         | NA       |                    |
|      | • no signs of overheating to surrounding building fabric                                                                                                 | NA       |                    |
|      | • no signs of overheating to conductors/terminations                                                                                                     | NA       |                    |
| 9.0  | Location(s) containing a bath or shower                                                                                                                  |          |                    |
| 9.1  | Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA                                                                       | NA       |                    |
| 9.2  | Where used as a protective measure, requirements for SELV or PELV are met                                                                                | NA       |                    |
| 9.3  | Shaver sockets comply with BS EN 61558-2-5 or BS 3635                                                                                                    | NA       |                    |
| 9.4  | Presence of supplementary bonding conductors unless not required by BS 7671: 2008                                                                        | NA       |                    |
| 9.5  | Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1                                                                               | NA       |                    |
| 9.6  | Suitability of equipment for external influences for installed location in terms of IP rating                                                            | NA       |                    |
| 9.7  | Suitability of equipment for installation in a particular zone                                                                                           | NA       |                    |
| 9.8  | Suitability of current-using equipment for a particular position within the location                                                                     | NA       |                    |
| 10.0 | Other special installations or locations                                                                                                                 |          |                    |
|      | List special locations present, if any. List the results of particular inspections applied.<br>- a separate page is required for each location           | NA       |                    |

\* All boxes must be completed.  
✓ indicates Acceptable condition  
LIM indicates a Limitation  
NA indicates Not applicable

Unacceptable condition state C1 or C2  
Improvement recommended state C3  
Further investigation required state F1  
(to determine whether danger or potential danger exists)

Outcome  
Provide additional comment where appropriate on attached numbered sheets. C1, C2 and C3 coded items to be recorded in section F of the report.



## SCHEDULE OF CIRCUIT DETAILS FOR THE PRIMARY DISTRIBUTION BOARD

| TO BE COMPLETED IN EVERY CASE   |                           | TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION |                                  |                  |                     |
|---------------------------------|---------------------------|------------------------------------------------------------------------------------------------------------|----------------------------------|------------------|---------------------|
| Location of distribution board: | Service Cupboard - Gents. | Supply to distribution board is from:                                                                      | No of phases:                    | Nominal voltage: | V                   |
| Distribution board designation: | DB1                       | Overcurrent protective device for the distribution circuit:                                                | Associated RCD (if any): BS (EN) |                  |                     |
|                                 |                           | Type: BS (EN)                                                                                              | Rating: A                        | RCD No of poles: | I <sub>Δn</sub> inA |

[illegible]

\* In such cases, details of the distribution (sub main) circuit(s), together with the test results for the circuit(s), must also be provided on continuation schedules.

↑ See Table 4A2 of Appendix 4 of BS 7671

| CODES FOR TYPE OF WIRING                |                                          |                                              |                                           |                                               |                           |                           |                          |                          |
|-----------------------------------------|------------------------------------------|----------------------------------------------|-------------------------------------------|-----------------------------------------------|---------------------------|---------------------------|--------------------------|--------------------------|
| A                                       | U                                        | C                                            | D                                         | E                                             | F                         | G                         | H                        | O (Other - please state) |
| Thermoplastic insulated/sheathed cables | Thermoplastic cables in metallic conduit | Thermoplastic cables in non-metallic conduit | Thermoplastic cables in metallic trunking | Thermoplastic cables in non-metallic trunking | Thermoplastic /SWA cables | Thermosetting /SWA cables | Mineral-insulated cables |                          |

Page 7 of 9

This report is based on the model forms shown in Appendix 6 of BS 7671

Published by NICEIC, a part of the Ascotiva Group © Copyright The Electrical Safety Council (July 2011)

1. 19/05/19

**See next page for  
Schedule of Test Results**

**Original** [To the person ordering the work]

See previous page for  
Schedule of Circuit Details

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with British Standard 7071 - Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX.

## A. DETAILS OF THE CLIENT

Client: *Corwall Council*

Address: *New County Hall,  
71-73*

Postcode:

## B. PURPOSE OF THE REPORT

This report must be used only for reporting on the condition of an existing installation.

Purpose for which this report is required:

*Annual inspection & test due*

Date(s) on which inspection and testing were carried out:

*23.6.14*

## C. DETAILS OF THE INSTALLATION

Occupier: *Corwall Council*

Address: *New County Hall,  
Bullard Rd,  
Corwall*

Postcode: *PL27 6AL*

Estimated age of the electrical installation:

*20 years*

Description of premises: domestic, commercial, industrial, other (Please state)

*Commercial*

Evidence of alterations or additions

☒

If yes, estimated age

*1 years*

Date of previous inspection:

*29.4.13*

Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No:

*IPN3/0218296*

Records of installation available:

*No*

Records held by:

*NA*

## D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:

*Supply, consumer unit, circuits & accessories.*

Agreed limitations including the reasons, if any, on the inspection and testing:

*Unable to find main water supply entry point.*

Agreed with:

Operational limitations including the reasons (see page No. 1)

*No 2.0 tests (1.0 & 2.0 tests were carried out)*

The inspection and testing have been carried out in accordance with BS 7071, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected.

## E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

*Good*

Summary of the condition of the installation continued on additional pages? No / Yes Specify page

Overall assessment of the installation:

**SATISFACTORY / UNSATISFACTORY** (Delete as appropriate)

An 'Unsatisfactory' assessment indicates that dangerous and/or potentially dangerous conditions have been identified

This report should have been reviewed and confirmed by the registered Qualified Supervisor of the Approved Contractor responsible for issuing it. (See declaration on page 2)

This report is based on the model forms shown in Appendix B of BS 7071

Published by NICEIC, a part of the Asotivo Group © Copyright The Electrical Safety Council (July 2011)

IPN32

Page 1 of

8

Please see the 'Notes for Recipients' on the reverse of this page.

Duplicate (to be retained by the contractor)



# ELECTRICAL INSTALLATION CONDITION REPORT

## H. SCHEDULES AND ADDITIONAL PAGES

Inspection Schedule: Page(s) No 4, 6, 8

Additional pages, including additional source(s) data sheets:

Page No(s)

Schedule of Circuit Details for the installation: Page No(s) 7

Schedule of Test Results for the installation: Page No(s) 8

The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

## I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

12 months

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or require further investigation are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

## J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading title:

Comms Solutions Ltd.

Address:

Castle Crag,  
Bedford.

Telephone number:

Email address:



Enrolment number:  
(Essential information)

601497

Postcode: PK31 1DZ

Branch number:  
(if applicable)

Characteristics of primary supply  
overcurrent protective device(s)

| System type(s) | Number and type of live conductors |                  | Nature of supply parameters                                |                                                                                            | BS(EN)                                |
|----------------|------------------------------------|------------------|------------------------------------------------------------|--------------------------------------------------------------------------------------------|---------------------------------------|
| TNS            | n.c. ✓                             | d.c.             | Nominal voltage: 230 V                                     | U <sub>n</sub> 234 V                                                                       | 88                                    |
| TN-C-S         | 1-phase (3-wire) ✓                 | 1-phase (3-wire) | Nominal frequency: 50 Hz                                   | Notes:<br>(1) by enquiry<br>(2) by enquiry or by measurement                               | Type RHL                              |
| TN-C           | 2-phase (3-wire)                   | 3-phase          | Prospective fault current, I <sub>pf</sub> 6.0067 kA       | (3) where more than one supply, record the highest or highest values<br>(4) by measurement | Rated current 60 A                    |
| TT ✓           | 3-phase (3-wire)                   | 3-phase (4-wire) | External earth fault loop impedance, Z <sub>e</sub> 34.1 Ω |                                                                                            | Short-circuit capacity kA             |
| IT             | Other                              | Please state:    | Number of sources 1                                        |                                                                                            | Confirmation of supply polarity ✓ (✓) |

## L. PARTICULARS OF INSTALLATION AT THE ORIGIN

| Means of earthing                                                                  |                                                  | Details of installation earth electrode (where applicable) |                                      |
|------------------------------------------------------------------------------------|--------------------------------------------------|------------------------------------------------------------|--------------------------------------|
| Distributor's facility:                                                            | Type: Red                                        | Location: Outside Grates.                                  |                                      |
| Installation earth electrode:                                                      | Electrode resistance, R <sub>e</sub> 34.1        | (Ω) Method of measurement: Loop tester                     |                                      |
| Main switch or circuit-breaker                                                     |                                                  | Earthing and protective bonding conductors                 |                                      |
| Type: BS(EN) 61004                                                                 | Voltage rating 230 V                             | Earthing conductor                                         | Main protective bonding conductors   |
| No. of poles 2                                                                     | Rated current, I <sub>n</sub> 80 A               | Conductor material Copper                                  | Conductor material Copper            |
| Primary supply conductors: metalclad                                               | RCD operating current, I <sub>Δn</sub> 100 mA    | Conductor csa 16 mm <sup>2</sup>                           | Conductor csa 10 mm <sup>2</sup>     |
| Primary supply conductors: csa 2.5 mm <sup>2</sup>                                 | Rated time delay NA ms                           | Connection/continuity verified ✓ (✓)                       | Connection/continuity verified ✓ (✓) |
|                                                                                    | RCD operating time (at I <sub>Δn</sub> ) FAIL ms |                                                            |                                      |
| * (Applicable only where an RCD is suitable and is used as a main circuit-breaker) |                                                  | Bonding of extraneous-conductive parts (✓)                 |                                      |
|                                                                                    |                                                  | Water service ✓                                            | Gas service                          |
|                                                                                    |                                                  | Oil service                                                | Structural steel                     |
|                                                                                    |                                                  | Lightning protection                                       | Other incoming services              |
|                                                                                    |                                                  | Specify                                                    |                                      |

# ELECTRICAL INSTALLATION CONDITION REPORT

## INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

| Item | Description                                                                                                                            | Outcome* | Location reference |
|------|----------------------------------------------------------------------------------------------------------------------------------------|----------|--------------------|
| 1.0  | Condition/adequacy of distributor's/supply intake equipment                                                                            |          |                    |
| 1.1  | Service cable                                                                                                                          | ✓        |                    |
| 1.2  | Service cut-out/fuse(s)                                                                                                                | ✓        |                    |
| 1.3  | Meter tails - distributor                                                                                                              | ✓        |                    |
| 1.4  | Meter tails - consumer                                                                                                                 | ✓        |                    |
| 1.5  | Metering equipment                                                                                                                     | ✓        |                    |
| 1.6  | Means of main isolation (where present)                                                                                                | ✓        |                    |
| 2.0  | Presence of adequate arrangements for parallel or switched alternative sources                                                         | NA       |                    |
| 3.0  | Automatic disconnection of supply                                                                                                      |          |                    |
| 3.1  | Main earthing and bonding arrangements                                                                                                 |          |                    |
|      | • Presence and condition of distributor's earthing arrangement                                                                         | NA       |                    |
|      | • Presence and condition of earth electrode arrangement                                                                                | ✓        |                    |
|      | • Adequacy of earthing conductor size                                                                                                  | ✓        |                    |
|      | • Adequacy of earthing conductor connections                                                                                           | ✓        |                    |
|      | • Accessibility of earthing conductor connections                                                                                      | ✓        |                    |
|      | • Adequacy of main protective bonding conductor size(s)                                                                                | ✓        |                    |
|      | • Adequacy of main protective bonding conductor connections                                                                            | 1101     |                    |
|      | • Accessibility of main protective bonding connections                                                                                 | 1101     |                    |
|      | • Provision of earthing/bonding labels at all appropriate locations                                                                    | ✓        |                    |
| 3.2  | FELV                                                                                                                                   |          |                    |
|      | • Source providing at least simple separation                                                                                          | ✓        |                    |
|      | • Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises                               | NA       |                    |
| 3.3  | Reduced low voltage                                                                                                                    |          |                    |
|      | • Adequacy of source                                                                                                                   | ✓        |                    |
|      | • Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises                               | NA       |                    |
| 4.0  | Other methods of protection (where the methods of protection listed below are employed, details should be provided on separate sheets) |          |                    |
| 4.1  | Double insulation                                                                                                                      | NA       |                    |
| 4.2  | Reinforced insulation                                                                                                                  | NA       |                    |
| 4.3  | Use of obstacles                                                                                                                       | ✓        |                    |
| 4.4  | Placing out of reach                                                                                                                   | NA       |                    |
| 4.5  | Non-conducting location                                                                                                                | NA       |                    |
| 4.6  | Earth-free local equipotential bonding                                                                                                 | NA       |                    |
| 4.7  | Electrical separation for more than one item of equipment                                                                              | NA       |                    |
| 5.0  | Distribution equipment                                                                                                                 |          |                    |
| 5.1  | Adequacy of working space/accessibility of equipment                                                                                   | ✓        |                    |
| 5.2  | Security of fixing                                                                                                                     | ✓        |                    |
| 5.3  | Condition of insulation of live parts                                                                                                  | ✓        |                    |
| 5.4  | Adequacy/security of barriers                                                                                                          | ✓        |                    |
| 5.5  | Condition of enclosure(s) in terms of IP rating                                                                                        | ✓        |                    |
| 5.6  | Condition of enclosure(s) in terms of fire rating                                                                                      | ✓        |                    |
| 5.7  | Enclosure not damaged/deteriorated so as to impair safety                                                                              | ✓        |                    |
| 5.8  | Presence of main switch(es), linked where required                                                                                     | ✓        |                    |
| 5.9  | Operation of main switch(es) (functional check)                                                                                        | ✓        |                    |
| 5.10 | Correct identification of circuit protective devices                                                                                   | ✓        |                    |
| 5.11 | Adequacy of protective devices for prospective fault current                                                                           | ✓        |                    |
| 5.12 | RCD(s) provided for fault protection - Includes RCBs                                                                                   | ✓        |                    |

\* All boxes must be completed.

✓ Indicates Acceptable condition

"LIM" indicates a Limitation

"NA" Indicates Not applicable

Unacceptable condition state C1 or C2

Improvement recommended state C3

Further investigation required state F/1  
(to determine whether danger or potential danger exists)

Outcome

Provide additional comment where appropriate on attached numbered sheets. C1, C2 and C3 coded items to be recorded in section F of the report.

# ELECTRICAL INSTALLATION CONDITION REPORT

## INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

| Item | Description                                                                                                                                                                                                                                                                                                                                                                                                          | Outcome* | Location reference |
|------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|--------------------|
| 5.13 | RCD(s) provided for additional protection - Includes RCBOs                                                                                                                                                                                                                                                                                                                                                           | ✓        |                    |
| 5.14 | RCD(s) provided for protection against fire - Includes RCBOs                                                                                                                                                                                                                                                                                                                                                         | ✓        |                    |
| 5.15 | Manual operation of circuit-breakers and RCDs to prove disconnection                                                                                                                                                                                                                                                                                                                                                 | ✓        |                    |
| 5.16 | Presence of RCD retest notice at or near equipment where required                                                                                                                                                                                                                                                                                                                                                    | ✓        |                    |
| 5.17 | Presence of diagrams, charts or schedules at or near equipment where required                                                                                                                                                                                                                                                                                                                                        | ✓        |                    |
| 5.18 | Presence of non-standard (mixed) cable colour warning notice at or near equipment where required                                                                                                                                                                                                                                                                                                                     | ✓        |                    |
| 5.19 | Presence of alternative supply arrangement warning notice(s) at or near equipment where required                                                                                                                                                                                                                                                                                                                     | NA       |                    |
| 5.20 | Presence of replacement next inspection recommendation label                                                                                                                                                                                                                                                                                                                                                         | ✓        |                    |
| 5.21 | Presence of other required labelling (specify)                                                                                                                                                                                                                                                                                                                                                                       | NA       |                    |
| 5.22 | Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)                                                                                                                                                                                                                                                                            | ✓        |                    |
| 5.23 | Protection against mechanical damage where cables enter equipment                                                                                                                                                                                                                                                                                                                                                    | ✓        |                    |
| 5.24 | Protection against electromagnetic effects where cables enter metallic enclosures                                                                                                                                                                                                                                                                                                                                    | ✓        |                    |
| 6.0  | Distribution/final circuits                                                                                                                                                                                                                                                                                                                                                                                          |          |                    |
| 6.1  | Identification of conductors                                                                                                                                                                                                                                                                                                                                                                                         | ✓        |                    |
| 6.2  | Cables correctly supported throughout their length                                                                                                                                                                                                                                                                                                                                                                   | ✓        |                    |
| 6.3  | Condition of insulation of live parts                                                                                                                                                                                                                                                                                                                                                                                | ✓        |                    |
| 6.4  | Non-sheathed cables protected by enclosure in conduit, duct or trunking                                                                                                                                                                                                                                                                                                                                              | NA       |                    |
| 6.5  | Suitability of containment systems for continued use (including flexible conduit)                                                                                                                                                                                                                                                                                                                                    | ✓        |                    |
| 6.6  | Cables correctly terminated in enclosures (indicate extent of sampling in Section D of report)                                                                                                                                                                                                                                                                                                                       |          |                    |
| 6.7  | Examination of cables for signs of unacceptable thermal and mechanical damage/deterioration                                                                                                                                                                                                                                                                                                                          | ✓        |                    |
| 6.8  | Adequacy of cables for current-carrying capacity with regard to the type and nature of installation                                                                                                                                                                                                                                                                                                                  | ✓        |                    |
| 6.9  | Adequacy of protective devices; type and rated current for fault protection                                                                                                                                                                                                                                                                                                                                          | ✓        |                    |
| 6.10 | Presence and adequacy of circuit protective conductors                                                                                                                                                                                                                                                                                                                                                               | ✓        |                    |
| 6.11 | Co-ordination between conductors and overload protective devices                                                                                                                                                                                                                                                                                                                                                     | ✓        |                    |
| 6.12 | Cable installation methods/practices appropriate to the type and nature of installation and external influences                                                                                                                                                                                                                                                                                                      | ✓        |                    |
| 6.13 | Cables where exposed to direct sunlight, of a suitable type                                                                                                                                                                                                                                                                                                                                                          | ✓        |                    |
| 6.14 | Concealed cables installed in prescribed zones (see extent and limitations)                                                                                                                                                                                                                                                                                                                                          | ✓        |                    |
| 6.15 | Concealed cables incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage caused by nails, screws and the like where not in prescribed zones or not protected by 30 mA RCD (see extent and limitations)                                                                                                                                         | NA       |                    |
| 6.16 | Provision of additional protection by 30 mA RCD for cables concealed in walls or partitions                                                                                                                                                                                                                                                                                                                          | ✓        |                    |
| 6.17 | Provision of additional protection by 30 mA RCD <ul style="list-style-type: none"> <li>Where reasonably likely to be used to supply mobile equipment for use outdoors</li> <li>For all socket-outlets of rating 20 A or less provided for use by ordinary persons</li> </ul>                                                                                                                                         | ✓        |                    |
| 6.18 | Provision of fire barriers, sealing arrangements and protection against thermal effects                                                                                                                                                                                                                                                                                                                              | ✓        |                    |
| 6.19 | Band II cables segregated/separated from Band I cables                                                                                                                                                                                                                                                                                                                                                               | NA       |                    |
| 6.20 | Cables segregated/separated from non-electrical services                                                                                                                                                                                                                                                                                                                                                             | ✓        |                    |
| 6.21 | Termination of cables at enclosures (identify numbers and locations of items inspected in Section D) <ul style="list-style-type: none"> <li>Connections under no undue strain</li> <li>No bare insulation of a conductor visible outside an enclosure</li> <li>Connections of live conductors adequately enclosed</li> <li>Adequacy of connection at point of entry to enclosure (gland, bush or similar)</li> </ul> | ✓        |                    |
| 6.22 | General condition of wiring systems                                                                                                                                                                                                                                                                                                                                                                                  | ✓        |                    |
| 6.23 | Temperature rating of cable insulation                                                                                                                                                                                                                                                                                                                                                                               | ✓        |                    |
| 6.24 | Condition of accessories including socket-outlets, switches and joint boxes                                                                                                                                                                                                                                                                                                                                          | ✓        |                    |
| 6.25 | Suitability of accessories for external influences                                                                                                                                                                                                                                                                                                                                                                   | ✓        |                    |

\* All boxes must be completed.

✓ indicates Acceptable condition  
LIM indicates a Limitation  
NA indicates Not applicable

Unacceptable condition state C1 or C2  
Improvement recommended state C3  
Further investigation required state F1  
(to determine whether danger or potential danger exists)

Outcome  
Provide additional comment where appropriate on attached numbered sheets C1, C2 and C3 coded items to be recorded in section F of the report.

Page 5 of

8

# ELECTRICAL INSTALLATION CONDITION REPORT

## INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

| Item | Description                                                                                                                                              | Outcome* | Location reference |
|------|----------------------------------------------------------------------------------------------------------------------------------------------------------|----------|--------------------|
| 7.0  | Isolation and switching                                                                                                                                  |          |                    |
| 7.1  | Isolators                                                                                                                                                |          |                    |
|      | • presence and condition of appropriate devices                                                                                                          | ✓        |                    |
|      | • acceptable location                                                                                                                                    | ✓        |                    |
|      | • capable of being secured in the OFF position                                                                                                           | ✓        |                    |
|      | • correct operation verified                                                                                                                             | ✓        |                    |
|      | • clearly identified by position and/or durable marking(s)                                                                                               | ✓        |                    |
|      | • Warning label posted in situations where live parts cannot be isolated by the operation of a single device                                             | N/A      |                    |
| 7.2  | Switching off for mechanical maintenance                                                                                                                 |          |                    |
|      | • presence and condition of appropriate devices                                                                                                          | ✓        |                    |
|      | • acceptable location                                                                                                                                    | ✓        |                    |
|      | • capable of being secured in the OFF position                                                                                                           | ✓        |                    |
|      | • correct operation verified                                                                                                                             | ✓        |                    |
|      | • clearly identified by position and/or durable marking(s)                                                                                               | ✓        |                    |
| 7.3  | Emergency switching/stopping                                                                                                                             |          |                    |
|      | • presence and condition of appropriate devices                                                                                                          | N/A      |                    |
|      | • readily accessible for operation where danger might occur                                                                                              | N/A      |                    |
|      | • correct operation verified                                                                                                                             | N/A      |                    |
|      | • clearly identified by position and/or durable marking(s)                                                                                               | N/A      |                    |
| 7.4  | Functional switching                                                                                                                                     |          |                    |
|      | • presence and condition of appropriate devices                                                                                                          | ✓        |                    |
|      | • correct operation verified                                                                                                                             | ✓        |                    |
| 8.0  | Current-using equipment (permanently connected)                                                                                                          |          |                    |
| 8.1  | Condition of equipment in terms of IP rating                                                                                                             | ✓        |                    |
| 8.2  | Equipment does not constitute a fire hazard                                                                                                              | ✓        |                    |
| 8.3  | Enclosure not damaged/deteriorated so as to impair safety                                                                                                | ✓        |                    |
| 8.4  | Suitability for the environment and external influences                                                                                                  | ✓        |                    |
| 8.5  | Security of fixing                                                                                                                                       | ✓        |                    |
| 8.6  | Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire (indicate extent of sampling in Section D of report) | ✓        |                    |
| 8.7  | Recessed luminaires (e.g. downlighters)                                                                                                                  |          |                    |
|      | • correct type of lamps fitted                                                                                                                           | N/A      |                    |
|      | • installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar                                         | N/A      |                    |
|      | • no signs of overheating to surrounding building fabric                                                                                                 | N/A      |                    |
|      | • no signs of overheating to conductors/terminations                                                                                                     | N/A      |                    |
| 9.0  | Location(s) containing a bath or shower                                                                                                                  |          |                    |
| 9.1  | Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA                                                                       | N/A      |                    |
| 9.2  | Where used as a protective measure, requirements for SELV or PELV are met                                                                                | N/A      |                    |
| 9.3  | Shaver sockets comply with BS EN 61558-2-5 or BS 3535                                                                                                    | N/A      |                    |
| 9.4  | Presence of supplementary bonding conductors unless not required by BS 7671: 2008                                                                        | N/A      |                    |
| 9.5  | Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1                                                                               | N/A      |                    |
| 9.6  | Suitability of equipment for external influences for installed location in terms of IP rating                                                            | N/A      |                    |
| 9.7  | Suitability of equipment for installation in a particular zone                                                                                           | N/A      |                    |
| 9.8  | Suitability of current-using equipment for a particular position within the location                                                                     | N/A      |                    |
| 10.0 | Other special installations or locations                                                                                                                 |          |                    |
|      | List special locations present, if any. List the results of particular inspections applied.                                                              |          |                    |
|      | -- a separate page is required for each location                                                                                                         | N/A      |                    |

\* All boxes must be completed.

✓ indicates Acceptable condition

L/M indicates a Limitation

N/A indicates Not applicable

Unacceptable condition state C1 or C2

Improvement recommended state C3

Further investigation required state F1 (to determine whether danger or potential danger exists)

Outcome

Provide additional comment where appropriate on attached numbered sheets. C1, C2 and C3 coded items to be recorded in section F of the report.





**Duplicate (To be retained by the contractor)**

# Log Book – Outlet Temperatures (Sentinels & Representatives)

(PW)

Month..May..2015.....

To comply with the specified control measures, water from the hot water outlets should reach at least 50°C within 1 minute of running (55°C in healthcare premises) and water from the cold water outlets should be below 20°C after running the water for up to 2 minutes. Sentinel outlets are the nearest and furthest outlets on a system or the first and last outlets on a recirculated system and must be monitored on a monthly basis. A representative amount on non sentinel outlets must be monitored annually on a rotational basis. Failures must be reported to the Responsible Person for further action in accordance with the written scheme.

| UPRN    | Site Name:                      | Outlet Reference & Location: | Outlet Fed From: | Outlet Type (S/R) | Temp in °C | Name:    | Date:   |
|---------|---------------------------------|------------------------------|------------------|-------------------|------------|----------|---------|
| 14475 ✓ | BUDE – CROOKLETS BEACH CAR PARK | DISABLED WALLGATE            | MAINS            |                   | 15.6       | M WEBBER | 25/5/15 |
|         | LADIES WALLGATE (1)             | LADIES WALLGATE (2)          | MAINS            |                   | 15.4       | M WEBBER | 25/5/15 |
|         | GENTS WALLGATE (1)              | GENTS WALLGATE (2)           | MAINS            |                   | 15.6       | M WEBBER | 25/5/15 |
| 14476 ✓ | BUDE – SUMMERLEAZE BEACH        | LADIES WALLGATE              | MAINS            |                   | 15.3       | M WEBBER | 25/5/15 |
|         | GENTS WALLGATE                  | GENTS WALLGATE               | MAINS            |                   | 15.1       | M WEBBER | 25/5/15 |
|         | DISABLED SINK (1)               | DISABLED SINK (2)            | MAINS            |                   | 15.3       | M WEBBER | 25/5/15 |
|         | BUDE – POST OFFICE              |                              |                  |                   |            |          |         |
|         |                                 |                              |                  |                   |            |          |         |
| 14479 ✓ | BUDE – THE CRESCENT             | LADIES WALLGATE              | MAINS            |                   | 15.2       | M WEBBER | 25/5/15 |
|         |                                 | GENTS WALLGATE               | MAINS            |                   | 15.1       | M WEBBER | 25/5/15 |
|         |                                 | DISABLED WALLGATE            | MAINS            |                   | 15.3       | M WEBBER | 25/5/15 |
| 14484 ✓ | WIDEMOUTH BAY                   | GENTS WALLGATE               | MAINS            |                   | 14.7       | M WEBBER | 25/5/15 |
|         | LADIES WALLGATE (1)             | LADIES WALLGATE (2)          | MAINS            |                   | 14.6       | M WEBBER | 25/5/15 |
|         | BABY CHANGE SINK                | DISABLED SINK                | MAINS            |                   | 14.9       | M WEBBER | 25/5/15 |

Outlet Fed From = Source of water i.e.: Water Heater No, Cold Water Storage Tank No, Mains Cold, etc

Outlet Type: S = Sentinel; R = Representative

# Log Book – Outlet Temperatures (Sentinels & Representatives) (PW) Month: MAY 2015

To comply with the specified control measures, water from the hot water outlets should reach at least 50°C within 1 minute of running (55°C in healthcare premises) and water from the cold water outlets should be below 20°C after running the water for up to 2 minutes. Sentinel outlets are the nearest and furthest outlets on a system or the first and last outlets on a recirculated system and must be monitored on a monthly basis. A representative amount on non sentinel outlets must be monitored annually on a rotational basis. Failures must be reported to the Responsible Person for further action in accordance with the written scheme.

| UPRN | Site Name:                   | Outlet Reference & Location: | Outlet Fed From: | Outlet Type (S/R) | Temp in °C | Name:    | Date:   |
|------|------------------------------|------------------------------|------------------|-------------------|------------|----------|---------|
| X    | BOSCASTLE - GATEWAY          |                              |                  |                   |            |          |         |
| X    | BOSCASTLE - TIC              |                              |                  |                   |            |          |         |
|      |                              |                              |                  |                   |            |          |         |
|      |                              |                              |                  |                   |            |          |         |
|      |                              |                              |                  |                   |            |          |         |
|      | CAMELFORD – ENFIELD PARK     | LADIES WALLGATE              | MAINS            |                   | 13.8       | M WEBBER | 11/5/15 |
|      |                              | GENTS WALLGATE               | MAINS            |                   | 13.7       | M WEBBER | 11/5/15 |
|      |                              | DISABLED SINK                | MAINS            |                   | 13.5       | M WEBBER | 11/5/15 |
|      | TINTAGEL – TREVENNA (FRYS)   | LADIES WALLGATE              | MAINS            |                   | 14.4       | M WEBBER | 11/5/15 |
|      |                              | GENTS WALLGATE               | MAINS            |                   | 14.4       | M WEBBER | 11/5/15 |
|      |                              | GENTS DISABLED SINK          | MAINS            |                   | 14.6       | M WEBBER | 11/5/15 |
|      | LADIES DISABLED SINK 14.5    | LADIES WALLGATE              | MAINS            |                   | 15.3       | M WEBBER | 11/5/15 |
|      | TINTAGEL – TREBARWITH STRAND | GENTS WALLGATE               | MAINS            |                   | 15.4       | M WEBBER | 11/5/15 |
|      |                              | DISABLED SINK                | MAINS            |                   | 15.2       | M WEBBER | 11/5/15 |

Outlet Fed From = Source of water i.e.: Water Heater No, Cold Water Storage Tank No, Mains Cold, etc

Outlet Type: S = Sentinel; R = Representative

# Log Book – Outlet Temperatures (Sentinels & Representatives)

(PW)

Month..1799..2015.....

To comply with the specified control measures, water from the hot water outlets should reach at least 50°C within 1 minute of running (55°C in healthcare premises) and water from the cold water outlets should be below 20°C after running the water for up to 2 minutes. Sentinel outlets are the nearest and furthest outlets on a system or the first and last outlets on a recirculated system and must be monitored on a monthly basis. A representative amount on non sentinel outlets must be monitored annually on a rotational basis. Failures must be reported to the Responsible Person for further action in accordance with the written scheme.

| UPRN | Site Name:                                  | Outlet Reference & Location: | Outlet Fed From: | Outlet Type (S/R) | Temp in °C | Name:    | Date:   |
|------|---------------------------------------------|------------------------------|------------------|-------------------|------------|----------|---------|
| ✓    | PORT ISAAC – ROSCARRICK HILL (FISH CELLARS) |                              |                  |                   |            |          |         |
|      |                                             |                              |                  |                   |            |          |         |
|      |                                             |                              |                  |                   |            |          |         |
|      | WADEBRIDGE – THE PLATT                      | LADIES WALLGATE              | MAINS            |                   | 12.3       | M WEBBER | 29/5/15 |
|      |                                             | GENTS WALLGATE               | MAINS            |                   | 12.1       | M WEBBER | 29/5/15 |
|      |                                             | DISABLED SINK                | MAINS            |                   | 12.4       | M WEBBER | 29/5/15 |
|      | WADEBRIDGE – EGLASHAYLE ROAD                | LADIES WALLGATE              | MAINS            |                   | 11.6       | M WEBBER | 29/5/15 |
|      |                                             | GENTS WALLGATE               | MAINS            |                   | 11.4       | M WEBBER | 29/5/15 |
|      |                                             | DISABLED SINK                | MAINS            |                   | 11.3       | M WEBBER | 29/5/15 |
|      | LANIVET – TRURO ROAD                        | LADIES WALLGATE              | MAINS            |                   | 13.3       | M WEBBER | 29/5/15 |
|      |                                             | GENTS WALLGATE               | MAINS            |                   | 13.5       | M WEBBER | 29/5/15 |
|      |                                             | DISABLED SINK                | MAINS            |                   | 13.2       | M WEBBER | 29/5/15 |
|      | NEW POLZEATH                                | LADIES WALLGATE              | MAINS            |                   | 13.4       | M WEBBER | 29/5/15 |
|      |                                             | GENTS WALLGATE               | MAINS            |                   | 13.5       | M WEBBER | 29/5/15 |
|      |                                             | DISABLED SINK                | MAINS            |                   | 13.3       | M WEBBER | 29/5/15 |

# Log Book – Outlet Temperatures (Sentinels & Representatives) (PW) Month..MAY..2015.....

To comply with the specified control measures, water from the hot water outlets should reach at least 50°C within 1 minute of running (55°C in healthcare premises) and water from the cold water outlets should be below 20°C after running the water for up to 2 minutes. Sentinel outlets are the nearest and furthest outlets on a system or the first and last outlets on a recirculated system and must be monitored on a monthly basis. A representative amount on non sentinel outlets must be monitored annually on a rotational basis. Failures must be reported to the Responsible Person for further action in accordance with the written scheme.

| UPRN  | Site Name:                    | Outlet Reference & Location: | Outlet Fed From: | Outlet Type (S/R) | Temp in °C | Name:    | Date:   |
|-------|-------------------------------|------------------------------|------------------|-------------------|------------|----------|---------|
| 15947 | POLZEATH – CORONATION GARDENS | LADIES WALLGATE              | MAINS            |                   | 13.7       | M WEBBER | 29/5/15 |
|       |                               | GENTS WALLGATE               | MAINS            |                   | 13.4       | M WEBBER | 29/5/15 |
|       |                               | DISABLED SINK                | MAINS            |                   | 13.5       | M WEBBER | 29/5/15 |
|       |                               | LADIES WALLGATE              | MAINS            |                   | 12.7       | M WEBBER | 29/5/15 |
|       | DAYMER BAY                    | GENTS WALLGATE               | MAINS            |                   | 12.9       | M WEBBER | 29/5/15 |
|       |                               | DISABLED SINK                | MAINS            |                   | 13.0       | M WEBBER | 29/5/15 |
|       |                               | DISABLED SINK (1)            | MAINS            |                   | 16.0       | M WEBBER | 29/5/15 |
|       |                               | DISABLED SINK (2)            | MAINS            |                   | 15.9       | M WEBBER | 29/5/15 |
|       | WADEBRIDGE – CAMEL TRAIL      | LADIES SINK (1)              | MAINS            |                   | 14.9       | M WEBBER | 29/5/15 |
|       |                               | LADIES SINK (4)              | MAINS            |                   | 15.1       | M WEBBER | 29/5/15 |
|       |                               | GENTS SINK (1)               | MAINS            |                   | 15.1       | M WEBBER | 29/5/15 |
|       |                               | GENTS SINK (4)               | MAINS            |                   | 15.3       | M WEBBER | 29/5/15 |
|       |                               |                              |                  |                   |            |          |         |
|       |                               |                              |                  |                   |            |          |         |
|       |                               |                              |                  |                   |            |          |         |

Outlet Fed From = Source of water i.e.: Water Heater No, Cold Water Storage Tank No, Mains Cold, etc

Outlet Type: S = Sentinel; R = Representative

Month.....MAY 2015.....

TEMP

[illegible]

Outlet Type: S = Sentinel; R = Representative

