



SECTION A: DETAILS OF THE CLIENT			
Name The Harlington (Fleet Council)	Address		
		Fleet Hampshire	
		GU51 4BY	
SECTION B: REASON FOR PRODUCING THIS REPORT			
Safety assessment requested by client			
Dates on which the inspection and testing was carried out 13 Ja	an 2019		
SECTION C: DETAILS OF THE INSTALLATION WHICH	IS THE S	SUBJECT OF THIS REPORT	
Occupier The Point	Addicas	236 Fleet Road	
		Fleet Hampshire	
		GU51 4BY	
Description of premises: Domestic Commercial Industrial	Other 🗸	Youth Centre (Fleet Council)	
Estimated age of the installation 35 years Evidence of ad	lditions/alte	rations If yes, estimated age 3 yes	ars
Installation records available? (Regulation 621.1) Date of last	inspection	-	
SECTION D: EXTENT AND LIMITATIONS OF INSPECT	ION AND	TESTING	
Extent of the installation covered by this report			
100% of the installation			
Agreed limitations including the reasons (see Regulation 634.2)			
1 Inspection Schedule Item 5.10: Concealed cables installed in p	orescribed z	ones (see Section D. Extent and limitations)	(522.6.202).
Inspection Schedule Item 5.11: Cables concealed under floors, (see Section D. Extent and limitations) (522.6.204;).	, above ceil	ings or in walls/partitions, adequately protec	ted against damage
Agreed with Client	45		
Operational limitations including the reasons			
DB12 - unable to ascertain where these circuits go Unable to shut off alarm - no dead testing on this circuit	(O)		
The inspection and testing detailed in this report and accompanying Wiring Regulations) as amended to 2015.	g schedules	have been carried out in accordance with B	5 7671: 2008 (IET
It should be noted that cables concealed within trunking and conduct under NOT been inspected unless specifically agreed between the client and it specthousing other electrical equipment.			
SECTION E: SUMMARY OF THE CONDITION OF THE I	INSTALL	ATION	
General condition of the electrical installation (in terms of electrica			
-			
Overall assessment of the installation in terms of its suitability for c	ontinued us	se UNSATISFACTORY	
An unsatisfactory assessment indicates that dangerous (code C1) a	nd/or poter	ntially dangerous (code C2) conditions have	peen identified.
SECTION F: RECOMMENDATIONS			
Where the overall assessment of the suitability of the installation fo any observations classified as "Danger present" (code C1) or "Poter Investigation without delay is recommended for observations identi Observations classified as "Improvement recommended" (code C3)	ntially dange fied as "Fur	erous" (code C2) are acted upon as a matte ther investigation required" (code FI).	
Subject to the necessary remedial action being taken, I/we recomm	nend that th	ne installation be further inspected and teste	d by 13 Jan 2024





SECTION G: DECLARATION

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations of inspection and testing in section D of this report.

electrical in	nstallatio	on taking into accou	unt the state	d exte	ent and limitat	ions	of inspectio	n and tes	ting in	sectio	n D of	this report.			
Inspectio	n and t	tested by:					Report au	thorised	for iss	sue by	':				
Name	Paul Ti	illett					Name	-							
Position	Owner			Date	13 Jan 2019		Position	-				Date	-		
Signature		1-0	Jujuttell				Signature								
Details of	f the co	ontractor													
Trading titl	le ATI	Electrical					Enrolment/	branch	EPP37	7736 /	1107				
Address	Flat	1 Park Road					Telephone		079 2	9 59 7	4 79				
		borough													
		ipshire 4 6LS													
SECTION	H: SC	CHEDULE													
The follow	e following items are part of this document and this report is valid only when they are to it: 11 observations.														
	11 observations.														
	85 i	tems in the schedu	le of inspect	ion.											
	2 9	schedule(s) of test	results for b	oards	with a total of	f 3	6 circuits.								
SECTION	N I: SU	IPPLY CHARAC	TERISTIC	S ANI	D EARTHIN	IG /	ARRANCE	IENTS							
Earth arrange		Number and	Type of Live	e Con	ductors		Nature of	Supply F	Param	eters		Supply Prot	tective De	evice	
TN-C		a.c.	•	d.c.		lom	inal voltage l	J/U0 23	30 /	230	٧	BS (EN)			
TN-S	~	1-phase, 2-wire		2-wire	e 🗌 🗼	om	inal frequenc	cy f *		50	Hz	Туре			
TN-C-S		2-phase, 3-wire		3-wire	e 🗌 📑	rosi	pective fault	current Ip	pf **	0	kA	Rated current		A	
TT		3-phase, 3-wire		Other		xte	rnal loop imp	edance Z	'e **	0	Ω	Short-circuit capacity	0	KA	
IT		3-phase, 4-wire			**		enquiry enquiry or meas	urement				Сараску			
		Confirmation of s	supply polari	ty											
Other sou	irces of	f supply													
١,															





SECTION J: PA	ART	ICUI	ARS O	F INS	ΓALL	ATIC	N RE	FERRED	ТО	IN THE F	REP	ORT					
Means of Earthi	ng		Details	of Ins	tallat	ion E	arth El	ectrode (whe	ere applica	able))					
Distributor's facilit	ty	~ .	Туре														
Installation earth electrode		<u> </u>	Locatio	n													
electione			Resista	nce to	earth	(2 C	Σ									
Main Protective	Cor	duct	ors														
Earth Conductor				Materia	al			csa				m	nm ² (Connec	ction / continuity verified	1	
Main protective handing conductors															ction / continuity verified	j	
To water installati	on p	ipes		To gas	insta	llation	pipes		То	oil installat	tion p	oipes			To structural steel		
To lightning prote	ction			To oth	er		Specif	у									
PASS: the item has	passe	d. FAI	TL: the iter	m has fai	led. L1	M: ther	re are lin	mitations tha	at app	ply to the iter	n. N-	C: the i	item is	s not co	ntinuous. N/A: the item is i	ot ava	ilable.
Main Switch / S	arth Conductor Material CSa mm² Connection / continuity verified mm² Connection / continuity verified mm² Connection / continuity verified CSa mm² Connection / continuity verified To owner installation pipes To gas installation pipes To oil installation pipes To structural steel Dightning protection To other Specify ASS: the item has passed. FAIL: the item has failed. LIM: there are limitations that apply to the item. N-C: the item is not continuous. N/A: the item is not available. If RCD main switch S(EN) 60947-3 Poles 2 Current rating 100 A Rated residual operating current (IΔn) 0 mA																
Aain Protective Conductor Farth Conductor Material Connection / continuity verified Material Connection / continuity verified Material Connection / continuity verified Connection / continuity verified To water installation pipes To gas installation pipes To oil installation pipes To structural steel To olightning protection To other Specify PASS: the item has passed. FAIL: the item has failed. LIM: there are limitations that apply to the item. N-C: the item is not continuous. N/A: the item is not available. Main Switch / Switch-Fuse / Circuit Breaker / RCD Cocation If RCD main switch SS(EN) 60947-3 Poles 2 Current rating 100 A Rated residual operating current (I\Dan) 0 mA																	
BS(EN)	609	47-3		Poles	2	Curre	nt ratin	ıg		100	Α	Rate	d res	idual o	perating current (IΔn)	0	mA
Supply conductors	s ma	terial	C	opper		Fuse/	'device	rating or s	ettin	ng	Α	Rate	d tim	e dela	/	0	mS
Supply conductors	s CSA	4		25		Volta	ge ratir	ıg		400	٧	Meas	sured	opera	ting time (IΔn)	0	mS
							Š	21	くつ								





SEC	CTION K: OBSERVATIONS		
	erring to the attached schedules of inspection and test results, and subject to the limitations specified at the Extent and L ection and Testing section	imitiations of	
No r	remedial action is required The following observations are made 🔽 (see below):		
#		Location	Code
1	Inspection Schedule Item 4.9: Correct identification of circuit details and protective devices (514.8.1; 514.9.1). Further investigation is required. Circuit Indentification out of date or poor in some instances. No phase idnetification stickers	DB12, DB9	FI
2	Inspection Schedule Item 4.18: RCD(s) provided for fault protection - includes RCBOs (411.4,9; 411.5.2: 531.2). is in a potentially dangerous condition. Urgent remedial action is required. No RCD protection provided. Poor protection against electrical shock. Does not conform to current regulations.	General	C2
3	Inspection Schedule Item 4.19: RCD(s) provided for additional protection - includes RCBOs (411.3.3: 415.1). is in a potentially dangerous condition. Urgent remedial action is required. No RCD protection provided. Poor protection against electrical shock. Does not conform to current regulations.	General	C2
4	Inspection Schedule Item 5.1: Identification of conductors (514.3.1). is recommended for improvement. Switched lines in lighting accessories not identified	General	C3
5	Inspection Schedule Item 5.12.1: for all socket-outlets of rating 20 A or less. unless an exception is permitted (411.3.3). is in a potentially dangerous condition. Urgent remedial action is required. No RCD protection provided. Poor protection against electrical shock. Does not conform to current regulations.	General	C2
6	Inspection Schedule Item 5.12.3: for cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203). is in a potentially dangerous condition. Urgent remedial action is required. No RCD protection provided. Poor protection against electrical shock. Does not conform to current regulations.	General	C2
7	Inspection Schedule Item 5.12.4: for cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203). is in a potentially dangerous condition. Urgent remedial action is required. No RCD protection provided. Poor protection against electrical shock. Does not conform to current regulations.	General	C2
8	Power supply cable emerging from ceiling	General	FI
9	Overuse of extension leads throughout Insufficient sockets	General	C3
10	Socket slightly loose	Main Hall	C3
11	Inspection Schedule Item 4.5: Enclosure not damaged/deteriorated so as to impair safety (621.2(iii)). is recommended for improvement. Blanking plate missing	DB12	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1: Danger present. Risk of injury. Immediate remedial action required. C3: Improvement recommended.

C2: Potentially dangerous - urgent remedial action required. FI: Further investigation required without delay.





TNSDE	CTION SCHEDULE	
		Not
OUTCOM Item	PASS Acceptable condition C1 or C2 Unacceptable condition C3 Improvement recommended FI Further investigation NV verified LIM Limitation N/A Description and comment (if any)	applicable Outcome
1.0	DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT	_
1.1	Condition of service cable	N/A
1.2	Condition of service head	N/A
1.3	Condition of distributor's earthing arrangement	N/A
1.4	Condition of meter tails - Distributor/Consumer	PASS
1.5	Condition of metering equipment	N/A
1.6	Condition of isolator (where present)	N/A
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)	_
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A
2.1	Adequate arrangements where a generating set operates as a switched atternative to the public supply (551.7) Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	<u> </u>
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chapter 54)	N/A
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	N/A
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)	N/A
	Provision of earthing/bonding labels at all appropriate locations (514.13.1)	
3.3		N/A
3.4	Confirmation of earthing conductor size (542.3: 543.1.1)	PASS
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)	N/A
3.6	Confirmation of main protective bonding conductor sizes (544.1)	N/A
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2: 544.1.2)	N/A
3.8	Accessibility and condition of other protective bonding connections (543.3.2)	N/A
4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD S)	-
4.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12: 513.1)	PASS
4.2	Security of fixing (134.1.1)	PASS
4.3	Condition of enclosure(s) in terms of IP rating etc. (416.2)	PASS
4.4	Condition of enclosure(s) in terms of fire rating etc. (421.1.201; 526.5)	PASS
4.5	Enclosure not damaged/deteriorated so as to impair safety (621.2(iii))	C3
4.6	Presence of main linked switch (as required by 537.1.4)	PASS
4.7	Operation of main switch (functional check)(612.13.2)	PASS
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (612.13.2)	N/A
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	FI
4.10	Presence of RCD quarterly test notice at or near consumer unit/distribution board (514.12.2)	N/A
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit/distribution board (514.14)	N/A
4.12	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)	N/A
4.13	Presence of other required labelling (please specify) (Section 514)	PASS
4.14	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (421.1.3)	PASS
4.15	Single-pole switching or protective devices in line conductor only (132.14.1: 530.3.2)	PASS
4.16	Protection against mechanical damage where cables enter consumer unit/distribution board (522.8.1; 522.8.11)	PASS
4.17	Protection against electromagnetic effects where cables enter consumer unit/distribution board/enclosures (521.5.1)	PASS





OUTCOL	ES PASS Acceptable C1 or C2 Unacceptable C3 Improvement recommended FI Further investigation NV verified LIM Limitation N/A	Not
OUTCOM	ES PASS Acceptable condition C1 or C2 Unacceptable condition C3 Improvement recommended FI Further investigation NV Verified LIM Limitation N/A	applicable
Item	Description and comment (if any)	Outcome
4.18	RCD(s) provided for fault protection - includes RCBOs (411.4,9; 411.5.2: 531.2)	C2
4.19	RCD(s) provided for additional protection - includes RCBOs (411.3.3: 415.1)	C2
4.20	Confirmation of indication that SPD is functional (534.2.8)	N/A
4.21	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure (526.1)	N/V
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A
5.0	FINAL CIRCUITS	-
5.1	Identification of conductors (514.3.1)	C3
5.2	Cables correctly supported throughout their run (522.8.5)	PASS
5.3	Condition of insulation of live parts (416.1)	PASS
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	PASS
5.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	PASS
5.5	Adequacy of cables for current carrying capacity with regard for the type and nature of installation (Section 523)	PASS
5.6	Coordination between conductors and overload protective devices (433.1: 533.2.1)	PASS
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	PASS
5.8	Presence and adequacy of circuit protective conductors (411.3.1, 1, 543.1)	PASS
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	PASS
5.10	Concealed cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	LIM
5.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Section D. Extent and limitations) (522.6.204;)	LIM
5.12	Provision of additional protection by RCD not exceeding 30 mA:	-
5.12.1	for all socket-outlets of rating 20 A or less. unless ar exception is permitted (411.3.3)	C2
5.12.2	for supply to mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	N/A
5.12.3	for cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	C2
5.12.4	for cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)	C2
5.13	Provision of fire barriers. sealing arrangements and protection against thermal effects (Section 527)	PASS
5.14	Band II cables segregated / separated from Band I cables (528.1)	PASS
5.15	Cables segregated / separated from communications cabling (528.2)	PASS
5.16	Cables segregated / separated from non-electrical services (528.3)	PASS
5.17	Termination of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526)	PASS
5.17.1	Connections soundly made and under no undue strain (526.6)	PASS
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	PASS
5.17.3	Connections of live conductors adequately enclosed (526.5)	PASS
5.17.4	Adequately connected at point of entry to enclosure (glands. bushes etc.) (522.8.5)	PASS
5.18	Condition of accessories including socket-outlets, switches and joint boxes (621.2 (iii))	PASS
5.19	Suitability of accessories for external influences (512.2)	PASS
5.20	Adequacy of working space/accessibility to equipment (132.12; 513.1)	PASS
5.21	Single-pole switching or protective devices in line conductors only (132.14.1. 530.3.2)	PASS
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER	-





OUTCOI	TES PASS Acceptable condition C1 or C2 Unacceptable condition C3 Improvement recommended FI Further investigation NV verified LIM Limitation N/A a	Not applicable												
Item	Description and comment (if any)	Outcome												
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)	N/A												
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	N/A												
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	N/A												
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2008 (701.415.2)													
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3m from zone 1 (701.512.3)													
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	N/A												
6.7	Suitability of accessories and control gear etc. for a particular zone (701.512.3)	N/A												
6.8	Suitability of current-using equipment for particular position within the location (701.55)	N/A												
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS	-												
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied.)	N/A												
Inspect	ed by:	1												
Name	Paul Tillett Date 13 Jan 2019 Signature	'												







BOAR	D CHARACTERISTICS	Designation DB9 Supply Origin Location Phases 3 Phase sequence confirmed - Overcurrent protective device for distribution circuit BS-EN RCD BS-EN Poles Rating RCD BS-EN Poles Rating Ratin																				TEST	INSTR	UMENT	S	
	Designation					APPL	IES WH	EN NOT CONI	NECTED	TO INS	TALLA	TION C	RIGIN							Serial	or ass	et numb	ers of te	st instru	ments	used
	DB9				9	Supply (Origin									Supply	polarity	confirme	d YES		Cor	ntinuity		801289	Э	
	Location				F	Phases	3		Phas	e sequ	ence	confirr	ned	-		Charac	teristics	RCD op	erating	Insula	tion res	istance		223300	J	
							nrotecti	ive device fo	or dictri	hution	circui	i+					oard		nes	E	arth fau	ult loop		801289	a	
	Pear Storage Area						proceed	ive device is				Nom	inal			_		T			imp	edance		00120.	<u></u>	
	Real Storage Area							-	Kaung	-	A	volt	age 4	OU V		Zs	- Ω	In	- ms		Earth ele	RCD		-		
					RCD	BS-EN		-	Pole	s -		Rat	ing	- m	ıΑ	Ipf	- kA	5In	- ms			istance		-		
				CI	RCUIT	DETAI	LS							_					TEST	RESU	LTS					
Circuit number	Circuit designation	Wiring type	Reference method	Number of points	Live mm ²	CPC mm ²	Maximum disconnection time	BS (EN)	Туре	Rating (A)	Short circuit	Max Zs permitted by RS7671	RCD operating current (In)	Phase (r1)	Neutral (rn)	CPC (r2)	R1+R2	R2	Live Live MΩ	Live Earth MΩ	Polarity check	Earth fault Dop Impedance	RCD time At In ms	RCD time At 5In ms	Test button operation	Vulnerable to test
1L1	Lights - Hall and Main Office	Α	В	-	1.5	1.5	0.4	60898	В	6	3	5.82	-	-	-	-	-	-	-	-	PASS	-	-	-	-	-
1L2	Lights - Store and Toilets	-	-	-	1.5	1.5	0.4	60898	В	6	3	5.82	-	-	-	-	-	-	-	-	PASS	-	-	-	-	-
1L3	Lights - Office and Music Store Room	ı	-	-	1	1	0.4	60898	В		3	5.82	1	1	1	1	-	-	1	-	PASS	-	ı	ı	-	-
2L1	Sockets - Main Hall, Music Store Room, Office and Kitchenette	1	-	-	2.5	2.5	0.4	60898	В	3	3	1.10	-	1	-	-	-	-	1	-	PASS	0.47	1	-	-	-
2L2	Water Heater - Disabled	-	-	-	2.5	2.5	0.4	60898	В	16	3	2.18	-	-	-	-	-	-	-	-	PASS	-	-	-	-	-
2L3	Water Heater - Kitchenette	-	-	-	2.5	2.5	0.4	60898	В	16	3	2.18	-	-	-	-	-	-	-	-	PASS	-	-	-	-	-
3L1	Sub Main Supply - DB12	-	-	-	10	10	0.4	60898	В	50	3	0.70	-	-	-	-	-	-	-	-	PASS	-	-	-		-
3L2	Sub Main Supply - DB12	-	-	-	10	10	0.4	60898	В	50	3	0.70	-	-	-	-	-	-	-	-	PASS	-	-	-	-	-
3L3	Sub Main Supply - DB12	-	-	-	10	10	0.4	60898	В	50	3	0.70	-	-	-	-	-	-	-	-	PASS	-	-	-		-
4L1	Lights Main Hall (Incorrect)	-	-	-	1.5	1.5	0.4	60898	В	6	3	5.82	-	-	-	-	-	-	-	-	PASS	-	-	-	-	-
4L2	Cyber Ring Main	-	-	-	2.5	2.5	0.4	60898	В	32	3	1.10	-	-	-	-	-	-	-	-	PASS	0.40	-	-	-	-
4L3	Hand Dryer	-	-	-	2.5	2.5	0.4	60898	В	16	3	2.18	-	-	-	-	-	-	-	-	PASS	-	-	-	-	-
5L1	Intruder Alarm	-	-	-	2.5	2.5	0.4	60898	В	16	3	2.18	-	-	-	-	-	-	-	-	PASS	-	-	-		<u> </u>
5L2	Outside Lighting	-	-	-	1	1	0.4	60898	В	6	3	5.82	-	-	-	-	-	-	-	-	PASS	-	-	-	-	-
5L3	Water Heater - Cleaners Cupboard	-	-	-	2.5	2.5	0.4	60898	В	16	3	2.18	-	-	-	-	-	-	-	-	PASS	-	-	-	-	-





				CI	RCUIT	DETAI	LS												TEST	RESU	LTS					
Circuit number	Circuit designation	Wiring type	Reference	Number of points	Live mm ²	CPC mm ²	Maximum disconnection time	BS (EN)	Туре	Rating (A)	(ky) Short circuit	Max Zs permitted by BS7671	RCD operating current (In)	Phase (r1)	Neutral (rn)	CPC (r2)	R1+R2	R2	Live Live MΩ	Live Earth MΩ	Polarity check	Earth fault Dop Impedance	RCD time At In ms	RCD time At 5In ms	er b	Vulnerable to test
6L1	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6L2	No Identification	-	-	-	4	4	0.4	60898	В	32	3	1.10	-	-	-	ı	-	1	-	-	-	-	-	1	-	-
6L3	Hand Dryer - Gents	-	-	-	2.5	2.5	0.4	60898	В	16	3	2.18	-	-	-	•	-	•	-	-	PASS	-	-	-	-	-
Engine	er Paul Tillett				Date	13 .	Jan 20:	19 Signa	ature		-		7	2	Ant.	11	1	A F	PVC/PVC cables	;		S FOR TYPES C cables in meta		G XLPE/SV	/A cables	
Position	o Owner	-											-6	w		wie			PVC cables in m PVC cables in n			C cables in non- C/SWA cables	metallic trunk	ng H MICC mi	neral insulat	ed cables





BOAR	D CHARACTERISTICS																					TEST	INSTR	UMENT	rs	
	Designation					APPI	IES WH	EN NOT CON	NECTED	TO INS	TALL	ATION C	RIGIN							Serial	or ass	et numb	ers of te	est instru	ments	used
	DB12					Supply	Origin									Supply	polarity	confirme	d -		Cor	ntinuity		-		
	Location					Phases	3		Phas	e sequ	ence	confirr	ned	-		Charac	teristics	RCD op	erating	Insula	tion res	istance		_		
					Ove	rcurrent	nrotect	ive device fo	or distri	hution	circu	it				at b	oard		nes	E	arth fa			_		
	Rear Storage Area				0.0	BS-EN	procee	ive device it				Nom	inal	.,		7-		Tue			imp	edance RCD				
	Near Storage Area							-	Rating	y -		volt		- V		23	- Ω	In	- ms		arth ele					
					RCD	BS-EN		-	Pole	s -		Rat	ing	- m	ıΑ	Ipf	- kA	5In	- ms			istance		-		
				C	IRCUIT	DETAI	LS												TEST	RESU	LTS					
Circuit number	Circuit designation	Wiring type	Reference	Number of	Live mm ²	CPC mm ²	Maximum disconnection time	BS (EN)	Туре	Rating (A)	Short circuit	Max Zs permitted by RS7671	RCD operating current (In)	Phase (r1)	Neutral (rn)	CPC (r2)	R1+R2	R2	Live Live MΩ	Live Earth MΩ	Polarity check	Earth fault loop impedance	RCD time At In ms	RCD time At 5In ms	Test button operation	Vulnerable to test
1L1	Ofifce	Α	В	Ī -	2.5	2.5	0.4	60898	В	10	3	3.50	_	-	-	-	-	-	-	-	-	-	-	-	j -	-
1L2	Quiet Room	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1L3	Main Hall	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2L1	Main Hall	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2L2	Main Hall	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2L3	Disabled Toilet	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3L1	Male Toilet	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3L2	Female Toilet	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3L3	Kitchenette	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	1	-	-	-	-	-	ı	-	-	-	-	-	-
4L1	Smoking Room	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4L2	Not Used	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4L3	Not Used	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5L1	Not Used	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	_	-
5L2	Not Used	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5L3	Not Used	Α	В	_	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	_	-	-	-	
6L1	Not Used	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6L2	Not Used	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-





Δ	т	FI	F	C:	TRI	C	ΔΙ
_			_	${}^{\sim}$		\sim	\neg

6L3	Not Used	Α	В	-	2.5	2.5	0.4	60898	В	10	3	3.50	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Engine	er Paul Tillett				Date	13 3	Jan 201	.9 Signa	ature		,		(2	Ant	11	1	A P	VC/PVC cables			S FOR TYPES cables in meta		G XLPE/SW	A cables	
Positio	Owner												-6	w	W	ul			VC cables in m VC cables in no				metallic trunki	ng H MICC mir I Other	neral insulate	ed cables





GUIDANCE FOR RECIPIENTS

This Report is an important and valuable document which should be retained for future reference.

- 1 The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
- 2 The person ordering the Report should have received the "original" Report and the inspector should have retained a duplicate.
- 3 The "original" Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
- 4 Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested quarterly. For safety reasons it is important that this instruction is followed.
- 5 Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
- 6 Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D. For items classified in Section K as C1 ("Danger present"), the safety of those using the installation is at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.
- 8 For items classified in Section K as C2 ("Potentially dangerous"), the safety of those using the installation may be at risk and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
- 9 Where it has been stated in Section K that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extens or imitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (sec Section F).
- 10 For safety reasons, the electrical installation should be re-inspected a appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under "Recommendations' and on a label at or near to the consumer unit/distribution board.





Circuit chart supplied by:

A T Electrical Flat 1 116 Park Road Farnborough Hampshire GU14 6LS

									Circui	t Char	t Boa	ard:	DB9		
Client The Harlington (Fleet Council)							Occupier The P	oint							
Вс	pard location Rear Sto	rage Are	ea			Installa	ation address 236 F	236 Fleet Road							
Supply is from Origin							Hamp	Hampshire GU51 4BY							
	urrent device BS-EN	-					G031	וסד							
Overcurrent device rating for this board			A				Associated RCD for	or _			Pating	_	mA		
-	No of phases 3	3 Nominal voltage 4			400) V	this board BS(Ef	1	1	RCD Rating - RCD operating -					
	· L				C1	inductors				time at In			ms		
Circuit number	Circuit designation	Wiring Type	Reference Method	Number of points	mm²	octors odo mm²	BS (EN)	Type	Rating (A)	Short circuit capacity (kA)	RCD Operating current (mA)		Circuit vulnerable to test		
1L1	Lights - Hall and Main Office	А	В	-	1.5	1.5	60898	В	6	3	-		-		
1L2	Lights - Store and Toilets	-	-	-	1.5	1.5	60898	В	6	3		-	-		
1L3	Lights - Office and Music Store Room	-	-	-	1	1	60898	В	6	3		-	-		
2L1	Sockets - Main Hall Music Store Room, Office and Kitchenette	-	-	-	2.5	2.5	60898	В	32	3		-	-		
2L2	Water Heater - Disabled	-	-	-	2.5	2.5	60898	В	16	3		-	-		
2L3	Water Heater - Kitchenette	-	-	-	2.5	2.5	60898	В	16	3		-	-		
3L1	Sub Main Supply - DB12	-	-	-	10	10	60898	В	50	3		_	-		
3L2	Sub Main Supply - DB12	-	-	-	10	10	60898	В	50	3		-	-		
3L3	Sub Main Supply - DB12	-	-	-	10	10	60898	В	50	3		-	-		
4L1	Lights Main Hall (Incorrect)	-	-	-	1.5	1.5	60898	В	6	3		_	-		
4L2	Cyber Ring Main	-	-	-	2.5	2.5	60898	В	32	3		-	-		
4L3	Hand Dryer	-	-	-	2.5	2.5	60898	В	16	3		-	-		
5L1	Intruder Alarm	-	-	-	2.5	2.5	60898	В	16	3		-	-		
5L2	Outside Lighting	-	-	-	1	1	60898	В	6	3		-	-		
5L3	Water Heater - Cleaners Cupboard	-	-	-	2.5	2.5	60898	В	16	3		-	-		

Spare

6L1





Circuit chart supplied by:

A T Electrical Flat 1 116 Park Road Farnborough Hampshire GU14 6LS

											Circui	t Char	t Board:	DB9
Client The Harlington (Fleet Council)							Occupier The Point							
Во	ard location	Rear Storage Area					Installation address 236 Fleet Road Fleet							
Su	pply is from	Origin							Hampshire GU51 4BY					
Overcurrent device for this board									G031 41)				
Overcurrent device rating for this board		-	А				Associated RCD for					RCD	Rating -	mA
_	lo of phases	3	No	minal v	oltage	400	this board BS(EN) RCD No of poles -				RCD ope	ms		
-F			۵.			Cond	luctors	(ercurren	t protective	devices	ī	t t
Circuit number design			Wiring Type	Reference	Number of points		D5 (E		N) Type		Rating (A)	Short circuit capacity (kA)	RCD Operating current (mA)	Circuit vulnerable test
6L2	No Identifi	dentification		_	_	mm²	mm²	6089	8	В	32	3		_
6L3			-	_	-	2.5	2.5	6089	-	В	16	3	-	-
							S			,				,





Circuit chart supplied by:

A T Electrical Flat 1 116 Park Road Farnborough Hampshire GU14 6LS

Circuit Chart Board: DB12 Client The Harlington (Fleet Council) The Point Occupier 236 Fleet Road **Board location** Rear Storage Area Installation address Fleet Hampshire Supply is from Origin GU51 4BY Overcurrent device BS-EN for this board Overcurrent device Associated RCD for Α RCD Rating mΑ rating for this board this board BS(EN) No of phases ٧ Nominal voltage 3 RCD operating RCD No of poles ms time at In 2 Conductors Overcurrent protective devices number Wiring Type Reference Method vulnerable **RCD** Number of Short points Circuit g Rating circuit Operating Circuit 1 BS (EN) Type designation (A) capacity current (kA) (mA) mm² mm² 1L1 Ofifce Α В 2.5 2.5 60898 В 10 3 3 В _ 2.5 2.5 В 10 1L2 Quiet Room Α 60898 1L3 Main Hall В 2.5 2.5 60898 Α В 10 3 3 Main Hall В 2.5 2.5 60898 В 2L1 Α 10 2L2 2.5 2.5 60898 3 Main Hall Α В В 10 3 2L3 **Disabled Toilet** Α В 2.5 60898 10 2.5 Male Toilet 2.5 3L1 Α В 60898 В 10 3 3L2 Female Toilet В 2.5 2.5 60898 В 10 3 Α 3L3 2.5 2.5 60898 10 3 Kitchenette Δ В В _ _ 4L1 Smoking Room Α В 2.5 2.5 60898 В 10 3 _ _ 4L2 Not Used Α В _ 2.5 2.5 60898 В 10 3 _ 4L3 Not Used Α В 2.5 2.5 60898 В 10 3 2.5 3 5L1 Not Used Α В 2.5 60898 В 10 51.2 Not Used Α В 2.5 2.5 60898 В 10 3 _ В 2.5 2.5 В 10 3 5L3 Not Used Α _ 60898 _ 6L1 Not Used Α В _ 2.5 2.5 60898 В 10 3 _ В 2.5 2.5 В 3 6L2 Not Used Α 60898 10

6L3

Not Used

2.5

2.5

60898

В

10

3

В

Α