

Appendix J: Oil Top Up Volumes (2017/2018)



**South Tees
Site Company**

	Dock Road Indoor 66kV Substation to Transformer 67 at South Bank Coke Ovens	Corridor 66kV Substation to REF Mill 66kV Substation
Date	Volume (litres)	Volume (litres)
30-Jan-17	68	160
19-May-17	60	
01-Sep-17	84	
06-Nov-17		270
02-Jan-18	85	150
25-Jun-18	74	120
31-Oct-18	130	
12-Dec-18	70	160
Total	571	860