

BUNDLE 3 LOT 1: M&E: MARCH 2017

Course Title	Required	Comments
LU Safe Isolation - Levels 1, 2 & 3 (Electrical)	All Low Voltage electrical works must be undertaken and/or supervised by an appropriately certified Safe Isolation electrician at all times	Sufficient trained Supplier Personnel of appropriate levels for cover. For any work on all electrical Low Voltage non-Power Assets, as defined within LU Cat Std S1069.
Basic Type Disclosure from Disclosure Scotland	All Supplier Personnel accessing and/or undertaking maintenance activities in a substation environment	Required prior to undertaking LU Power Delivery Sub-station Low Voltage Authorised Person (LV1) or LU Power Delivery Sub-station Competence
First Aid		Sufficient trained Supplier Personnel for cover
Site Person in Charge – Non Track Sites	two or more in the shift, and all mobile teams	Sufficient trained Supplier Personnel for cover
PASMA	When working using high level access	Sufficient trained Supplier Personnel for cover
IPAF	When working using Motorised Access Platforms	Sufficient trained Supplier Personnel for cover
High Level Access Training	Where specialist access is required. Typically, at 7 No. Jubilee Line Stations awareness training for high level gantry systems is required to access public area lighting.	Sufficient trained Supplier Personnel for cover
NEBOSH	Health & Safety Manager	
IOSH Level Two	All Contract Managers and Health & Safety Advisor	

BUNDLE 3 LOT 1: M&E: MARCH 2017

SCHEDULE 23 : DOCUMENTS ON CD-ROM

The documents on the CD-ROM titled "Contract Reference Number TfL-00925 - 1FM Bundle 3 Lot 1 – Mechanical and Electrical Maintenance (Rail) – Documents on CD-ROM" are incorporated into the Contract.