

11 June 2020
1992

Richard Utting Associates LLP
63c Thorpe Road
Norwich
Norfolk
NR1 1UD
www.rua.co.uk

T: 01603 611 281
E: myles.hughes@rua.co.uk

Dear Sirs/Madam,

1992 – Design and Construction of the S278 Works at Hethersett Lane, Norwich – Tender Amendment Nr. 1

Further to our letter dated 20 May 2020 enclosing the tender documents for the above project, please will you make the following amendments to your tender:

- a) Pre-Construction Information document from AECOM under Appendix L, titled “NRP S278 CDM Project Plan 03.06.20”;
- b) Revised AECOM drawings; with the vertical alignment amended to accord with the Anglian Water Main position and agreement on cover levels with Anglian Waters Asset Management Team
- c) Revised AECOM drawings; please note the provision of the new drawing “GLS_001” Archaeology Excavation Survey, which shows the revised existing ground levels following the reduced level excavation works required to complete the Archaeological Watching brief.
- d) New Amey drawings;
- e) Revised Appendix F – List of Drawings – Rev B due to this Tender Amendment Nr. 1;
- f) Revised Appendix A – Contract Sum Analysis – Rev B containing new provisional sums; as follows
 - i. Substation Base – Provisional Sum
 - ii. Approximate Quantities for undertaking UKPN trenching (including sand backfill, backfill with selected site won material (if not under the carriageway) and disposal of surplus material), duct and tile tape installation
 - i. Please note that the trenching works is deemed to include a 3m x 3m jointing bay at a location to be agreed with UKPN and a depth to match the bottom of the trench
 - ii. Please note the ducting is to be installed in accordance with UKPN’s requirements and the **minimum** depth of the top duct is to be 750mm from the **adjacent finished road level**
- g) Revised Appendix A – Contract Sum Analysis – Rev B – Containing declaration of Contractors Overhead and Profit to be added to Provisional Sums and Approximate quantities

Cont’d.../

10 June 2020
1992

Dear Sirs/Madam,


1992 – Design and Construction of the S278 Works at Hethersett Lane, Norwich – Tender Amendment Nr. 1 Cont'd

h) Answers to questions from tendering contractors;

Ref	Question	Answer
Q1.	Are the Carter Design drawings included for information only and is the soft landscaping on the James Blake Associates drawings to be priced?	The scope of works is the Section 278 works and a section of road linking to the on-site road, which is shown on the Carter Design drawings. Landscaping is to be included to the Section 278 works only.
Q2.	Approximately 17m of road "missing" between Section 278 works on AECOM drawings and on-site roads in Carter Design information.	AECOM drawings updated to capture missing section of road.
Q3.	What do you anticipate to be the contractor's design & build requirement?	The Client will achieve technical approval of the Section 278 works and the contractor will have design responsibility from this point forward.
Q4.	What is the status of the street lighting design and as these works will form part of the contract when will a drawing or quotation from Amey be available?	Amey drawings provided.
Q5.	Item 37 of the Scope of Works states that topsoil is to be disposed of off-site, but Appendix 6/8 para. 6 states that surplus topsoil can be placed within landscape areas, which is correct?	The topsoil can be reused within the landscaping areas (subject to the quality – deemed the Contractors risk), however, any excess quantity will need to be disposed off-site.
Q6.	The Contract Sum Analysis includes an item for foul water drainage, what does this comprise?	No requirements for foul water drainage indicated on the drawings – Foul Water Manhole FW01 and the associated spur will be installed prior to the Contractor taking possession of the site.

To acknowledge that the changes under Tender Amendment Nr. 1 will be incorporated into your tender you are required to sign the section at the bottom of this letter and return a scanned copy by email to myles.hughes@rua.co.uk before the date of tender return.

Yours sincerely,



Myles Hughes BSc AssocRICS
Senior Quantity Surveyor
For Richard Utting Associates LLP

We acknowledge that the above amendments will be taken into account when preparing our tender.

Signed:

For and on behalf of:

Dated: