

## TENDER CLARIFICATIONS 18<sup>TH</sup> NOVEMBER 2020

---

- 1) Are there existing welfare facilities we can use, or would we be required to provide our own, like a self-contained Welfare unit that we could possibly site in the Contractors car park?

*A: We can provide access to toilets, water and an area to sit and eat lunch. There will be a kettle provided. Its location may not be next to the work sites, and will be shared with Horniman Staff, which means construction personnel will need to be mindful of social distancing etc.*

- 2) Clarification: the new bow top fencing at the Butterfly House works area should be powder coated prior to installation.
- 3) Is stretcher bond suitable instead of garden wall bond for the gardener's yard retaining wall facing?

*A: Yes, stretcher bond is acceptable, but please state clearly what you have allowed for.*

- 4) Is an extension to Friday 27<sup>th</sup> November possible

*A: Due to the time pressures on the project to be completed before the 31<sup>st</sup> March 2020, an extension to the tender period is unfortunately not possible.*

Tim Hopkins

Head of Estates

18.11.20