

Electrical Installation Condition Report Summary Ref: 248527/967419/2

Client Details		Installation Tested	
Client Address	Fleet Air Arm Museum Box D6 RNAS Yeovilton Ilchester Somerset	Occupier Address	Fleet Air Arm Museum Main Museum RNAS Yeovilton Ilchester Somerset
Post Code	BA22 8HT	Post Code	BA22 8HT
		Area Tested	As Above

Purpose of Report

To assess the condition of the electrical installation

Condition Report Defect Summary

Unsatisfactory	Remedial work required
Code 1 (C1)	0 Danger present. Risk of injury. Immediate remedial action required
Code 2 (C2)	174 Potentially dangerous - urgent remedial action required
Code 3 (C3)	377 Improvement recommended
Further Investigation	91 Further Investigation required without delay
No Code	General Observations made by the Inspector regarding the Installation
Note	In order to attain a "Satisfactory" result there must be no C1, C2 defects or items requiring "Further Investigation"

Inspection and Test Date and Next Due Date

Test Date **04-Nov-19** Retest Period **3 years** Next due **04-Nov-22**

The "Next due" date above applies provided all C1 Defects are remedied immediately and any defects identified as requiring "Further Investigation" should also be remedied without delay. In addition, any C2 Defects are to be remedied as a matter of urgency.

Electrical Installation Condition Report compiled by

Inspection Engineer	P Anderson	Depot	Yeovil	Date	04-Nov-19
Reviewed by	Ken Terry	Signed		Date	05-Jun-20
NICEIC Reg No	000500 - 107	Phone	01392 357102	Fax	01392 357103
Position	Inspection and Test Manager				
Company	SSE Contracting				
Address	Heron Road Sowton Industrial Estate Exeter Devon EX2 7FB				

Electrical Installation Condition Report Summary (continued)

Extent and Limitations

Extent:

The extent of the Installation Inspected and Tested is defined on the previous page in the "Installation Tested" section. If the Inspection and Test does not extend to the entire electrical installation at that location, the "Area Tested" defines the area(s) that have been tested. The extent of any sampling applied to the Inspection and Test can be found in the Scope of Works or Specification provided at the Quotation/Tender stage and/or as agreed with the Client and subject to the Client making the Inspector aware of all parts of the Installation to be tested.

Operational Limitations:

Any Operational Limitations imposed during the Inspection and Test, specific to parts of the Installation, will be identified in the "Observations and Recommendations for Action" Section 4 of this Condition Report.

Agreed Limitations:

All "Hazardous Area" installations (potentially explosive atmospheres) are excluded from this report. Access to the equipment above 3m has not been included in line with BS7671 unless specifically stated within the agreed Specification.

The following Agreed Limitations have been applied to the Condition Report overall:

- 1
- 2 Inspection of main supply equipment has not been possible as well as main earthing, bonding & main intake panel connected to origin of supply.

Engineers Comments

Not Applicable

This Electrical Installation Condition Report comprises the following:

- Section 1 Report Summary, Extent and Limitations, Guidance for Recipients
- Section 2 Installation Details
- Section 3 Schedule of Items Requiring Inspection
- Section 4 Observations and Recommendations for Action to be Taken
- Section 5 Index of Equipment Reports
- Section 6 114 Equipment Reports - Circuit Details and Test Results [1] to [114]

Note: This report must be read in its entirety and sections should not be read in isolation

Installation Details

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Installation History

Nature of Installation	Museum
Estimated age of the original installation	Unknown
Evidence of alterations/additions	Unknown
Date of previous inspection	Oct-2014
Previous records held by	Fleet Air Arm Museum
Previous Report Ref. Number	907296/967419/1

Supply Characteristics

Type of Electrical System	TN-C-S (Protective Neutral Bond)	
Number and type of live conductors	3 Phase 4 Wire (3 Phase & Neutral)	
Nominal Voltage (U) and Frequency (f)	400 - 420 Volts	50 Hz
Maximum Demand	800 A per phase	
External Earth Fault Loop Impedance (Ze)	Unknown	
PFC (value doubled if 3 phase)	Unknown	
Number of alternative supplies	1	
Supply 2	Generator	Unknown
Supply 3	N/A	
Polarity at Origin	Limitation	
Phase Rotation at the Origin	Not Verified	

Primary Supply Overcurrent Device(s)

BS (EN)	Unknown
Type	Unknown
Nominal current rating	Unknown
Short-circuit capacity	Unknown

Earth Electrode Details

Type	Not Applicable
Location	
Resistance	
Method of Measurement	

Main Switch or Circuit Breaker

Location	E43751	
Type BS (EN)	Unknown	
Number of poles	Unknown	
Supply conductor material	Unknown	
Supply conductor size	Unknown	
Voltage and Current rating	Unknown	Unknown

Main RCD Details

RCD	Voltage	Current Rating (A)	Operating Current (mA)	x1 Test (ms)	Rated Time Delay
1		Not Applicable			
2					

Earthing and Bonding Arrangements

	Required	CSA mm2	Material	Satisfactory	Location of Connection
Main Earthing Conductor	Yes	L	L	No	L
Water Service	Yes	L	L	No	L
Gas Service	Yes	L	L	No	L
Steelwork	Yes	L	L	No	L

Schedule of Items Requiring Inspection

Based on BS7671 (as amended)

Section 3

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Defect Code Key

Acceptable Condition	ü	Meets the requirements of BS7671 (as amended), no defects noted
Unacceptable Condition	Code 1 (C1)	Danger present. Risk of injury. Immediate remedial action required
Unacceptable Condition	Code 2 (C2)	Potentially dangerous - urgent remedial action required
Improvement Recommended	Code 3 (C3)	Improvement recommended
Further Investigation	Code FI (FI)	Further Investigation required without delay
Observation	(O)	Observation made by the Inspector
Not Verified	(NV)	This item has not been verified
Limitation	(L)	Limitation imposed and therefore Item has not been Inspected and or Tested.
Not Applicable	(NA)	This item is not applicable in the Installation tested

For full details of any Defects identified please refer to Section 4 of this Condition Report

Schedule of Items Requiring Inspection

Defect Code

A visual inspection will firstly be made of the external condition of all electrical equipment which is not concealed. Further detailed inspection, including partial dismantling of equipment as required, will be carried out as agreed with the person ordering the work. The Schedule of Items requiring inspection below are not exhaustive and other regulations, other than those listed may apply.

ELECTRICAL INTAKE EQUIPMENT	ü
• Service cable	ü
• Service head	ü
• Distributor's earthing arrangements	ü
• Meter tails - Distributor/Consumer	ü
• Metering equipment	ü
• Isolator	ü
Note: Where inadequacies in distributor's equipment are encountered, it is the responsibility of the person ordering the report to inform the appropriate authority	
PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES	ü
• Adequate arrangements where a generating set operates as a switched alternative to the public supply	ü
• Adequate arrangements where a generating set operates in parallel with the public supply	ü
AUTOMATIC DISCONNECTION OF SUPPLY	ü O
Main earthing/bonding arrangements	ü
1. Presence of distributor's earthing arrangement or presence of installation earth electrode arrangement	C2
2. Adequacy of earthing conductor size	ü
3. Adequacy of earthing conductor connections	C2
4. Accessibility of earthing conductor connections	C3
5. Adequacy of main protective bonding conductor sizes	ü
6. Adequacy and location of main protective bonding conductor connections	C2
7. Accessibility of all protective bonding connections	C3
8. Provision of earthing/bonding labels at all appropriate locations	ü
• FELV - requirements satisfied	NA
OTHER METHODS OF PROTECTION	NA

Schedule of Items Requiring Inspection

Section 3

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Schedule of Items Requiring Inspection	Outcome
• Non-conducting location	NA
• Earth-free local equipotential bonding	NA
• Electrical separation	NA
• Double insulation	ü
• Reinforced insulation	ü
DISTRIBUTION EQUIPMENT	FI
• Adequacy of working space/accessibility to equipment	ü
• Security of fixing	C2
• Condition of insulation of live parts	ü
• Adequacy/security of barriers	C2
• Condition of enclosure(s) in terms of IP rating etc	C2
• Condition of enclosure(s) in terms of fire rating etc	C3
• Enclosure not damaged/deteriorated so as to impair safety	C2
• Presence and effectiveness of obstacles	C2
• Presence of main switch(es), linked where required	C3
• Operation of main switch(es) (functional check)	ü
• Manual operation of circuit-breakers and RCDs to prove disconnection	ü
• Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check)	ü
• RCD(s) provided for fault protection - include RCBOs	ü
• RCD(s) provided for additional protection, where required - includes RCBOs	ü
• Presence of RCD six monthly test notice at or near equipment, where required	C3
• Presence of diagrams, charts or schedules at or near equipment, where required	C3
• Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required	C3
• Presence of alternative supply warning notice at or near equipment, where required	C3
• Presence of next inspection recommendation label	ü
• Presence of other required labelling	C2
• Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	ü O
• Single-pole switching or protective devices in line conductors only	ü
• Protection against mechanical damage where cables enter equipment	C2
• Protection against electromagnetic effects where cables enter ferromagnetic enclosure	C2
DISTRIBUTION CIRCUITS	FI
• Identification of conductors	C3
• Cables correctly supported throughout their run	ü
• Condition of insulation of live parts	ü
• Non-sheathed cables protected by enclosure in conduit, ducting or trunking	C3
• Suitability of containment systems for continued use (including flexible conduit)	ü
• Cables correctly terminated in enclosures	C2
• Confirmation that conductor connections, (refer to Extent and Limitations) including connections to busbars, are correctly located in terminals and are tight and secure	FI
• Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration	ü
• Adequacy of cables for current-carrying capacity with regard for the type and nature of installation	ü
• Adequacy of protective devices: type and rated current for fault protection	C2

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Schedule of Items Requiring Inspection	Outcome
• Presence and adequacy of circuit protective conductors	C2
• Coordination between conductors and overload protective devices	ü O
• Cable installation methods/practices with regard to the type and nature of installation and external influences	ü
• Where exposed to direct sunlight, cable of a suitable type	ü
• Cables concealed under floors, above ceilings, in walls/partitions less than 50 mm from a surface, and in partitions containing metal parts	C3
1. installed in prescribed zones. (refer to Extent and Limitations)	ü
2. incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (refer to Extent and Limitations)	ü
• Provision of fire barriers, sealing arrangements and protection against thermal effects	ü
• Band II cables segregated/separated from Band I cables	ü
• Cables segregated/separated from non-electrical services	ü
• Condition of circuit accessories	ü
• Suitability of circuit accessories for external influences	ü
• Single-pole switching or protective devices in line conductors only	ü
• Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment (refer to Extent and Limitations and Scope of Works)	C2
• Presence, operation and correct location of appropriate devices for isolation and switching	C2
• General condition of wiring systems	FI
• Temperature rating of cable insulation	ü
FINAL CIRCUITS	FI
• Identification of conductors	FI
• Cables correctly supported throughout their run	C3
• Condition of insulation of live parts	C2
• Non-sheathed cables protected by enclosure in conduit, ducting or trunking	C3
• Suitability of containment systems for continued use (including flexible conduit)	ü
• Adequacy of cables for current-carrying capacity with regard for the type and nature of installation	C2
• Adequacy of protective devices: type and rated current for fault protection	C2
• Presence and adequacy of circuit protective conductors	C2
• Coordination between conductors and overload protective devices	C2
• Wiring system(s) appropriate for the type and nature of the installation and external influences	C2
Cables concealed under floors, above ceilings, (refer to Extent and Limitations) in walls/partitions, adequately protected against damage	ü
1. installed in prescribed zones (refer to Extent and Limitations)	ü
2. incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (refer to Extent and Limitations) or	ü
Provision of additional protection by 30 mA RCD	ü
1. *for circuits used to supply mobile equipment not exceeding 32 A rating for use outdoors	C2
2. *for all socket-outlets of rating 32 A or less unless exempt	C3
3. *for cables concealed in walls at a depth of less than 50 mm	ü
4. *for cables concealed in walls/partitions containing metal parts regardless of depth *Note: Older installations designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. RCD protection required on all circuits in Domestic installations	ü
5. *for final circuits supplying luminaires within domestic (household) premises	ü

Schedule of Items Requiring Inspection

Section 3

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Schedule of Items Requiring Inspection	Outcome
• Provision of fire barriers, sealing arrangements and protection against thermal effects	ü
• Band II cables segregated/separated from Band I cables	ü
• Cables segregated/separated from non-electrical services	ü
• Termination of cables at enclosures - identify/record numbers and locations of items inspected	C2
1. Connections under no undue strain	ü
2. No basic insulation of a conductor visible outside enclosure	C2
3. Connections of live conductors adequately enclosed	ü
4. Adequately connected at point of entry to enclosure (glands, bushes etc.)	C2
• Condition of accessories including socket-outlets, switches and joint boxes	C2
• Suitability of accessories for external influences	C3
• Single-pole switching or protective devices in line conductors only	ü
ISOLATION AND SWITCHING	ü
Isolators	ü
1. Presence and condition of appropriate devices	C2
2. Acceptable location	ü
3. Capable of being secured in the OFF position	ü
4. Correct operation verified	ü
5. Clearly identified by position and/or durable marking	ü
6. Warning label posted in situations where live parts cannot be isolated by the operation of a single device	ü
Switching off for mechanical maintenance	ü
1. Presence and condition of appropriate devices	ü
2. Acceptable location	C2
3. Capable of being secured in the OFF position	ü
4. Correct operation verified	ü
5. Clearly identified by position and/or durable marking	ü
Emergency switching/stopping	NA
1. Presence and condition of appropriate devices	NA
2. Readily accessible for operation where danger might occur	NA
3. Correct operation verified	NA
4. Clearly identified by position and/or durable marking	NA
Functional switching	ü
1. Presence and condition of appropriate devices	ü
2. Correct operation verified	ü
CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)	ü O
• Condition of equipment in terms of IP rating etc	C2
• Equipment does not constitute a fire hazard	ü
• Enclosure not damaged/deteriorated so as to impair safety	C2
• Suitability for the environment and external influences	ü
• Security of fixing	C2
• Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire	ü
• Recessed luminaires (downlighters)	ü

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Schedule of Items Requiring Inspection	Outcome
1. Correct type of lamps fitted	ü
2. Installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar	ü
3. No signs of overheating to surrounding building fabric	ü
4. No signs of overheating to conductors/terminations	ü
PART 7 SPECIAL INSTALLATIONS OR LOCATIONS	
Note: If any special installations or locations are present, the items Inspected will be based on the Requirements of Guidance Note 7 relevant to the Special Installation or Location	
Locations containing a Bath or Shower	ü
Swimming Pools and Other Basins	NA
Rooms and Cabins containing Sauna Heaters	NA
Construction and Demolition site installations	NA
Agricultural and Horticultural installations	NA
Conducting locations with restricted movement	NA
Electrical installations in Caravan/Camping Parks and similar locations	NA
Marinas and similar locations	NA
Medical locations	NA
Exhibition Shows and Stands	NA
Solar Voltaic (PV) Power Supply Systems	NA
Mobile or Transportable Units	NA
Electrical installations in Caravans and Motor Caravans	NA
Operating and Maintenance Gangways	NA
Temporary Electrical Installations – Amusement Devices, Fairgrounds, Amusements Parks & Circuses	NA
Heating Cables and Embedded Heating Systems	NA
Outdoor Lighting Installations	NA
Extra Low Voltage Lighting Installations	NA
Electric Vehicle Charging Installations	NA
Onshore Units of Electrical Shore Connections for Inland Navigation Vessels	NA

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Defect Code Key

Unacceptable Condition	Code 1 (C1)	Danger present. Risk of injury. Immediate remedial action required
Unacceptable Condition	Code 2 (C2)	Potentially dangerous - urgent remedial action required
Improvement Recommended	Code 3 (C3)	Improvement recommended
Further Investigation	Code FI (FI)	Further Investigation required without delay
No Code		Observation made by the Inspector
Limitation	(L)	Limitations imposed and therefore Item has not been Inspected and or Tested
Note	In the "Fixed" Column "Yes" indicates SSE Contracting has corrected the Defect, "Others" indicates its been corrected by someone else. "Remains" indicates the Defect was identified on a previous EICR and still remains.	

Item	Code	Description	Fixed
------	------	-------------	-------

General Deviations

1	3	It was not possible to confirm the position of the final termination of the protective bonding conductor. All main earthing & bonding not inspected.	
2	3	Access to the origin of the installation was not afforded, therefore we are unable to confirm the method of earthing and adequacy of main Protective bonding.	
3	3	Access to the terminations of the Protective bonding conductors was not afforded, therefore been assumed that the method of protection against fault protection is ADS.	
4	3	There were no Surge Protection Devices (SPDs) installed as a means of Protection against overvoltages.	
5	3	It is recommended additional protection against arcing caused by fault currents is installed for these final circuits. Gas/boiler rooms, workshop, all areas of timber frame.	

[1] Main Intake Panel Hall 2 Switch Room

6	2	The Main earthing conductor connections are unsatisfactory. Circuit 4L123, the cable sheath earth has not been extended in the switch fuse enclosure.	
7	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
8	3	The Insulation test shows results lower than expected but above the permissible levels. Circuit 9L123.	
9	FI	A restriction on isolation was imposed at the time of testing in the following areas. This item of equipment has not been inspected and therefore isolation of end testing has not been possible.	
10	FI	Due to operational restrictions we have been unable to verify that all connections on the distribution equipment are correctly located in terminals and are tight and secure.	
11		The Overcurrent device(s) (fuses/MCBs) protecting the Distribution circuit(s) appear(s) to be of an incorrect rating. Circuit 4L123 switch fuse has 32A BS88 fuses with 6mm singles outgoing for light control.	

[2] DB F/ISO Swordfish Kitchen Intake

12	2	The method of terminating the distribution circuit conductors is unsuitable. No SWA earthing ring/fly lead on incoming this enclosures earth terminal to downstream equipment.	
13	2	Earth Loop Impedance values were unsatisfactory. Circuit 1L123.	
14	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
15	3	There is no appropriate labelling for identification purposes in respect of the following: No labelling to bonding/earthing conductors.	
16	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Outgoing terminal shield is unfixed.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
17	3	The fire rating of the enclosure is inadequate. Internal terminal shields are flammable material - cardboard.	
18		10mm bonding in gas and water pipes in switch room.	

[3] DB/F/BB Swordfish Kitchen Intake

19	2	There is no appropriate labelling for identification purposes in respect of the following: No labelling to indicate exposed live parts internally, isolate elsewhere.	
20	2	Earth Loop Impedance values were unsatisfactory. Circuits 1L123, 2L123.	
21	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. No IP protection to internal live parts.	
22		No protective devices within equipment therefore max Zs provide by upstream fuse protection - 160A BS88.	

[4] DB F/1 Swordfish Kitchen Intake

23	2	The Distribution equipment is inadequately fixed or insecure. Circuit 6L123 RCD above DB is no fixed inside enclosure and is loose when cover removed.	
24	2	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 8L2, 1 of 2 screws missing from fire alarm cover.	
25	2	The distribution circuit CPC does not appear to be large enough to act as a combined protective and bonding conductor. Main bonding terminal above this DB is connected via 10mm earth from earth bar, continuous earth should be present from incoming cable sheath earth at main isolator. Main frame earth used through busbar enclosure and main isolator enclosure.	
26	2	The termination / jointing of final circuit cables is unsatisfactory. Where Klik roses have been used on some restaurant lights, no back box has been fitted. Connections are not contained and rose is screwed to the wooden boxing.	
27	2	The equipment enclosure has been damaged/deteriorated. 10L123 control panel for walk in fridge - 1 of 2 panel clips is broken.	
28	2	The Earth continuity results were unsatisfactory. 9L123 restaurant heater, no CPC continuity to heater controller by chain door, 240 in multicore CPC not connected.	
29	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
30	3	Cable entry holes include no suitable protection (such as grommets or grommet strip) to avoid damage to the cable where they enter the equipment. No grommet protection where CPC enters DB.	
31	3	There appears to be no discrimination between protective devices. Some circuits have plugged in sockets with integral RCDs. These are exempt from test as plugged in but should be noted that these sockets are downstream from DB RCBO, 4L1, 5L3, 6L123.	
32	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
33	3	It has not been possible to carry out the following insulation tests: L-L where unable to remove loads.	
34	FI	Despite reasonable investigation, some final circuits could not be traced. 3L2 labelled as restaurant extra coffee machine, unable to locate.	
35		The protective device is showing signs of heat damage. Evidence of previous fault on neutral bar L/H/S, some superficial damage to N bar & plastic mounting MCB 6L123 appears new.	
36		7L1, 7L2, 7L3 circuits tested to form controllers only.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
37		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible. Circuit 8L2.	
38		There was an accessory with an integral RCD. The location and test results are as follows: 6L123 RCD above DB - ½ = Pass, x 1 = 49.9ms, x 5 = 14.1ms, Test Button = Pass.	
39		There was an accessory with an integral RCD. The location and test results are as follows: 11L123 RCD above DB - ½ = Pass, x 1 = 28.6ms, x 5 = 15.4ms, Test Button = Pass.	

[5] DB F/3 Swordfish Centre Electrical Cupboard

40	2	An appropriate and adequate device for isolating or switching is required on the distribution circuit. Supply SWA not terminated correctly, no gland and taped up where entering enclosure.	
41	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
42	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No neutral bar shield as per design.	
43	3	Due to the lack of Information about construction of the partitions it is recommended that a 30mA RCD is installed on this cable to ensure that minimum protection levels are maintained. Circuit 4L2 spot lights high level, out of reach.	
44	3	The termination / jointing of final circuit cables is unsatisfactory. Floating connectors inside DB.	
45	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 5L2.	

[6] DB F/9 Dry Store

46	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Hole on top surface of DB where cables leaves enclosure.	
47	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
48	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No neutral bar shield as per designs.	
49	FI	It was not possible to confirm the position of the final termination of the protective bonding conductor. 10mm CPC leaves DB to unknown location.	
50	FI	The termination / jointing of final circuit cables is unsatisfactory. Obscure method of connection on ring main circuit 1L3, ring appears to be connected in connector blocks inside DB with 3rd cable spurred at this point.	
51	FI	Appropriate means of isolation for the equipment is either absent or in poor condition. Circuit 2L3 unknown joint in circuit where old colour T+E leaves DB but new colours at water heater and no point of isolation.	

[7] DB F/5 Servery Café

52	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
53	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
54	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. Internal live parts exposed.	
55	3	The termination / jointing of final circuit cables is unsatisfactory. Unterminated cores in DB.	
56	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
57	FI	Unknown flex connected only to neutral in DB.	

[8] DB F/2 Swordfish Café

58	2	The Overcurrent device(s) (fuses/MCB's) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 10L1, 1.5mm T+E on 16A MCB.
59	2	The current carrying capacity of the final circuit cable does not appear adequate for the potential load. Circuit 1L2 bug zapper opposite is wired in 1.5 flex, spurred from 32A ring main.
60	2	The termination / jointing of final circuit cables is unsatisfactory. Unused cores taped up with masking tape inside DB.
61	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 1L1 socket in switch room has 4 x cables terminated in one socket.
62	2	The condition of the electrical accessory is unsatisfactory. Circuit 1L3 switch fuse for heater is broken/cracked.
63	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.
64	3	The distribution circuit is not in use and should be removed to simplify the installation. Circuit 4L2 spare RCD fails to trip on test and test button should be removed to avoid future connection to it.
65	3	The termination / jointing of final circuit cables is unsatisfactory. Floating connections inside DB.
66	3	The termination / jointing of final circuit cables is unsatisfactory. Circuit 2L2, 2.5 T+E is extended to sockets in trunking with connector blocks.
67	3	Single Insulated final circuit cables are not installed in an appropriate protective system such as conduit or trunking. Circuit 1L1 single pass through trunking into conduit but no bush on conduit and single unswitched cables exposed.
68	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.
69		There was an accessory with an integral RCD. The location and test results are as follows: Circuits 5L2, 5L3, 6L1 RCD above DB - ½ = Pass, x 1 = 48.6ms, x 5 = 15ms, Test Button = Pass.

[9] DB D/A Hall 4 Adjacent Concorde

70	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.
71	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No neutral bar shield in DB.
72	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.
73	3	The following final circuit(s) was found off, left off and not tested. Circuit 6L123.
74	FI	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Circuits 5L123, 9L123 no access at time of test.
75		95mm bond to steel work left hand side of DB.

[10] DB D/D Concorde Rear Door

76	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Circuit chart not up to date.
77	3	There is no notice warning of mixed wiring colours to two versions of BS7671.

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
78	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering. Cores not labelled within DB.	
79	3	It has not been possible to carry out the following insulation tests: Lighting.	
80	3	It has not been possible to carry out insulation tests LIVE to CPC due to the sensitivity of some of the electronic control gear in circuit. Lighting.	

[11] DB D/F (Toilet DB) Concorde Hall Toilets

81	2	The Main earthing conductor connections are unsatisfactory. SWA earthing ring not drilled & connected to earth bar at DB.	
82	3	The termination / jointing of final circuit cables is unsatisfactory. Cables within DB not earthed down.	
83	3	It has not been possible to carry out the following insulation tests: Lighting circuits 7L3, 8L3.	
84	3	It has not been possible to carry out insulation tests LIVE to CPC due to the sensitivity of some of the electronic control gear in circuit. Lighting circuits 7L3, 8L3.	

[12] DB D/E Hall 4 Concorde

85	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
86	3	Final circuit cable conductors/CPCs are not correctly colour coded/identified. Circuit 1L1, 3L3 neutrals (phase coloured), 2L1, 1L2, 1L1, 2L2 (phases incorrectly coloured).	
87	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 6L3.	

[13] DB D/D Hall 4 Concorde

88	2	Earth Loop Impedance values were unsatisfactory. Circuit 4L1.	
89	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
90	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
91	FI	Despite reasonable investigation, some final circuits could not be traced. Circuits 2L1, 5L2, 9L3, 13L3, 14L3, 16L3, 20L2.	
92	L	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Limitations on all circuits.	
93		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 12L3 RCD unit by socket - ½ = Pass, x 1 = 19ms, x 5 = 15.2ms, Test Button = Pass.	

[14] DB D/C Hall 4 Concorde

94	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Blanks missing from DB.	
95	2	The protective device for fault protection of the final circuit does not appear to be appropriate. 24L123 phase circuit connected with single phase MCBs.	
96	2	The condition of the electrical accessory is unsatisfactory. Circuit 21L2 socket on pillar has broken lug in back box.	
97	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
98	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No neutral bar shield in DB.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
99	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering. Some sockets/accessories wired in non standard colours i.e. yellow on L1.	
100	FI	Despite reasonable investigation, some final circuits could not be traced. Circuits 1L1, 3L2, 5L1, 12L2, 13L1.	
101	FI	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Limitations on all circuits.	
102		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 4L1 3 x RCD sockets worst reading recorded.	
103		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 7L1 RCD unit - ½ = Pass, x 1 = 24.8ms, x 5 = 17.1ms, Test Button = Pass.	
104		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 7L2 RCD unit - ½ = Pass, x 1 = 28.9ms, x 5 = 18.9ms, Test Button = Pass.	
105		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 11L1 RCD unit - ½ = Pass, x 1 = 28.5ms, x 5 = 18.8ms, Test Button = Pass.	
106		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 12L1 RCD unit - ½ = Pass, x 1 = 28.5ms, x 5 = 18.6ms, Test Button = Pass.	
107		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 6L3 RCD unit - ½ = Pass, x 1 = 28.7ms, x 5 = 18.9ms, Test Button = Pass.	
108		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 6L2 RCD unit - ½ = Pass, x 1 = 19ms, x 5 = 15.9ms, Test Button = Pass.	
109		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 8L3 RCD unit - ½ = Pass, x 1 = 20.9ms, x 5 = 10.4ms, Test Button = Pass.	

[15] Sub A ISO 1 Hall 2

110	2	Appropriate means of isolation for the equipment is either absent or in poor condition. Door interlock does not work as has been disconnected internally.	
111	3	Due to the suspected presence of Asbestos containing materials (ACMs), it has not been possible to carry out all required inspection and testing on this switchgear. Excluded due to internal asbestos, circuits isolated at tested back boards.	
112	FI	Due to the suspected presence of Asbestos containing materials (ACMs), it is recommended that an Asbestos warning label is fitted to this Switchgear. No labelling to indicate asbestos internally.	
113	FI	This Item of switchgear has reached the end of its serviceable life due to its age / condition. It should be replaced with a modern equivalent to ensure the continued safe operation and use of the electrical installation.	
114		Ze calculated from upstream readings.	

[16] Sub A /BB Hall 2 Sub A Old Intake Room

115	2	There is no appropriate labelling for identification purposes in respect of the following: No labelling to indicate live parts exposed internally.	
116	2	The manner in which cables enter equipment could result in undesirable electromagnetic effects. Neutral feed to changeover switch passes through different hole to phases.	
117	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. No internal IP protection in changeover switch, equipment is not used and should be removed.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
118	3	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Inaccurate circuit chart in place.	
119	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No internal IP protection, all live parts exposed internally.	
120	3	This item of equipment does not afford a minimum standard of IP2X protection once opened.	
121	3	The termination / jointing of final circuit cables is unsatisfactory. 70mm fly lead is unterminated where hanging from Isolator DB A/3 circuit 8L123.	
122		No internal fusing, max Zs provided by upstream 200A BS88 fuses.	

[17] IS DB A/4 Hall 2 Sub A Old Intake Room

123 3 The Provision of diagrams, charts or schedules at or near equipment is inadequate.

[18] DB A/4 1st Floor Merlin Exhibition

124 2 The IP rating of the enclosure is unsatisfactory. Oversized large holes on top and bottom surfaces of DB.

125 2 Earth Loop Impedance values were unsatisfactory. Circuits 3L2, 4L1.

126 3 The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart place.

127 3 Socket outlets rated up to 32A are not protected by a 30mA RCD. No 30mA protection to all sockets.

128 3 The termination / jointing of final circuit cables is unsatisfactory. Floating connectors inside DB.

129 3 It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.

130 FI Despite reasonable investigation, some final circuits could not be traced. Circuit DB at bottom stairs is accurate.

131 There is no appropriate labelling for identification purposes in respect of the following: Circuits go via switches next to DB, switches not labelled.

132 It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible. Low IR unable to remote loads.

[19] IS DB/A/1 & 2 Hall 2 Sub A Old Intake Room

133 3 The Provision of diagrams, charts or schedules at or near equipment is inadequate.

[20] DB A/1 Hall 2 Sub A Old Intake Room

134 2 The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. All internal live parts exposed, no main switch or labelling to indicate this, requires upstream isolation.

135 2 The Overcurrent device(s) (fuses/MCB's) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 6L3, 2.5mm on 30A.

136 2 The Overcurrent device(s) (fuses/MCB's) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 1L3, 6mm on 50A.

137 2 Earth Loop Impedance values were unsatisfactory. Circuits 5L3, 6L3.

138 3 The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.

Occupier **Fleet Air Arm Museum**
Installation Address **Main Museum, RNAS Yeovilton**
Specific Location **Not Applicable**

Item	Code	Description	Fixed
139	3	Cable entry holes include no suitable protection (such as grommets or grommet strip) to avoid damage to the cable where they enter the equipment. Circuit 3L1 no grommet protection, this cable leaves top surface of DB.	
140	3	The termination / jointing of final circuit cables is unsatisfactory. Floating connectors in DB and unterminated cores.	
141	FI	The termination / jointing of Distribution circuit cables is unsatisfactory. Circuit 5L1 unknown joint in circuit, 2x2.5mm at MCB, 1 x 6mm at DB and CPC is unknown.	
142	FI	This Item of switchgear has reached the end of its serviceable life due to its age / condition. It should be replaced with a modern equivalent to ensure the continued safe operation and use of the electrical installation. Due to the age/condition of DB would advise replacement of equipment.	
143	FI	The distribution circuit is not in use and should be removed to simplify the installation. Main circuits are labelled as old supply no longer in use, these should be removed/disconnected to simplify the installation.	
144	FI	The termination / jointing of final circuit cables is unsatisfactory. Circuit 5L3, 2x2.5mm at MCB, unknown number of points, IR low.	
145	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 6L1 labelled as lights but unknown.	
146	FI	The following final circuit(s) was found off, left off and not tested. Multiple circuits found off, left off and not tested, 1L1, 2L123, 3L1, 4L1, 4L3, 7L1, 7L2.	
147	FI	Due to the way in which the ring circuit conductors were connected within the distribution board it was not possible to test the ring continuity of some conductors. Circuit 6L1, unknown in circuit where 2x2.5mm at MCB, circuit is unknown but labelled as lighting, unable to carry out ring continuity at DB.	
148	FI	Circuit 5L3 unable to test ring N-N & E-E due to method of connection inside DB and unknown accessories, socket tested by coastguard resume, appears to be a radial.	
149	FI	Unknown type of BS3871 MCB.	

[21] DB A/15 Conservation Room Hall 2

150	2	Final circuit cables are not double insulated where entering the enclosure. Circuit 4L3 some T+E cable stripped back outside of lights above suspended ceiling and some cables are unfixed/supported.	
151	2	Final circuit accessories are not appropriate for the environment in which they are installed. Some fittings on circuit 4L3 have unused holes in.	
152	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
153	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. No RCD protection circuit 1L3, 2L3, 3L3.	
154	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
155		Installation of emergency lighting in store area should be considered.	
156		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	

[22] DB A/17 Carrier Exhibition Korea End

157	2	There is no appropriate labelling for identification purposes in respect of the following: No labelling to indicate exposed live terminals inside DB.	
-----	---	---	--

Occupier **Fleet Air Arm Museum**
Installation Address **Main Museum, RNAS Yeovilton**
Specific Location **Not Applicable**

Item	Code	Description	Fixed
158	2	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Open hole in top surface of DB where unused SWA gland in place.	
159	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuits 4, 5, 6 the protective device exceeds the max current capacity of the 1.5 flex connected.	
160	3	There is no six monthly test notice for RCD's.	
161	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
162	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. Internal barriers/terminal guards missing on all internal live parts.	
163	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
164	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 3 appears to supply hut behind DB but unknown point of entry/connection. Zs measured in hut and worst reading recorded.	
165		Non traditional wiring in use, all circuits wired in flex 20m+.	

[24] DB A/14 Wrens Gallery Cupboard

166	3	There appears to be no discrimination between protective devices. Upstream 30mA RCD.	
167		Circuit 1L3 only 1 point accessed for testing, circuit chart indicates 9 points in circuit.	

[25] SF/DB A/2 SKUA Exhibition Cupboard

168	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
169	3	This item of equipment does not afford a minimum standard of IP2X protection once opened.	
170	FI	Due to the suspected presence of Asbestos containing materials (ACMs), it has not been possible to carry out all required inspection and testing on this switchgear. Asbestos flash guards inside switch fuse L2 fuse only.	
171		Incoming supply is connected via internal busbars of DB A/1 S36824.	
172		Earth loop impedance measured at internal L1 & L3 incoming terminals.	

[26] DB A/2 SKUA Stairway

173	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
174	3	Some equipment/accessories inaccessible behind showcase.	
175	L	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Circuit 3L1 unable to access 240V with CPC supply to lights above ceiling structure.	

[27] IS DB/A/5 & 7 Hall 2 Sub A Old Intake Room

176	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Inaccurate circuit chart in place.	
-----	---	---	--

[28] DB A/7 Hall 2 Store Room

177	2	There is no appropriate labelling for identification purposes in respect of the following: No labelling to indicate live parts exposed and upstream isolation required.	
-----	---	---	--

Occupier **Fleet Air Arm Museum**
Installation Address **Main Museum, RNAS Yeovilton**
Specific Location **Not Applicable**

Item	Code	Description	Fixed
178	2	Cable entry holes include no suitable protection (such as grommets or grommet strip) to avoid damage to the cable where they enter the equipment. Inadequate grommet protection on top L/H/S of DB exposing hole inside of enclosure.	
179	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. All internal live parts exposed, tape used to cover incoming terminals.	
180	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 6L1, 3 x 2.5 radials on 30A MCB.	
181	2	The current carrying capacity of the final circuit cable does not appear adequate for the potential load. Circuit 8L2 extract from spurred from ring in room 120 in 1.5 T+E.	
182	2	The termination / jointing of final circuit cables is unsatisfactory. The termination of CPCs in the earth bar is unacceptable with cores of single cables not terminated and bunches of cables in 1 x terminal.	
183	2	The termination / jointing of final circuit cables is unsatisfactory. Unterminated cores within DB.	
184	2	Earth Loop Impedance values were unsatisfactory. Circuits 4L1, 4L2, 6L1 heater room 118.	
185	2	The Ring circuit continuity is not satisfactory.	
186	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
187	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. No RCD to sockets, circuits 4L1, 4L2, 8L2, 3L2, 6L1, 3L2, 5L3, 7L3.	
188	3	The termination / jointing of final circuit cables is unsatisfactory. Floating connectors inside DB.	
189	3	There is no suitable Sleeving on the CPC to indicate its function. CPC sleeving does not cover entire length of wire leaving excessive exposed copper in DB.	
190	3	It has not been possible to carry out the following insulation tests: L-L where equipment connected.	
191	FI	This Item of switchgear has reached the end of its serviceable life due to its age / condition. It should be replaced with a modern equivalent to ensure the continued safe operation and use of the electrical installation. Due to the age/condition of this equipment it is advised that it be replaced.	
192	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 6L1, 3 x 2.5mm on 30mA MCB appears to be 3 x radial, 1 of which is unknown.	
193	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 2L1 unknown number of points, 2 counted by 2 x 1.5mm T+E in EM O/S library door.	
194	FI	Despite reasonable investigation, some final circuits could not be traced. Circuits 1L3, 3L3, 4L3, 5L1, 5L2, 7L1.	
195	FI	Circuit 1L1 - 3 x emergency lights in hall 2 but lighting in this area from different supplies.	
196		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible. Low IR as unable to remove loads.	

[29] DB A/16 Top of U Boat Submarine

197	2	The IP rating of the enclosure is unsatisfactory. Hole in bottom of DB.	
198	3	There is no six monthly test notice for RCDs. No RCD test sticker.	
199	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
200	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 1 of 4 DB cover screws missing.	
201	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
202		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	

[30] 152 DB A/5 Hall 2 Store Room

203	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Where the switch has been disconnected the switch bar parts are exposed and live.	
204	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
205	FI	Appropriate means of isolation for the equipment is either absent or in poor condition. The switch has been disconnected from the internal mechanism so this unit is a straight through fuse connections but no isolation available before opening cover as fed from live side to adjacent DB.	

[31] DB A/5 Library Office

206	2	The Ring circuit continuity is not satisfactory. No ring continuity circuit 2L2 possible 2 x radials.	
207	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuits 1L1, 2L1, 2L2.	
208	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
209	FI	The termination / jointing of final circuit cables is unsatisfactory. Circuit 2L2 unknown joint in cable, ring main leaves DB but only 2.5 radial found in retail managers office.	
210	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 3L3, 4L1, 4L2 circuits go via contactor L/H/S DB and labelled storage heaters, contactor left off for confirmation.	
211	FI	Insulation Test results were unsatisfactory. Circuit 1L1 all points supposedly found but low IR readings.	
212		Emergency lighting in office area is on different circuit to lights, circuit 1L3.	

[32] DB A/6 Hall 2 Sub A Old Intake Room

213	2	There is no appropriate labelling for identification purposes in respect of the following: No warning notice of exposed live parts internally.	
214	2	The IP rating of the enclosure is unsatisfactory. Top L/H/S of DB 20mm hole.	
215	2	Earth Loop Impedance values were unsatisfactory. Circuit 4L2.	
216	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
217	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 1 of 4 cover screws missing.	
218	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. No internal shields or barriers within DB after main switch.	
219	3	Incoming terminal guard made of card/paper.	
220	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. No 30mA protection to sockets - circuits 5L3, 4L1, 4L2, 10L3, 4L3, 10L2, 10L1.	
221	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering. Blue core terminated into MCB circuits 3L1 & 3L3.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
222	3	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. High level lighting out of reach, circuit 7L3, 8L1, 9L2 agreed limitation of circuit.	
223	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
224	FI	This Item of switchgear has reached the end of its serviceable life due to its age / condition. It should be replaced with a modern equivalent to ensure the continued safe operation and use of the electrical installation. Age and condition of this item of equipment means replacement would be advised.	
225	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 3L3 unknown number of points in total, 1 x emergency light on stairwell located but labelled as lights and 2 x 1.5 at MCB.	
226	FI	Despite reasonable investigation, some final circuits could not be traced. Circuits remain unidentified after 2 tests, circuits 8L2, 9L1, 9L3.	
227	FI	Appropriate means of isolation for the equipment is either absent or in poor condition. Incoming tails pass through isolators below, no dedicated isolation for equipment, isolated at installation main isolation only.	

[33] IS DB A/8 & 9 Hall 2 Sub A Old Intake Room

228	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
229	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit (Meter).	
230		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible. Low IR where equipment in circuit.	

[34] DB A/8 Hall 2 Workshop

231	2	There is no appropriate labelling for identification purposes in respect of the following: No labelling to indicate exposed live parts internally.	
232	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. No IP2X protection on incoming terminals.	
233	2	The Overcurrent device(s) (fuses/MCB's) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 5L1 - 2 x 2.5mm radials on 32A MCB.	
234	2	The termination / jointing of final circuit cables is unsatisfactory. Incoming tails have been jointed inside DB with floating connectors.	
235	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 1 of 4 screws missing from DB cover.	
236	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. No IP2X protection on all terminals after main switch.	
237	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 4L1.	
238	3	The termination / jointing of final circuit cables is unsatisfactory. Floating connectors inside DB.	
239	3	It has not been possible to carry out the following insulation tests: L-L where unable to remove loads.	
240	FI	This Item of switchgear has reached the end of its serviceable life due to its age / condition. It should be replaced with a modern equivalent to ensure the continued safe operation and use of the electrical installation. Due to the age and condition of this equipment it is advised that it be replaced.	
241	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 1L1, 6L3.	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Item	Code	Description	Fixed
[35] DB A/9 Hall 2 Workshop			
242	2	There is no appropriate labelling for identification purposes in respect of the following: DB is labelled - do not switch off. No notice of exposed live parts inside.	
243	2	The manner in which cables enter equipment could result in undesirable electromagnetic effects. Supply phase and neutral enter through different holes.	
244	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Screw missing on incoming terminal cover exposing live connections.	
245	2	The IP rating of the enclosure is unsatisfactory. Blank missing from DB cover.	
246	2	The Earth continuity results were unsatisfactory. Circuit 3L3 - no earth to switch above stop/start control above bench.	
247	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
248	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 1 of 4 screws missing from DB cover.	
249	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. No internal barriers/live parts exposed internally.	
250	3	Incoming terminal cover made of flammable card/paper.	
251	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 1L1 - No RCD to 13A socket.	
252	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
253	3	The following final circuit(s) was found off, left off and not tested. Circuit 3L2.	
254	FI	This Item of switchgear has reached the end of its serviceable life due to its age / condition. It should be replaced with a modern equivalent to ensure the continued safe operation and use of the electrical installation. DB is aged, overcrowded and non maintainable.	
[36] IS DB A/11 Hall 2 Sub A Old Intake Room			
255	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
[37] DB A/11 Hall 2 Workshop			
256	2	There is no appropriate labelling for identification purposes in respect of the following: No labelling to indicate no IP2X internally.	
257	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Non IP2X on incoming terminals.	
258	2	The IP rating of the enclosure is unsatisfactory. Oversized hole/grommet on bottom of DB.	
259	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate/out of date circuit chart in place.	
260	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. No internal barriers inside DB after main switch.	
261	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 2L3.	
262	3	There is no suitable Sleeving on the CPC to indicate its function. Green only sleeving on CPCs.	
263	3	It has not been possible to carry out the following insulation tests: L-L where equipment connected.	

Occupier **Fleet Air Arm Museum**
Installation Address **Main Museum, RNAS Yeovilton**
Specific Location **Not Applicable**

Item	Code	Description	Fixed
264	FI	This Item of switchgear has reached the end of its serviceable life due to its age / condition. It should be replaced with a modern equivalent to ensure the continued safe operation and use of the electrical installation. Age & condition of this item of equipment means replacement is advised.	
265	FI	Despite reasonable investigation, some final circuits could not be traced. 10mm earth leaves DB to unknown location, possible bonding.	
266	FI	Despite reasonable investigation, some final circuits could not be traced. 6mm earth at DB, unknown origin connection, not at source.	

[38] DB A/11A Hall 2 Workshop

267	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
268	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Circuit 5L1 open holes in lights where cables pass in/out of fittings.	
269	3	It has not been possible to carry out the following insulation tests: L-L where unable to remove loads.	
270		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible. IR due to loads in circuit.	

[39] IS DB A/10 Hall 2 Sub A Old Intake Room

271	3	There is no appropriate labelling for identification purposes in respect of the following: No 400V label.	
272	3	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Inaccurate circuit chart in place.	
273	FI	The Overcurrent devices installed within this item of equipment do not appear to be capable of withstanding the level of Prospective Fault Current recorded. kA value exceeds that of max permitted for device.	

[40] DB A/10 Hall 2 Workshop

274	2	The distribution circuit cable/conductor is not correctly terminated. No fly lead/banjo on incoming SWA to earth bar where cable sheath in use.	
275	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. No internal barriers after main switches as per design/age.	
276	3	Incoming terminal shield is made of flammable paper/cardboard.	
277	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	

[41] IS DB A/3 Hall 2 Sub A Old Intake Room

278	2	Earth Loop Impedance values were unsatisfactory. Overcurrent protection for outgoing circuit is provided by upstream fuses, 200A BS88 measured Zs of circuit 1L123 exceeds that of max permitted by protective device.	
279	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	

[42] DB A/3 Shop Store

280	2	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Multiple screws missing on grid switch & switch 24 appears unfixed, pushed into back box.	
-----	---	--	--

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
281	2	The Distribution equipment is sufficiently damaged / deteriorated so far as to impair safety. Main switch cover is loose and unfixed, includes mechanism.	
282	2	The distribution circuit cable/conductor is not correctly terminated. Circuit 16L2 - SWA not terminated into DB, just cut back and enters back of DB.	
283	2	The protective device for the distribution circuit does not appear to be appropriate. Circuit 16L3 - 6mm sub mains on 40A MCB.	
284	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 2L3 - 16A MCB for 1.5 lighting circuit.	
285	2	The method of terminating the final circuit conductor is unsuitable. Multiple joints in walls, no mechanical protection to through crimped joints & single insulated cables. Floating connectors & unterminated cables in wall.	
286	2	The termination / jointing of final circuit cables is unsatisfactory. 1.5mm T+E on L/H/S of DB, L+E cut short but neutral connected.	
287	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 1L3 obscure means of wiring lighting track where flex strung between fittings.	
288	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 9L1 ring main has been extended incorrectly, 2 x 2.5mm to switch L/H/S, 2 x 2.5mm to joint box in wall behind DB the 2 x 2.5mm jointed in tape behind DB to original ring cables.	
289	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 9L1 multiple spurs from sockets on G/F. Outside learning room and Warnfords cage.	
290	2	The condition of the electrical accessory is unsatisfactory. Circuit 1L3 open hole in lighting track on landing exposing live terminal.	
291	2	Earth Loop Impedance values were unsatisfactory. Circuits 2L2, 3L1, 9L2.	
292	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
293	3	Cable entry holes include no suitable protection (such as grommets or grommet strip) to avoid damage to the cable where they enter the equipment. No grommet protection where cables pass into trunking behind DB.	
294	3	Cable entry holes include no suitable protection (such as grommets or grommet strip) to avoid damage to the cable where they enter the equipment. No grommet protection where cables pass into switch boxes L/H/H of DB.	
295	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Open 32mm hole in switch box 25-48.	
296	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Circuit 9L1 screw missing from DP switch L/H/S of DB.	
297	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Sockets on circuits 9L1, 15L1, 2L2, 2L3.	
298	3	The termination / jointing of final circuit cables is unsatisfactory. Unterminated cores in DB, circuit 8L2 is old circuit disconnected, marked as short circuit.	
299	3	Single Insulated final circuit cables are not installed in an appropriate protective system such as conduit or trunking. Much of the trunking lids are missing in roof void above switch banks.	
300	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
301	FI	The termination / jointing of final circuit cables is unsatisfactory. Circuit 9L1 joint to original ring cables behind DB is inaccessible but appears to show T+E jointed to singles. MF outgoing earth so unknown connection of CPC in jointed twin & earth cables.	
302	FI	Despite reasonable investigation, some final circuits could not be traced. Switch has outgoing cable but unknown purpose. Circuits 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42. Emergency key switch zone 4.	
303	FI	Despite reasonable investigation, some final circuits could not be traced. Switches 33/34 are live from unknown supply, not of this DB.	
304	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 7L2 labelled incorrect and does not terminate into switches L/H/S.	
305	FI	Despite reasonable investigation, some final circuits could not be traced. Circuits 11L1, 11L3 via switches L/H/S labelled as not in use but outgoing cables.	
306		T+E from DB to switch bank outside of room.	
307		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	
308		Earth Loop Impedance values were unsatisfactory. Circuit 13L3 - Zs exceeds max permitted by device but RCBO is RCD used for fault protection.	

[43] DB A/18 Conference Store Room

309	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
310	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
311		DB is mounted on its side & cover door detaches when opened.	

[44] DB A/22 Finance

312	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
313	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Sockets on circuits 1L3, 2L3, 3L3.	
314	3	It has not been possible to carry out the following insulation tests: L-L where unable to remove loads.	

[45] DB A/23 General Managers Office

315	2	The Overcurrent device(s) (fuses/MCB's) protecting the final circuit(s) appear(s) to be of an incorrect rating. 4mm supply cable from switch is not down rated to 40A supply MCB at DB A/18 S36797.	
316	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
317	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. No internal barrier to busbar, as per design.	
318	3	Final circuit cable conductors/CPCs are not correctly colour coded/identified. No sleeving to CPCs in DB.	
319	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 1L3.	
320	3	It has not been possible to carry out the following insulation tests: L-L where unable to remove loads.	

[46] DB A/20 Learning Centre

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Item	Code	Description	Fixed
321	3	There is no six monthly test notice for RCD's.	
322		There is no CPC in the lighting circuit supplying only Class ii equipment and Accessories. Circuit 10L2, no CPC to light switches, cat II equipment.	

[47] DB A/19 Accounts

323	2	There is no appropriate labelling for identification purposes in respect of the following: Switch in from office has 2 supplies & should be labelled as such, circuits 3L3, 4L3.	
324	2	The IP rating of the enclosure is unsatisfactory. Large open holes on top surface of DB.	
325	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 3L3 connector blocks used to joint cable & left exposed - by window.	
326	2	The Ring circuit continuity is not satisfactory. Circuit 7L3, no ring continuity, possibly 2 x radials.	
327	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
328	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Unused SWA gland on top surface of DB.	
329	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Sockets on circuit 2L3.	
330	3	It has not been possible to carry out the following insulation tests: L-L where unable to remove loads.	
331	3	The Ring circuit continuity is not satisfactory. Circuit 2L3 CPC ring continuity appears high but acceptable reading.	
332	FI	Despite reasonable investigation, some final circuits could not be traced. 16mm CPC at DB, unknown purpose - possible incoming CPC or outgoing bond.	
333	FI	Despite reasonable investigation, some final circuits could not be traced. Circuits 1L3, 6L3.	
334	L	A restriction on isolation was imposed at the time of testing in the following areas. Circuit 3L3 tested at joint in room 4, bridge lights inaccessible, agreed with G. Kelly.	

[48] IS DB A/12 Hall 2 Sub A Old Intake Room

335	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
336	3	Due to the suspected presence of Asbestos containing materials (ACM's), it is recommended that an Asbestos warning label is fitted to this Switchgear. No labelling to indicate asbestos internally.	
337	FI	Due to the suspected presence of Asbestos containing materials (ACM's), it has not been possible to carry out all required inspection and testing on this switchgear. Asbestos flash guards internally.	
338	FI	Due to the suspected presence of Asbestos containing materials (ACM's), it has not been possible to remove fuses to confirm the identity of individual circuits. The test readings recorded are the most unfavourable from the total area assumed to be controlled from this item of equipment.	

[49] DB A/12 Hall 2 Switch Room (Main)

339	2	There is no appropriate labelling for identification purposes in respect of the following: No warning notice of exposed live parts internally, isolate upstream.	
340	2	The distribution circuit cable/conductor is not correctly terminated. No fly lead/banjo from incomer gland to earth bar where cable sheath in use.	
341	2	The method of terminating the final circuit cable into the enclosure is unsuitable. Circuit 4L123 TRS gland is required for flex outgoing of isolator.	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Item	Code	Description	Fixed
342	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 4L123 - integral CPC of flex used as neutral earth to sump pump isolator is 4mm taken from toilet DB.	
343	3	There is no notice warning of alternative/additional supplies.	
344	3	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas:	
345	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. No internal shields or barriers inside DB after main switch.	
346	3	Incoming terminal guard is made of flammable card/paper.	
347	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Sockets on circuits 1L3, 2L3, 1L2, 5L2.	
348	3	The termination / jointing of final circuit cables is unsatisfactory. Floating connectors & unterminated cores inside DB.	
349	3	It has not been possible to carry out the following insulation tests: L-L where unable to remove loads.	
350	FI	This item of switchgear has reached the end of its serviceable life due to its age / condition. It should be replaced with a modern equivalent to ensure the continued safe operation and use of the electrical installation. Age & condition of this item of equipment means replacement would be advised.	
351	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 5L1.	

[50] DB A/13 Staff WC Hall 2

352	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
353		Emergency lights in toilets appear to be supplies from different locations.	
354		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	

[51] DB 6 Shop Store

355	2	The Distribution equipment is sufficiently damaged / deteriorated so far as to impair safety. Circuit 11L1 MCB is damaged in DB.	
356	2	Earth Loop Impedance values were unsatisfactory. Circuit 3L1.	
357	3	There is no six monthly test notice for RCDs.	
358	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
359	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
360	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Sockets on circuits 5L1, 6L1, 10L2, 10L3, 9L3, 13L2, 4L3, 6L3, 15L2, 12L2, 4L1, 3L3.	
361	3	The termination / jointing of final circuit cables is unsatisfactory. Unterminated cores in panel, circuit 2L1 disconnected from MCB labelled shop control circuit.	
362	3	Despite reasonable investigation, some final circuits could not be traced. Circuit 3L3 unknown number of points where Anderson Shelter has been build inside room.	
363	3	Despite reasonable investigation, some final circuits could not be traced. Circuit 3L2 unable to confirm number of points in room due to shelving & stock.	
364	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
365	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 13L2 unknown 1.5mm with 2.5mm radial from MCB.	
366	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 9L1 contactor sand like its in the wall behind the DB, unable to access.	
367	FI	Despite reasonable investigation, some final circuits could not be traced. Circuits 10L1, 11L3, 16L1, 1L3, 8L3.	
368		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	
369		Earth Loop Impedance values were unsatisfactory. Circuit 6L2 RCBO used for fault protection.	
370		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 10L2 outside socket - Test Button = Pass, x 1 = 17.6ms, x 5 = 17.4ms, ½ = Pass.	

[52] Shop Till DB Shop

371 3 The Provision of diagrams, charts or schedules at or near equipment is inadequate.

[53] Sub B DB Carrier Flight Desk Short Corridor

372 2 There is no appropriate labelling for identification purposes in respect of the following: No labelling to indicate exposed live terminals, busbars inside panel.

373 2 The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. No IP protection on incoming & outgoing terminals in contactor enclosure, circuit 1L123, Sub C DB contactor enclosure circuit 20L123, BB T1 contactor enclosure circuit 21L123.

374 3 The Provision of diagrams, charts or schedules at or near equipment is inadequate.

375 3 The termination / jointing of final circuit cables is unsatisfactory. Unterminated control wiring inside contactor enclosures.

376 Sub C DB contactor circuit 20L123 is permanently linked out.

[54] DB B/4 Washing Up Area

377 2 The termination / jointing of final circuit cables is unsatisfactory. Circuit 3L123, 2.5mm SY Flex from isolator to oven not fused down (63A MCB) & SY Flex braid not earthed.

378 3 The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate/incomplete circuit chart & DB circuit labelling in place.

379 3 The termination / jointing of final circuit cables is unsatisfactory. Unterminated cores inside DB.

380 3 There is no CPC in the lighting circuit supplying only Class ii equipment and Accessories. Circuit 1L1 - no CPC to lights in rear area where wired in singles in plastic conduit, plastic switch accessories.

381 3 It has not been possible to carry out the following insulation tests: Unable to remove loads

382 16mm bond to water pipe below.

383 Supplementary bonding to pipework/metal appliance below, circuit 2L123 W/M near.

384 It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.

[55] DB B/3 Carrier Flight Deck Short Corridor

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
385	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
386	3	There is no appropriate labelling for identification purposes in respect of the following: Incorrect labelling of Ambi-rad isolators, circuits 1, 2, 4, 5 not 1L1, 1L2, 2L1, 2L2.	

[56] French Kit DB DB B/1

387	2	The method of terminating the final circuit cable into the enclosure is unsuitable. No earth fly lead to SWA connector where cable sheath in use, circuit 2L1.	
388	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
389	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No grommet protection where cables leave DB.	
390	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. No 30mA protection 3 sockets circuits 3L2.	
391	3	The termination / jointing of final circuit cables is unsatisfactory. Unused/unterminated cables in DB.	
392	3	The termination / jointing of final circuit cables is unsatisfactory. Floating connectors within DB.	
393	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
394		The protective device is showing signs of heat damage. Circuit 2L2 signs of heat damage to MCB.	Yes
395		Circuit 3L3 unknown point of connection of SWA, circuit tested at controller by fan.	
396		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	

[57] DB B/2 Sub B DB Chamber 19L123

397	3	The location of the isolating or switching device is inappropriate. Main isolator L/H/S of DB (1M).	
398	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate/incomplete circuit chart in place.	
399	3	The termination / jointing of final circuit cables is unsatisfactory. Spare cores in DB not earthed down,	
400	3	Single Insulated final circuit cables are not installed in an appropriate protective system such as conduit or trunking. Trunking lid missing above DB.	
401	3	It has not been possible to carry out the following insulation tests: Circuit 5L2 contactors & emergency lights.	
402	L	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Limitations on all circuits due to MEWP failure at the museum.	
403		Circuit 4L2 fans are switched at 6 gang switch bank R/H/S of DB.	

[58] BB T1 Hall 3 Service Corridor

404	FI	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Unable to access busbar tap offs to carry out IR tests & fuse ratings.	
-----	----	---	--

[59] DB B/6 Hall 3 Service Corridor

405	2	The Overcurrent device(s) (fuses/MCB's) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 4L123 2.5mm cable on 32A MCB.	
-----	---	---	--

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
406	2	The Ring circuit continuity is not satisfactory. Circuit 2L1 L-L high ring continuity result.	
407	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
408	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No grommet strip from cable entries to DB.	
409	3	3 x cables in MCB circuit 2L3.	
410	3	Single Insulated final circuit cables are not installed in an appropriate protective system such as conduit or trunking. Trunking lid missing near DB.	
411	3	It has not been possible to carry out the following insulation tests: All lighting circuits unable to disconnect loads.	
412	3	It has not been possible to carry out insulation tests LIVE to CPC due to the sensitivity of some of the electronic control gear in circuit. Unable to disconnect sensitive equipment.	
413	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 3L123.	

[60] DB B/9 Rear of Buccaneer

414	2	There is no appropriate labelling for identification purposes in respect of the following: No labelling to indicate live parts exposed inside DB, isolate before removing cover.	
415	2	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 2 x open 20mm hole on top surface of DB.	
416	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. DB blank missing from cover.	
417	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Large open square hole on top surface of DB.	
418	2	The integrity of the IP Rating (Ingress Protection) of the equipment has been compromised or is of an inappropriate rating for the environment. Open hole in bottom of DB where small flex passes into enclosure, circuit 2L1.	
419	2	Earth Loop Impedance values were unsatisfactory. Circuit 3L3.	
420	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
421	3	Due to the suspected presence of Asbestos containing materials (ACMs), it is recommended that an Asbestos warning label is fitted to this Switchgear. Circuit 3L2 T+E cable stripped back 3+ inches from point of entry on top surface of DB.	
422	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. All internal live parts are exposed.	
423	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. All sockets fed via this DB.	
424	3	The following final circuit(s) was found off, left off and not tested. Circuits 1L2, 2L2, 3L2, 3L3, 4L1 tested but left off.	
425	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
426	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 3L2 unidentified but found off & left off, sockets small pots.	
427		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
[61] DB5 Hall 2 Carrier Info Hall			
428	2	The presence and effectiveness of obstacles used to prevent unintentional contact with live parts is unsatisfactory. 20mm holes in DB.	
429	2	The condition of the electrical accessory is unsatisfactory. Circuit 3L2 20mm hole in wall socket.	
430	2	The equipment enclosure has been damaged/deteriorated. Circuit 3L3 broken light fitting.	
431	3	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Circuit 2L1 unable to access terminations but 12V fittings.	
432	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Missing grommet strip - cable entry.	
433	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 3L2 & 4L1.	
434	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
435	3	It has not been possible to carry out the following insulation tests: Unable to remove loads.	
436	FI	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Circuit 4L2 very hard to access.	
[62] DB Phantom DB B/8			
437	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 8L123.	
438	3	Final circuit cable conductors/CPCs are not correctly colour coded/identified. Circuit 1L123 not correct identification used.	
439	3	The termination / jointing of final circuit cables is unsatisfactory. Spare cores not earthed down in DB.	
440	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
441	3	Earth Loop Impedance values were unsatisfactory. Circuit 8L123 - within 100% values.	
442	FI	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Circuits 2L3, 3L123, 7L3, 6L3 - confined spaces.	
443	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 5L2.	
[63] DB B/7 Phantom Store Room			
444	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. 2 x hole bottom of DB.	
445	3	There is no notice warning of mixed wiring colours to two versions of BS7671. RCD under DB.	
446	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 1L1.	
447	3	It has not been possible to carry out the following insulation tests: Circuit 3L2.	
[64] Sub C DB Carrier Panel Board Room			
448	2	The Overcurrent device(s) (fuses/MCB's) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 9L123, 10mm SWA on 100A MCCB.	
449	3	Spare parts stored in bottom of DB.	
[65] DB C/1 Plane Workshop			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Item	Code	Description	Fixed
450	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 3L123.	
451	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 1L3 - 2 x radials (no ring wired).	
452	2	The condition of the electrical accessory is unsatisfactory. Circuit 1L3 L/H/S socket earth pin damaged.	
453	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Very vague descriptions.	
454	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
455	3	Final circuit cable conductors/CPCs are not correctly colour coded/identified. Circuits 2L123, 3L123 poorly coloured cores.	
456	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
457	3	It has not been possible to carry out the following insulation tests: Circuit 1L1.	

[66] DB C/1/6L1 Workshop Hangar

458	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 1 of 4 DB cover screws missing.	
-----	---	--	--

[67] DB C/2 Carrier Control Room

459	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 5L1.	
460	3	The termination / jointing of final circuit cables is unsatisfactory. Spare cores not earthed down in DB.	
461	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
462	3	Circuit 3L2 - unknown number of points.	
463	3	It has not been possible to carry out the following insulation tests: Circuits 3L3, 3L2, 2L1.	
464	FI	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Circuits 8L1, 1L3.	
465	FI	A restriction on isolation was imposed at the time of testing in the following areas. Circuit 6L3 labelling indicates 1 x point but wired in 2x2.5 possibly 2 x radials/unknown.	
466		The following final circuit(s) was found off, left off and not tested. Circuit 5L3.	

[69] DB C/16 Carrier Ground Floor Store

467	3	There is no Main Switch capable of Isolating the electrical supply. Switch/Isolator R/H/S of DB.	
468	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No grommet strip on cable entry.	
469	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 2L1, 5L2.	
470	FI	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Circuit 1L123.	
471	FI	Despite reasonable investigation, some final circuits could not be traced. Unidentified circuit 2L2.	

[70] DB C/15 Carrier Ground Floor Store

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
472	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 1L1.	
473	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 4L1 - 4 x cables in one MCB.	
474	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 4L1 - slight loose connection on light 1st floor.	
475	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
476	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No grommet strip on cable entries.	
477	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 1L1.	
478	3	Single Insulated final circuit cables are not installed in an appropriate protective system such as conduit or trunking. Trunking lid missing R/H/S of DB.	
479	3	It has not been possible to carry out the following insulation tests: Circuits 1L3, 4L1, 4L2, 5L1, 5L2, 6L1, 6L2.	
480		Circuit 1L1 - used same continuity results as per guidance note 3.	

[71] DB C/17 Lift Room Deck 1

481	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Circuit schedule incorrectly written.	
482	3	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Circuit 4L2 - no access to terminations to test, tested to spur.	
483	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 2L2.	
484	3	It has not been possible to carry out the following insulation tests: Circuits 4L2, 3L2.	

[72] DB C/19 Carrier G/F Store

485	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 5L3, 1mm flex on 16A MCB.	
486	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
487	3	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Circuit 5L3 - LED wall light, no access behind wall to inspect circuit.	
488	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuits 4L3, 3L3, 2L3, 1L3.	
489	3	The equipment is insecurely fixed. Where sockets in use, these are not fixed above display fixtures, circuits 4L3, 3L3, 2L3, 1L3.	
490	3	It has not been possible to carry out the following insulation tests: Where unable to remove loads.	
491		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	

[73] DB C/27 Carrier Panel R/H/S

492	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
493	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 1L3.	
494	3	It has not been possible to carry out the following insulation tests: Unable to remove loads.	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Item	Code	Description	Fixed
[74] DB C/20 ISO Non Maintained Isolator			
495	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
[75] DB C/20 Carrier Service Room 2			
496	3	The following final circuit(s) was found off, left off and not tested. Circuits 1L123, 4L1.	
497	3	It has not been possible to carry out the following insulation tests: L-L, L-E on all lighting, circuits found off, not tested.	
[76] DB C/21 Carrier Service Cupboard 2			
498	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Missing grommet strip on cable entry.	
499	3	Single Insulated final circuit cables are not installed in an appropriate protective system such as conduit or trunking. Missing trunking lid under DB.	
500	3	It has not been possible to carry out the following insulation tests: Unable to remove loads.	
501	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 2L2.	
502		Circuit 1L1 used previous continuity reading as per guidance note 3.	
[77] DB C/5 Decbridge Lift Motor Room			
503	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 2L123.	
504	2	Circuits or accessories which supply or have the potential to supply mobile equipment outdoors are not protected by a 30mA RCD . Circuit 1L3 possibility to supply outdoor equipment.	
505	2	Appropriate means of isolation for the equipment is either absent or in poor condition. Circuit 7L123 hole in bottom of isolator 2.5mm.	
506	3	Circuit 2L123, 3 phase breaker feeds 3 single phase DBs.	
507	3	The equipment is insecurely fixed. Circuit 7L123 isolator loose fixing to wall.	
508	3	It has not been possible to carry out the following insulation tests: Circuit 1L1, 1L2.	
[78] DB C/18 Carrier Ground Floor Store			
509	3	Cable entry holes include no suitable protection (such as grommets or grommet strip) to avoid damage to the cable where they enter the equipment. No grommet strip around cable entries in top of DB.	
510	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
511	3	It has not been possible to carry out the following insulation tests: L-N lighting.	
512	3	It has not been possible to carry out insulation tests LIVE to CPC due to the sensitivity of some of the electronic control gear in circuit. L-E lighting.	
[79] DB C/22 Carrier Service Cupboard 2			
513	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No grommet strip on cable entry.	
514	3	It has not been possible to carry out the following insulation tests: Unable to remove loads.	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Item	Code	Description	Fixed
[80] Safety Lighting DB DB C/26			
515	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
516	3	It has not been possible to carry out the following insulation tests: Unable to remove loads.	
[81] DB C/14 Old Soft Frame Room			
517	2	The IP rating of the enclosure is unsatisfactory. 20mm hole - bottom of DB.	
518	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 2L3.	
519	3	It has not been possible to carry out the following insulation tests: Circuits 3L3 & 4L3.	
[83] DB C/23 Carrier Service Room 3			
520	2	The location of the isolating or switching device is inappropriate. No DB main switch in panel.	
521	2	Earth Loop Impedance values were unsatisfactory. Circuit 11L2.	
522	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Schedule not up to date.	
523	3	Cable entry holes include no suitable protection (such as grommets or grommet strip) to avoid damage to the cable where they enter the equipment. No grommet strip for cable entries to DB.	
524	3	The termination / jointing of final circuit cables is unsatisfactory. Spare cores in DB.	
525	3	The following final circuit(s) was found off, left off and not tested. Circuit 1L123.	
526	3	Circuit 3L123 no neutral at fan.	
527	3	It has not been possible to carry out the following insulation tests: Lighting & unidentified circuits.	
528	FI	Despite reasonable investigation, some final circuits could not be traced. Circuits 6L123, 10L123, 13L3, 16L1, 7L123, 14L2, 11L1, 15L2.	
529	L	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Circuit 2L123.	
530		Ring continuity readings used from previous test, no visual changes as per Guidance Note 3.	
[84] DB C/24 Carrier Service Room 3			
531	2	It was not possible to measure the following earth fault loop impedances: Circuit 5L3, 2 core flex supply no earth core.	
532	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No grommet strip for cable entries to DB.	
533	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
534	3	It has not been possible to carry out the following insulation tests: All lighting, unable to disconnect loads.	
535	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 7L1, 8L1.	
[85] DB C/25 Carrier Service Cupboard 3			
536	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Missing grommet strip around cable entry.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
537	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 2L2.	
538	3	The termination / jointing of final circuit cables is unsatisfactory. Spare cores in DB not earthed down.	
539	3	Circuit 1L1 - unable to obtain number of points on circuit.	
540	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 3L2, 1 of 2 cables.	
541	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 4L1.	
542		The following final circuit(s) was found off, left off and not tested. Circuit 4L3, 4L2.	

[86] DB C/8 Warnfords Restaurant

543	2	The method of terminating the distribution circuit conductors is unsuitable. Circuit 3L3, 3 x cables in MCB.	
544	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
545	3	Cable entry holes include no suitable protection (such as grommets or grommet strip) to avoid damage to the cable where they enter the equipment. No grommet strip for cable entries to DB.	
546	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. DB cover blank missing.	
547	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuits 2L3, 1L3, 3L2 lighting.	
548	3	Final circuit cables are not double insulated where entering the enclosure. Circuit 2L1 single layer PVC where connections have been made into downlights.	
549	3	It has not been possible to carry out the following insulation tests: Circuits 1L1, 3L3, 2L1.	
550		Circuit 3L2 no changes to circuit ring continuity used from previous report as per guidance note 3.	

[87] DB C/9 Leander Corridor

551	2	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 2 of 4 DB cover screws missing.	
552	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
553	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Sockets on circuits 5L1, 6L2, 10L3, 11L2, 12L2.	
554	3	The termination / jointing of final circuit cables is unsatisfactory. Floating connections within DB.	
555	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
556	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
557		Circuit 12L3 unknown joint in cable, 10mm T+E at this DB, 10mm PVC/PVC at DB C/13.	

[88] DB C/13 Leander Suite Office 27

558	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
-----	---	--	--

[89] DB C/10 Carrier Service Cupboard 3

559	2	The IP rating of the enclosure is unsatisfactory. Holes in top of DB covered by tape.	
560	3	There is no notice warning of mixed wiring colours to two versions of BS7671.	
561	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 1 of 4 DB cover screws missing.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
562	FI	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Limitations on all circuits.	

[90] DB C/28 Carrier Experience Office

563	3	It has not been possible to carry out the following insulation tests: Circuit 7L3.	
564	3	It has not been possible to carry out insulation tests LIVE to CPC due to the sensitivity of some of the electronic control gear in circuit. Circuit 7L3.	
565	L	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Circuit 5L3.	

[92] DB C/12 Carrier Service Cupboard 3

566	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering. Circuit 4L1.	
567	3	It has not been possible to carry out the following insulation tests: Unable to remove loads.	
568	3	It has not been possible to carry out insulation tests LIVE to CPC due to the sensitivity of some of the electronic control gear in circuit.	

[93] DB 8 Shop Store

569	2	The method of terminating the distribution circuit conductors is unsuitable. Circuit 7L2 SWA not terminated into gland but stripped and taped back.	
570	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
571	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 1 of 4 cover screws missing.	
572	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Circuit 1-4L123 rotary switch screw is missing on isolators.	
573	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Circuit 1L123 isolator cover screw missing.	
574	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. 1 of 2 neutral bar shields missing.	
575	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 7L1 unable to locate/access for damper.	

[94] DB 11 Lift Room

576	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. 25mm bush for 2.5mm T+E on top surface of DB, leaves open hole.	
577	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Blank missing on DB cover.	
578	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
579	3	Single Insulated final circuit cables are not installed in an appropriate protective system such as conduit or trunking. Conduit box lid missing where cables pass to lift shaft.	
580	FI	Despite reasonable investigation, some final circuits could not be traced. Circuits tested at local switches only, no access to lift shaft.	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Item	Code	Description	Fixed
581	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit chart/labelling does not appear to match local switch labels.	

[95] DB G/1 Hall 1 Adjacent Sea King

582	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Open 25mm hole on bottom of DB x 2.	
583	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Incomplete/inaccurate circuit chart.	
584	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. 2 of 4 screws missing to DB cover.	
585	3	The fire rating of the enclosure is inadequate. Wood cupboard has been used to cover open holes in bottom of DB.	
586	3	Final circuit cable conductors/CPCs are not correctly colour coded/identified. Circuit 7L123.	
587	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
588	FI	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Circuit 7L123, included in report for continuity, unused MCB should be removed if not required. Open hole in bottom of MCB enclosure, 1 of 4 screws missing.	
589	FI	Unable to obtain amp rating of MCB as information worn away, circuits 1L1, 2L1, 3L1.	
590	FI	Without max Zs information & fault protection allowing 1667 ohms.	
591	L	The high level installation above 3m has been excluded from the condition Report and has not been inspected and tested in line with Guidance Note Three and the Report has been compiled accordingly. Circuit 3L1 unable to access high level socket.	

[96] DB G/2 Plant Room 3

592	2	The distribution circuit cable/conductor is not correctly terminated. No earthing ring/fly lead to SWA where cable sheath in use, circuit 1L123, 3L123.	
593	2	Earth Loop Impedance values were unsatisfactory. Circuit 1L123, 2L123.	
594	3	The following extraneous conductive metallic parts are not suitably bonded. 16mm bond to steelwork is not continuous, terminated via gas bond clamp.	
595	3	There is no six monthly test notice for RCDs.	
596	3	There is no appropriate labelling for identification purposes in respect of the following: Labelling to indicate 400V is required.	
597	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
598		16mm bond to gas & steelwork L/H/S of DB.	
599		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 4L2 RCD socket - ½ = Pass, x 1 = 28.3ms, x 5 = 18.5ms, Test Button = Pass.	
600		Circuit 4L1 - tested to light switch only.	

[97] DB G/4 Hall 1 Sea King Exhibition

601	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Blank missing on DB & no shroud on 1 x unused busbar way inside DB.	
-----	---	---	--

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
602	2	The insulation of the final circuit cable/accessory is showing signs of damage. Circuit 2L3 insulation damaged on neutral conductor in socket on pillar.	
603	2	The integrity of the IP Rating (Ingress Protection) of the equipment has been compromised or is of an inappropriate rating for the environment. Circuit 3L3 socket by DB T+E passes through 20mm hole on top of socket box.	
604	2	The integrity of the IP Rating (Ingress Protection) of the equipment has been compromised or is of an inappropriate rating for the environment. Circuit 2L3, 20mm open hole on top surface of socket on pillar far wall.	
605	3	There is no six monthly test notice for RCDs.	
606	3	The current carrying capacity of the final circuit cable does not appear adequate for the potential load. Circuit 3L3 camera 1.5mm T+E wired out of socket is on 16A MCB & not fixed.	
607	3	Final circuit cables are not double insulated where entering the enclosure. T+E cable entering top of DB has outer sheath stripped back.	
608	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
609	L	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Circuit 3L3 circuit tested at socket, camera inaccessible at high level.	

[98] DB G/3 Plant Room 2

610	2	The distribution circuit cable/conductor is not correctly terminated. Earthing ring/fly leads missing to SWA where cable sheath is in use, circuits 1L3, 3L123, 4L123.	
611	2	Earth Loop Impedance values were unsatisfactory. Circuits 3L123, 4L123.	
612	3	The following extraneous conductive metallic parts are not suitably bonded. Bonding to gas is not continuous where connected via steelwork bond below DB.	
613	3	There is no six monthly test notice for RCDs.	
614	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
615	3	The following final circuit(s) was found off, left off and not tested. Circuit 4L123.	
616	FI	A restriction of access was imposed so it was not possible to gain access to Inspect and Test the following areas: Inaccurate circuit chart.	
617		25mm bonds to local steelwork & gas pipe.	
618		25mm incoming earth is from hall 2 main isolator, S36757.	
619		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 1L1 RCD socket - ½ = Pass, x 1 = 29.3ms, x 5 = 18.4ms, Test Button = Pass.	

[99] E/ISO 1 O/S Workshop Door

620	2	The main earthing terminal for the installation is unsatisfactory. No earth fly leads in joint box below & this switch where downstream bonding present.	
621	2	Due to the suspected presence of Asbestos containing materials (ACMs), it is recommended that an Asbestos warning label is fitted to this Switchgear. Asbestos flash guards inside, no labelling of this.	
622	2	The Distribution equipment is sufficiently damaged / deteriorated so far as to impair safety. Lid has 1 of 2 fixings missing & the 1 remaining is corroded and does not go into place.	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Item	Code	Description	Fixed
623	2	The equipment enclosure has been damaged/deteriorated. Outgoing cable is jointed in enclosure to the left of this equipment, enclosure is severely corroded.	
624	3	The IP rating of the enclosure is unsatisfactory. Surface corrosion to enclosure.	

[100] Sub E/BB Workshop

625	2	The main earthing terminal for the installation is unsatisfactory. Main frame earth used where downstream bonding present, no fly lead within enclosure.	
626	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. No IP2X protection or labelling to indicate this.	
627	3	Final circuit cable conductors/CPCs are not correctly colour coded/identified. Circuit 3L123, L2 phase identified with green & yellow tape.	
628		Overcurrent protection for final circuits provide by upstream BS3036 100A fuses.	

[101] IS DB/E/1 Workshop Intake

629	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Open/unused gland on L/H/S of enclosure.	
630	2	Earth Loop Impedance values were unsatisfactory. Circuit 1L123.	
631	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
632	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. Incoming terminals are non IP2X, supply side of switch by design.	
633	3	The mechanical protection of all or part of the distribution circuit Conductor is missing. Trunking lid above equipment is lifting & does not fix into position.	

[102] DB E/1 Workshop Intake

634	2	Part of the insulation or barriers to prevent access to live parts is missing /insecure. Circuit 1L123 only 1 of 2 fixing to light spur above stop/start.	
635	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuit 1L123, 32A supply to stop/start control but control circuit wiring & singles to light spur wired in 1mm & not fused down including 240V emergency stop button circuit.	
636	2	The method of terminating the final circuit cable into the enclosure is unsuitable. Circuit 1L123 SWA not glanded in trunking above DB.	
637	2	The method of terminating the final circuit cable into the enclosure is unsuitable. Circuit 1L123 no integral CPC to SWA in circuit, 6mm separate single to equipment armoured earthed only by stop start enclosure metal box.	
638	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
639	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. Various exposed live parts inside DB.	
640	3	Final circuit cable conductors/CPCs are not correctly colour coded/identified. Circuit 4L123 connected at MCB yellow/red/blue.	

Occupier **Fleet Air Arm Museum**
Installation Address **Main Museum, RNAS Yeovilton**
Specific Location **Not Applicable**

Item	Code	Description	Fixed
641	3	Final circuit cables are not sufficiently fixed or supported causing undue strain being placed on the cable, existing fixings or supports and/or terminations. Circuit 4L123 SWA is unfixed between trunking below DB & drill mounted isolator.	
642	FI	The Final circuit is not in use and should be removed to simplify the installation. Multiple cables, connector blocks in DB, not live with board or not labelled for purpose, cables should be removed if not required or labelled.	
643		The protective device for fault protection of the final circuit does not appear to be appropriate. Circuit 3L123 is 3 phases to meter on 3 x single phase MCBs.	

[103] DB E/2 Isoaltor Workshop Intake

644	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
645	3	Final circuit cable conductors/CPCs are not correctly colour coded/identified. Incoming L2 phase labelled with green & yellow tape.	
646	3	It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible. Unable to remove loads in circuit due to asbestos in DB E/2 & equipment in unswitched.	
647	FI	Due to the suspected presence of Asbestos containing materials (ACMs), it has not been possible to carry out all required inspection and testing on this switchgear. Unable to access equipment on 1L123 to test due to asbestos.	

[104] DB E/2 Workshop Intake

648	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
649	FI	Due to the suspected presence of Asbestos containing materials (ACMs), it has not been possible to carry out all required inspection and testing on this switchgear. Unable to access due to asbestos inside.	
650		Equipment & all circuits excluded from test due to asbestos inside DB.	

[105] IS DB E/3/4 Workshop Intake

651	2	The following extraneous conductive metallic parts are not suitably bonded. Multiple earths on bolt in bottom of switch fuse, bolt is loose.	
652	2	The method of terminating the distribution circuit conductors is unsuitable. Exposed copper on incoming L2 terminal.	
653	2	The Overcurrent device(s) (fuses/MCBs) protecting the final circuit(s) appear(s) to be of an incorrect rating. Circuits 1L123, 1L1, 10mm on 100A.	
654	2	Earth Loop Impedance values were unsatisfactory. Circuits 1L123, 1L1.	
655	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	

[106] DB E/3 Workshop Intake

656	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
657	3	Circuit 2L1 unorthodox method of wiring, flex for entire circuit.	
658	3	Appropriate means of isolation for the equipment is either absent or in poor condition. No local isolation for high level gas heater circuit 2L1.	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Item	Code	Description	Fixed
[107] DB E/4 Central Workshop			
659	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 4L1 braid of SY Flex not earthed.	
660	2	The integrity of the IP Rating (Ingress Protection) of the equipment has been compromised or is of an inappropriate rating for the environment. Circuit 1L3, 1 of 4 lights has cover missing exposing internal live parts.	
661	2	The equipment is insecurely fixed. Circuit 4L3, 2nd light L/H/S appears to be fixed to part of a collapsing ceiling tile.	
662	2	The equipment is insecurely fixed. Circuit 3L3 sockets are hung from ceiling over bench from chain & unfixed.	
663	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
664	3	There is no appropriate labelling for identification purposes in respect of the following: The stickers warning of 2 colours in installation & RCD test notice on the cover of the DB are torn & should be replaced.	
665	3	Single Insulated final circuit cables are not installed in an appropriate protective system such as conduit or trunking. No containment for single core cables pressing down to light switch below DB.	
666	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
667	3	Earth Loop Impedance values were unsatisfactory. Circuit 6L123 main switch RCD being used as fault protection allowing 1667 ohms.	
668		Circuit 1L1 MCB slider in off position, Zs measured then left off.	
[108] DB E/4/2B Generator Outside Workshop			
669	2	Earth Loop Impedance values were unsatisfactory. Circuit 6L3.	
670	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
671	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. Exposed internal live parts.	
672	3	The method of terminating the final circuit cable into the enclosure is unsuitable. No fly lead to supply cable banjo.	
673	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 4L3.	
674		This Item of switchgear has reached the end of its serviceable life due to its age / condition. It should be replaced with a modern equivalent to ensure the continued safe operation and use of the electrical installation. Main switch RCD downstream from board RCD.	
[109] DB E/5 Central Workshop			
675	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
676		The distribution circuit is not in use and should be removed to simplify the installation. This equipment & supply.	
677		5 x MCBs of 5 x manufacturers.	
[110] IS DB/E/6 Workshop Intake			
678	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. No IP protection on incoming terminals straight from busbar.	

Occupier **Fleet Air Arm Museum**
Installation Address **Main Museum, RNAS Yeovilton**
Specific Location **Not Applicable**

Item	Code	Description	Fixed
679	2	Earth Loop Impedance values were unsatisfactory. Circuit 1L123.	
680	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate. Inaccurate circuit chart in place.	
681	3	This item of equipment does not afford a minimum standard of IP2X protection once opened. No IP protection on outgoing terminals.	

[111] DB E/6 Swordfish Centre Electrical Cupboard

682	2	The condition of the electrical accessory is unsatisfactory. Circuit 1L2 sockets on plastic boxed walls are insecurely fixed.	
683	2	The condition of the electrical accessory is unsatisfactory. Circuit 1L2 - socket in adaptable box by dishwasher sink & box is broken.	
684	2	The condition of the electrical accessory is unsatisfactory. Circuit 6L2 broken double socket outlet in box 4.	
685	2	Circuit protective conductors (fly leads) are missing from the accessory/fitting. Circuit 6L2 on all 4 floor boxed, earth fly leads, 5 lids are broken, not connected to covers.	
686	2	The integrity of the IP Rating (Ingress Protection) of the equipment has been compromised or is of an inappropriate rating for the environment. Circuit 6L2 socket box No. 3 has evidence of spilled liquid causing corrosion to faceplates.	
687	2	Earth Loop Impedance values were unsatisfactory. Circuits 1L2, 5L123.	
688	2	The Ring circuit continuity is not satisfactory. Circuit 1L2 - no ring continuity found.	
689	2	The Ring circuit continuity is not satisfactory. Circuit 6L2 no ring continuity on 32A circuit.	
690	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
691	3	The necessary data for the protection device was unavailable, therefore it is not possible to confirm the required disconnection times will be achieved. Circuit 5L123 generic data used providing max Zs of 0.116 ohms.	
692	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Sockets on circuits 1L2, 1L3, 8L3, 6L1, 6L2, 7L1, 7L2, 7L3, 8L1.	
693	3	The termination / jointing of final circuit cables is unsatisfactory. Excessive copper showing on MCB terminals circuits 4L123, 5L123.	
694	3	The termination / jointing of final circuit cables is unsatisfactory. Unterminated cores floating in panel.	
695	3	The termination / jointing of final circuit cables is unsatisfactory. Floating connectors in DB.	
696	3	The position of the electrical accessory is unsatisfactory. Circuit 6L2 - box 2 has socket mounted wrong way around so cannot be plugged into.	
697	3	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Circuit 8L1 unable to access CCTV sockets for testing, above high level ceiling.	
698	3	It has not been possible to carry out the following insulation tests: L-L where unable to disconnect boards.	
699	FI	The Final circuit is not in use and should be removed to simplify the installation. Numerous cables hanging in cupboard around DBs unterminated & assumed redundant, these cables should be removed from DB area.	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
700		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	

[112] DB E/8 Swordfish Centre Electrical Cupboard

701	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
702	3	The following final circuit(s) was found off, left off and not tested. Circuit 12L1 found off so has been left off.	
703	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
704	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 4L1.	
705	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 12L1.	
706	FI	Despite reasonable investigation, some final circuits could not be traced. Circuit 3L1 previous ring continuity but no continuity found, 1 point labelled on circuit, 2 x T+E at MCB.	
707		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	

[113] DB E/7 Swordfish Centre Electric Cupboard

708	2	There is no appropriate labelling for identification purposes in respect of the following: 400V & multiple supplies at switches & not indicated/labelled as such.	
709	2	The equipment enclosure or internal barrier is unsatisfactory making access to live parts possible. Large open hole in top surface of DB.	
710	2	The termination / jointing of final circuit cables is unsatisfactory. Circuit 2L2 unknown joint in cable as 1.5mm flex at switch in kitchen, assumed to be above ceiling.	
711	2	Earth Loop Impedance values were unsatisfactory. Circuits 2L2, 2L3, 5L1.	
712	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
713	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. No 30mA protection of sockets on circuits 7L3, 8L1.	
714	3	The termination / jointing of final circuit cables is unsatisfactory. Unterminated cores, floating connectors inside DB.	
715	3	The termination / jointing of final circuit cables is unsatisfactory. Circuit 6L3 downlighters are connected above ceiling with connector blocks leaving single insulated T+E cores exposed.	
716	3	Although included in the scope, it has not been possible to gain access to the following areas of the high level installation and the Report has been compiled accordingly. Circuit 2L1 unable to access winch supply outside, above 3 Mtrs.	
717	3	The Final circuit is not in use and should be removed to simplify the installation. Circuit 8L3 RCD above is obstructed by cables/trunking above DB, used & could be removed.	
718		Circuits 5L1, 5L2, 5L3 are Square D MCBs.	
719		Despite reasonable investigation, some final circuits could not be traced. Circuits 7L3, 8L1 circuits appear to be radials doing sockets above ceilings, lights plugged into sockets above stage area, unknown number of points in circuits.	
720		There is no CPC in the lighting circuit supplying only Class II equipment and Accessories. Circuit 8L2, no CPC to class II equipment (downlights).	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Item	Code	Description	Fixed
721		There was an accessory with an integral RCD. The location and test results are as follows: Circuit 8L3 RCD above - ½ = Pass, x 1 = 8.9ms, x 5 = 5.5ms, Test Button = Pass.	
[114] DB E/9 Room 221			
722	2	Earth Loop Impedance values were unsatisfactory. Circuit 4L3.	
723	3	The Provision of diagrams, charts or schedules at or near equipment is inadequate.	
724	3	Part of the insulation or barriers to prevent access to live parts is missing /insecure. No neutral bar shield as per design.	
725	3	Distribution circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
726	3	The distribution circuit is not in use and should be removed to simplify the installation. Unused circuit disconnected in DB requires removal.	
727	3	Socket outlets rated up to 32A are not protected by a 30mA RCD. Circuit 4L3.	
728	3	Final circuit cable conductors are not identifiable by an acceptable method of numbering or lettering.	
729	3	The integrity of the IP Rating (Ingress Protection) of the equipment has been compromised or is of an inappropriate rating for the environment. Unused conduit box of L/H/S of DB with open 20mm unused gland.	
730	3	It has not been possible to carry out the following insulation tests: L-L where equipment in circuit.	
731		It is suspected that the low insulation resistance readings obtained are due to equipment still connected to the circuit conductors. Isolation of this equipment has not been possible.	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Equipment Report No.	Name	Asset No.	Location	Fed from
[1]	Main Intake Panel	E43751	Hall 2 Switch Room	Origin of Supply
[2]	DB F/ISO	S36840	Swordfish Kitchen Intake	[1] Main Intake Panel
[3]	DB/F/BB	S36841	Swordfish Kitchen Intake	[2] DB F/ISO
[4]	DB F/1	S36842	Swordfish Kitchen Intake	[3] DB/F/BB
[5]	DB F/3	B44045	Swordfish Centre Electrical Cupboard	[4] DB F/1
[6]	DB F/9	S36844	Dry Store	[4] DB F/1
[7]	DB F/5	S36869	Servery Café	[4] DB F/1
[8]	DB F/2	S36843	Swordfish Café	[3] DB/F/BB
[9]	DB D/A	S36799	Hall 4 Adjacent Concorde	[1] Main Intake Panel
[10]	DB D/D	S36832	Concorde Rear Door	[9] DB D/A
[11]	DB D/F (Toilet DB)	S36812	Concorde Hall Toilets	[9] DB D/A
[12]	DB D/E	S36802	Hall 4 Concorde	[9] DB D/A
[13]	DB D/D	S36800	Hall 4 Concorde	[9] DB D/A
[14]	DB D/C	S36801	Hall 4 Concorde	[9] DB D/A
[15]	Sub A ISO 1	S36757	Hall 2	[1] Main Intake Panel
[16]	Sub A /BB	S36758	Hall 2 Sub A Old Intake Room	[15] Sub A ISO 1 via C/O Switch
[17]	IS DB A/4	S36759	Hall 2 Sub A Old Intake Room	[16] DB/F/BB
[18]	DB A/4	S36791	1st Floor Merlin Exhibition	[17] IS DB A/4
[19]	IS DB/A/1 & 2	S36760	Hall 2 Sub A Old Intake Room	[16] DB/F/BB
[20]	DB A/1	S36824	Hall 2 Sub A Old Intake Room	[19] IS DB/A/1 & 2
[21]	DB A/15	S36815	Conservation Room Hall 2	[20] DB A/1
[22]	DB A/17	S36811	Carrier Exhibition Korea End	[20] DB A/1
[23]	DB A/14/RCD	T44664	Hall 2 Sub A Old Intake Room	[20] DB A/1
[24]	DB A/14	T44663	Wrens Gallery Cupboard	[23] DB A/14/RCD via AFDD
[25]	SF/DB A/2	S36822	SKUA Exhibition Cupboard	[19] IS DB/A/1 & 2 via S36824
[26]	DB A/2	S36823	SKUA Stairway	[25] SF/DB A/2
[27]	IS DB/A/5 & 7	S36761	Hall 2 Sub A Old Intake Room	[16] DB/F/BB
[28]	DB A/7	S36789	Hall 2 Store Room	[27] IS DB/A/5 & 7
[29]	DB A/16	T44667	Top of U Boat Submarine	[28] DB A/7
[30]	152 DB A/5	S36790	Hall 2 Store Room	[27] IS DB/A/5 & 7 via S36789
[31]	DB A/5	S36796	Library Office	[30] 152 DB A/5
[32]	DB A/6	S36767	Hall 2 Sub A Old Intake Room	[16] Sub A /BB
[33]	IS DB A/8 & 9	S36762	Hall 2 Sub A Old Intake Room	[16] Sub A /BB

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Equipment Report No.	Name	Asset No.	Location	Fed from
[34]	DB A/8	S36768	Hall 2 Workshop	[33] Workshop DB1-1 1-2 Isolator via Meter R/H/S
[35]	DB A/9	S36769	Hall 2 Workshop	[33] Workshop DB1-1 1-2 Isolator via DB A/8 M/Switch
[36]	IS DB A/11	S36763	Hall 2 Sub A Old Intake Room	[16] DB/F/BB
[37]	DB A/11	S36771	Hall 2 Workshop	[36] IS DB A/11
[38]	DB A/11A	T44670	Hall 2 Workshop	[37] DB A/11
[39]	IS DB A/10	S36766	Hall 2 Sub A Old Intake Room	[16] DB/F/BB
[40]	DB A/10	S36770	Hall 2 Workshop	[39] IS DB A/10
[41]	IS DB A/3	S36764	Hall 2 Sub A Old Intake Room	[16] Sub A /BB
[42]	DB A/3	S36820	Shop Store	[41] IS DB A/3
[43]	DB A/18	S36797	Conference Store Room	[42] DB A/3 via ISO R/H/S
[44]	DB A/22	T44666	Finance	[43] DB A/18
[45]	DB A/23	T44665	General Managers Office	[43] DB A/18 via MS Below T44666
[46]	DB A/20	S36838	Learning Centre	[42] DB A/3
[47]	DB A/19	T44669	Accounts	[42] DB A/3
[48]	IS DB A/12	S36765	Hall 2 Sub A Old Intake Room	[16] Sub A /BB
[49]	DB A/12	T44638	Hall 2 Switch Room (Main)	[48] IS DB A/12
[50]	DB A/13	S36795	Staff WC Hall 2	[49] DB A/12
[51]	DB 6	S36819	Shop Store	[1] Main Intake Panel
[52]	Shop Till DB	T44687	Shop	[51] DB 6
[53]	Sub B DB	T44659	Carrier Flight Desk Short Corridor	[1] Main Intake Panel
[54]	DB B/4	T44660	Washing Up Area	[53] Sub B DB
[55]	DB B/3	T44661	Carrier Flight Deck Short Corridor	[53] Sub B DB
[56]	French Kit DB	S36816	DB B/1	[53] Sub B DB
[57]	DB B/2	T44662	Sub B DB Chamber 19L123	[53] Sub B DB
[58]	BB T1	A47207	Hall 3 Service Corridor	[53] Sub B DB
[59]	DB B/6	A47212	Hall 3 Service Corridor	[58] BB T1
[60]	DB B/9	B44033	Rear of Buccaneer	[58] BB T1
[61]	DB5	S36792	Hall 2 Carrier Info Hall	[58] BB T1
[62]	DB Phantom	S36814	DB B/8	[58] BB T1
[63]	DB B/7	S36813	Phantom Store Room	[58] BB T1
[64]	Sub C DB	S36805	Carrier Panel Board Room	[53] Sub B DB via 20L123 Contactr

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**


Equipment Report No.	Name	Asset No.	Location	Fed from
[65]	DB C/1	A47205	Plane Workshop	[64] Sub C DB
[66]	DB C/1/6L1	A47210	Workshop Hangar	[65] DB C/1
[67]	DB C/2	A47206	Carrier Control Room	[64] Sub C DB
[68]	DB C/16 ISO	S36774	Carrier Ground Floor Store	[64] Carrier Panel Board Sub C DB
[69]	DB C/16	S36775	Carrier Ground Floor Store	[68] DB C/16 ISO via Contactor
[70]	DB C/15	S36772	Carrier Ground Floor Store	[74] LiveSide DB C/20 ISO
[71]	DB C/17	A47204	Lift Room Deck 1	[70] DB C/15
[72]	DB C/19	B44034	Carrier G/F Store	[70] DB C/15 via Contactor Below
[73]	DB C/27	S36806	Carrier Panel R/H/S	[70] DB C/15 via Contactor
[74]	DB C/20 ISO	S36777	Non Maintained Isolator	[64] Carrier Panel Board Sub C DB
[75]	DB C/20	S36778	Carrier Service Room 2	[74] DB C/20 ISO
[76]	DB C/21	S36779	Carrier Service Cupboard 2	[64] Carrier Panel Board Sub C DB via S36777 LiveSide
[77]	DB C/5	A47202	Decbridge Lift Motor Room	[64] Sub C DB
[78]	DB C/18	S36776	Carrier Ground Floor Store	[77] DB C/5 via Contactor
[79]	DB C/22	S36780	Carrier Service Cupboard 2	[77] DB C/5 via Contactor
[80]	Safety Lighting DB	S36785	DB C/26	[77] DB C/5 via Contactor
[81]	DB C/14	A47203	Old Soft Frame Room	[77] DB C/5
[82]	DB C/23 ISO	S36781	Carrier Service Room 3	[64] Carrier Panel Board Sub C DB
[83]	DB C/23	S36782	Carrier Service Room 3	[82] DB C/20 ISO via Contactor
[84]	DB C/24	S36783	Carrier Service Room 3	[82] DB C/20 ISO
[85]	DB C/25	S36784	Carrier Service Cupboard 3	[64] Sub C DB via Liveside S36781
[86]	DB C/8	S36868	Warnfords Restaurant	[64] Sub C DB
[87]	DB C/9	S36798	Leander Corridor	[64] Carrier Panel Board Sub C DB
[88]	DB C/13	S36821	Leander Suite Office 27	[87] DB C/9
[89]	DB C/10	S36786	Carrier Service Cupboard 3	[64] Sub C DB
[90]	DB C/28	A47208	Carrier Experience Office	[89] DB C/10
[91]	DB C/12 ISO	S36788	Carrier Service Cupboard 3	[64] Sub C DB
[92]	DB C/12	S36787	Carrier Service Cupboard 3	[91] DB C/12 ISO via Contactor
[93]	DB 8	S36818	Shop Store	[1] Main Intake Panel
[94]	DB 11	S36870	Lift Room	[93] DB 8
[95]	DB G/1	S36794	Hall 1 Adjacent Sea King	[1] Main Intake Panel
[96]	DB G/2	T44636	Plant Room 3	[95] DB G/1 via 125A MCB Above

Index of Equipment Reports

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Equipment Report No.	Name	Asset No.	Location	Fed from
[97]	DB G/4	S36793	Hall 1 Sea King Exhibition	[95] DB G/1
[98]	DB G/3	T44637	Plant Room 2	[95] DB G/1 via 125A MCB Above
[99]	E/ISO 1	T44688	O/S Workshop Door	[1] Main Intake Panel via JB Below
[100]	Sub E/BB	S36825	Workshop	[99] E/ISO 1 via Phase Block O/S
[101]	IS DB/E/1	S36828	Workshop Intake	[100 Sub E/BB]
[102]	DB E/1	S36831	Workshop Intake	[101 IS DB/E/1]
[103]	DB E/2 Isoaltor	S36827	Workshop Intake	[100 Sub E/BB]
[104]	DB E/2	S36830	Workshop Intake	[103 IS/DB E/2]
[105]	IS DB E/3/4	S36826	Workshop Intake	[100 Sub E/BB]
[106]	DB E/3	T44668	Workshop Intake	[105 DB C/20 ISO]
[107]	DB E/4	S36834	Central Workshop	[105 DB C/20 ISO]
[108]	DB E/4/2B	T44692	Generator Outside Workshop	[107 DB E/4]
[109]	DB E/5	S36835	Central Workshop	[107 DB E/4]
[110]	IS DB/E/6	S36829	Workshop Intake	[100 Sub E/BB]
[111]	DB E/6	S36836	Swordfish Centre Electrical Cupboard	[110 IS DB/E/6]
[112]	DB E/8	S36839	Swordfish Centre Electrical Cupboard	[111 DB F/1]
[113]	DB E/7	S36837	Swordfish Centre Electric Cupboard	[111 DB F/1]
[114]	DB E/9	T44691	Room 221	[113 DB E/7]

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable




Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Swordfish Canteen DB F/ISI	1	SWA	B	157-1	-	5	-	-	0.22	200	500	0.10	-	-
L123		P	50	CS	200	35		-	-	-	200	NA	0.42	-	-
2	DB D/A S36799	1	SWA	B	947-2	-	5	-	-	0.01	L	-	0.08	-	-
L123		P	185	95	250	36		-	-	-	L	NA	0.09	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L12		-	-	-	-	-	-	-	-	-	-	NA	-	-	-
4	Supply to Shop Lift	1	SWA	F	157-1	-	5	-	-	-	200	500	0.10	-	-
L123		P	25	CS	200	36		-	-	-	200	NA	0.26	-	-
5	Sub A ISO 1 S36757	1	SWA	B	157-1	-	5	-	-	0.01	L	-	0.07	-	-
L123		P	240	CS	400	36		-	-	-	L	NA	0.09	-	-
6	DB 6 Shop Store S36819	1	SWA	B	947-2	-	5	-	-	L	L	-	0.15	-	-
L123		L	70	CS	125	36		-	-	-	L	NA	0.15	-	-
7	Sub B DB T44659 onto Sub C DB S3680	1	SWA	B/E	157-1	-	5	-	-	0.02	L	-	0.10	-	-
L123		P	185/95	CS	200	36		-	-	-	L	NA	0.08	-	-
8	DB 8 Shop Store S36818	1	SWA	B	947-2	-	5	-	-	L	L	-	0.15	-	-
L123		L	70	CS	125	36		-	-	-	L	NA	0.18	-	-
9	DB G/1 Hall 1 S36794 Sea King	1	SWA	B	157-1	-	5	-	-	L	101	500	0.24	-	-
L123		L	25	CS	100	25		-	-	-	101	NA	0.16	-	-
10	Workshop E/ISO T44688	2	SWA	B	157-1	-	5	-	-	0.35	200	500	0.24	-	-
L123		P	25	CS	100	25		-	-	-	200	NA	0.32	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	20/03/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	Supply to Busbar S36841	1	S	B	88	2	5	-	-	0.01	200	500	0.11	-	-
L123		P	50	35	160	80		-	-	-	200	NA	0.43	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	11/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	Ω	Ω	Ω	MΩ	AFDD Function	Zs Ω	mA	x5 ms	
1	DB F/1 S36842	1	S	B	-	-	5	-	-	0.01	200	500	0.11	-	-
L123		P	50	35	-	-	-	-	-	-	200	NA	0.44	-	-
2	DB F/2 S36843	1	S	B	-	-	5	-	-	0.01	200	500	0.11	-	-
L123		P	50	35	-	-	-	-	-	-	200	NA	0.44	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	11/02/2020	Multi-tester	493/21MLT		


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length 1 metre
 PVC Singles 50 mm²

Internal Rating

Unknown



Earthing Arrangements

PFC 1.56 kA
 Earth Loop 0.44 Ohms
 PVC Singles, 35 mm²

Supplied From DB/F/BB 1L123
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Swing Door Holder	1	T+E	B	60898	B	0.4	-	-	0.19	200	500	5.82	-	-
L1		P	2.5	1.5	6	10		-	-	-	200	NA	0.63	-	-
1	Old Heater Outlet Car Park Side	1	T+E	B	60898	B	0.4	-	-	0.54	200	500	1.74	-	-
L2		P	2.5	1.5	20	10		-	-	-	200	NA	0.98	-	-
1	Old Heater Outlet Old Main Entrance	1	T+E	B	60898	B	0.4	-	-	0.44	200	500	1.74	-	-
L3		P	2.5	1.5	20	10		-	-	-	200	NA	0.88	-	-
2	Old Heater Outlet Car Park Side	1	T+E	B	60898	B	0.4	-	-	0.34	200	500	1.74	-	-
L1		P	2.5	1.5	20	10		-	-	-	200	NA	0.78	-	-
2	Swordfish Centre Em DB F/3 B44045	1	SWA	B	60898	B	0.4	-	-	0.01	200	500	0.87	-	-
L2		P	10	CS/6	40	10		-	-	-	200	NA	0.58	-	-
2	Restaurant Sockets	5	T+E	B	61009	B	0.4	0.48	0.84	0.32	200	500	1.08	30	14.9
L3		P	2X2.5	2X1.5	32	10		0.48	-	-	200	NA	0.76	P	5.59
3	Restaurant Lights Circuit 2 & Ems	14	T+E	B	60898	B	0.4	-	-	1.10	200	250	3.49	-	-
L1		P	1.5	1	10	10		-	-	-	200	NA	1.54	-	-
3	Unknown	1	FLEX	B	61009	C	0.4	-	-	L	L	-	0.54	30	17.5
L2		L	6	6	32	10		-	-	-	L	NA	L	P	17.9
3	Sockets by Swing Door	2	T+E	B	61009	B	0.4	-	-	0.25	200	500	1.74	30	29.3
L3		P	2.5	1.5	20	10		-	-	-	200	NA	0.69	P	19.3
4	Servery Item 4	1	FLEX	B	61009	B	0.4	-	-	0.32	200	500	2.18	30	14.6
L1		P	2.5	2.5	16	10		-	-	-	200	NA	0.76	P	7.68
4	Servery Item 5	1	FLEX	B	61009	B	0.4	-	-	0.38	200	500	2.18	30	17.7
L2		P	2.5	2.5	16	10		-	-	-	200	NA	0.82	P	7.38
4	Servery Item 6	1	FLEX	B	61009	B	0.4	-	-	0.43	200	500	2.18	30	17.6
L3		P	2.5	2.5	16	10		-	-	-	200	NA	0.87	P	7.78
5	Servery Item 7	1	FLEX	B	61009	B	0.4	-	-	0.36	200	500	1.74	30	17.6
L1		P	2.5	2.5	20	10		-	-	-	200	NA	0.80	P	8.08


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
5	Servery Item 8 Bain Marie	1	FLEX	B	61009	B	0.4	-	-	0.37	200	500	1.08	30	27.5
L2		P	4	4	32	10		-	-	-	200	NA	0.81	P	17.9
5	Servery Item 9	1	FLEX	B	61009	B	0.4	-	-	0.17	200	500	1.08	30	14.8
L3		P	6	6	32	10		-	-	-	200	NA	0.61	P	5.49
6	Servery Item 10 via RCD Above	1	FLEX	B	60898	B	0.4	-	-	0.31	200	500	1.08	30	-
L123		P	4	4	32	10		-	-	-	999	NA	0.25	-	-
7	Kitchen Fan 1	1	T+E	A	60898	B	0.4	-	-	0.45	200	500	5.82	-	-
L1		P	1	1	6	10		-	-	-	200	NA	0.89	-	-
7	Kitchen Fan 2	1	T+E	A	60898	B	0.4	-	-	0.43	200	500	5.82	-	-
L2		P	1	1	6	10		-	-	-	200	NA	0.87	-	-
7	Kitchen Fan 3	1	T+E	A	60898	B	0.4	-	-	0.36	200	500	5.82	-	-
L3		P	1	1	6	10		-	-	-	200	NA	0.80	-	-
8	Restaurant Lights Circuit 1	73	T+E	A	60898	B	0.4	-	-	0.77	L	500	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	200	NA	1.21	-	-
8	Gas Interlock Kitchen	1	FLEX	B	60898	B	0.4	-	-	0.40	200	250	5.82	-	-
L2		P	1	1	6	10		-	-	-	0.01	NA	0.84	-	-
8	Dry Store DB S36844 DB F/4	1	T+E	A	60898	B	0.4	-	-	0.02	200	500	0.87	-	-
L3		P	16	6	40	10		-	-	-	200	NA	0.46	-	-
9	Restaurant Heater	1	SWA	A	60898	B	0.4	-	-	0.10	200	500	1.08	-	-
L123		P	6	6	32	10		-	-	-	200	NA	0.54	-	-
10	Walk In Fridge	1	SWA	A	60898	C	0.4	-	-	0.18	200	500	1.08	-	-
L123		P	2.5	CS	16	10		-	-	-	200	NA	0.62	-	-
11	Coffee Machine via RCD Above DB	1	FLEX	A	60898	B	0.4	-	-	0.45	200	500	1.74	30	-
L123		P	2.5	2.5	20	10		-	-	-	200	NA	0.93	-	-
12	Servery DB S36869 DB F/5	1	SWA	A	60898	B	0.4	-	-	0.03	200	500	0.87	-	-
L123		P	10	CS	40	10		-	-	-	200	NA	0.47	-	-
8	Fire Alarm Panel	1	T+E	B	60898	B	0.4	-	-	0.24	200	500	5.82	-	-
L2		P	2.5	1.5	6	10		-	-	-	200	NA	0.68	-	-
8	Lights in Boiler Room	1	S	B	60898	B	0.4	-	-	0.06	200	500	5.82	-	-
L2		P	1	1	6	10		-	-	-	200	NA	0.50	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	11/02/2020	Multi-tester	493/21MLT		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating	x1
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Lights Swordfish Center O/S Entrance	3	T+E	101	60898	B	0.4	-	-	1.24	L	250	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	0.00	NA	1.82	-	-
2	Lights Bar Area & Loft	3	T+E	101	60898	B	0.4	-	-	0.46	L	250	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	0.00	NA	1.04	-	-
3	Light Wash Up Area & Lobby	2	T+E	101	60898	B	0.4	-	-	0.69	L	250	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	0.00	NA	1.27	-	-
4	Emergency Spot Lights Swordfish Centre	4	T+E	101	60898	B	0.4	-	-	L	L	250	5.82	-	-
L2		L	1.5	1	6	10		-	-	-	0.00	NA	L	-	-
5	Emergency Spot Lights - Unknown	L	T+E	101	60898	B	0.4	-	-	L	L	250	5.82	-	-
L2		L	1.5	1	6	10		-	-	-	0.00	NA	L	-	-
6	Emergency Door Lights Swordfish Centre	4	T+E	101	60898	B	0.4	-	-	1.46	L	250	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	0.00	NA	2.04	-	-
7	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-	-
L2		-	-	-	6	10		-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	17/03/2020	Multi-tester	493/21MLT		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	ms	
1	Sockets This Area & Staff Rooms	10	T+E	B	61009	B	0.4	0.42	0.68	0.40	200	500	1.08	30	18.7
L3		P	2X2.5	2X1.5	32	6		0.42		-	200	NA	0.86	P	13.3
2	Water Heater Next Door	1	T+E	B	61009	B	0.4	-	-	0.34	200	500	2.18	30	18.3
L3		P	6	2.5	16	6		-	-	-	200	NA	0.80	P	28.3
3	Network Cab Comms Room	1	T+E	B	61009	B	0.4	-	-	0.22	200	500	2.18	30	17.2
L3		P	2.5	1.5	16	6		-	-	-	200	NA	0.68	P	17.2
4	Lights This Area & Staff Rooms	13	T+E	B	61009	B	0.4	-	-	0.55	L	500	5.82	30	18.1
L3		P	1.5	1	6	6		-	-	-	0.01	NA	1.01	P	17.6

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	17/03/2020	Multi-tester	493/21MLT		

Equipment Report

Section 6 [7]


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 10 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 0.99 kA
 Earth Loop 0.47 Ohms
 Cable Sheath

Supplied From DB F/1 12L123
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	AFDD Function	Z _s	mA	x5
			mm ²	mm ²	A	kA							Ω	Test Button	ms
1	Fly Killers R/H/S	2	T+E	B	60898	B	0.4	-	-	0.31	200	500	2.18	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.78	-	-
1	Window Fans	4	T+E	B	60898	B	0.4	-	-	0.61	L	250	3.49	-	-
L2		P	1.5	1.5	10	10		-	-	-	200	NA	1.08	-	-
1	Freezer Rm Socket & Outside	2	T+E	B	61009	C	0.4	0.18	0.35	0.51	200	500	0.54	30	35.4
L3		P	2X2.5	2X1.5	32	10		0.18	-	-	200	NA	0.98	P	25.5
2	Alcove & Kit Sockets	2	T+E	B	61009	C	0.4	-	-	0.11	200	500	0.87	30	27.9
L1		P	2.5	1.5	20	10		-	-	-	200	NA	0.58	P	18
2	Servery Extractor	1	T+E	B	60898	B	0.4	-	-	0.01	L	250	3.49	-	-
L2		P	1.5	1.5	10	10		-	-	-	200	NA	0.48	-	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Kitchen Extractor	1	SWA	B	60898	C	0.4	-	-	0.01	200	500	1.08	-	-
L123		P	2.5	CS	16	10		-	-	-	200	NA	0.48	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	17/03/2020	Multi-tester	493/21MLT		


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length 1 metre
 PVC Singles 50 mm²

Internal Rating

IP2X



Earthing Arrangements

PFC 1.56 kA
 Earth Loop 0.44 Ohms
 PVC Singles, 35 mm²

Supplied From DB/F/BB 2L123
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5
			mm ²	mm ²	A	kA						Ω	Test Button	ms
1	Sockets Service Rm, This Rm & Bug Zapper Corridor	6	S	B	61009	B	0.4	0.11	0.08	0.06	200	500	30	29.1
L1		P	2X2.5	2X1.5	32	10		0.12	-	-	200	NA	P	18.2
1	Sockets Kitchen Far L/H/S	7	T+E	B	61009	B	0.4	0.48	0.78	0.33	200	500	30	79.6
L2		P	2X2.5	2X1.5	20	10		0.48	-	-	200	NA	P	18.7
1	3kw Heater Far End	1	T+E	B	60898	B	0.4	-	-	0.35	200	500	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	-	-
2	Lobby Sockets & TV	3	T+E	B	61009	B	0.4	-	-	0.21	200	500	30	27.8
L1		P	2.5	1.5	20	10		-	-	-	200	NA	P	18.2
2	Sockets Kitchen	2	T+E	B	61009	B	0.4	-	-	0.26	200	500	30	28.1
L2		P	2.5	1.5	20	10		-	-	-	200	NA	P	18.2
2	HTN Stat Behind	1	T+E	B	60898	D	0.4	-	-	0.28	200	500	-	-
L3		P	1.5	1	2	10		-	-	-	200	NA	-	-
3	Meter	1	S	B	1361	-	0.4	-	-	0.01	200	500	-	-
L1		P	2.5	-	5	10		-	-	-	200	NA	-	-
3	Meter	1	S	B	1361	-	0.4	-	-	0.01	200	500	-	-
L2		P	2.5	-	5	10		-	-	-	200	NA	-	-
3	Meter	1	S	B	1361	-	0.4	-	-	0.01	200	500	-	-
L3		P	2.5	-	5	10		-	-	-	200	NA	-	-
4	Disabled WC Alarm	L	FLEX	B	60898	B	0.4	-	-	0.27	200	500	-	-
L1		P	1	1	6	10		-	-	-	200	NA	-	-
4	Spare	-	-	-	61009	B	-	-	-	-	-	-	30	-
L2		-	-	-	32	10		-	-	-	-	-	-	-
4	Spare	-	-	-	60898	C	-	-	-	-	-	-	-	-
L3		-	-	-	10	10		-	-	-	-	-	-	-
5	Spare	-	-	-	60898	B	-	-	-	-	-	-	-	-
L1		-	-	-	20	10		-	-	-	-	-	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
5	Till & Stand Coffee Machine	L	FLEX	B	60898	B	0.4	-	-	0.01	200	500	1.74	-	-
L2		P	2.5	2.5	20	10		-	-	-	200	NA	0.85	-	-
5	Till & Stand Coffee Machine	L	FLEX	B	60898	B	0.4	-	-	0.01	200	500	1.74	-	-
L3		P	2.5	2.5	20	10		-	-	-	200	NA	0.85	-	-
6	Till & Stand Coffee Machine	L	FLEX	B	60898	B	0.4	-	-	0.01	200	500	1.74	-	-
L1		P	2.5	2.5	20	10		-	-	-	200	NA	0.85	-	-
6	Spare	-	-	-	60898	B	-	-	-	-	-	-	1.08	-	-
L2		-	-	-	32	10		-	-	-	-	-	-	-	-
6	Spare	-	-	-	60898	B	-	-	-	-	-	-	1.08	-	-
L3		-	-	-	32	10		-	-	-	-	-	-	-	-
7	Inner Auto Door Opener	1	T+E	B	60898	B	0.4	-	-	0.26	200	500	5.82	-	-
L1		P	1.5	1.5	6	10		-	-	-	200	NA	0.70	-	-
7	Outer Auto Door Opener	1	T+E	B	60898	B	0.4	-	-	0.42	200	500	5.82	-	-
L2		P	1.5	1.5	6	10		-	-	-	200	NA	0.86	-	-
7	Spectrum Box Behind Fire Alarm	1	T+E	B	60898	B	0.4	-	-	0.21	200	500	5.82	-	-
L3		P	1.5	1.5	6	10		-	-	-	200	NA	0.65	-	-
8	Spare	-	-	-	60898	B	-	-	-	-	-	-	3.49	-	-
L1		-	-	-	10	10		-	-	-	-	-	-	-	-
8	Outside Lights	5	T+E	B	60898	B	0.4	-	-	-	L	250	3.49	-	-
L2		P	1.5	1.5	10	10		-	-	-	0.01	NA	2.31	-	-
8	Kitchen Lights	8	T+E	B	60898	B	0.4	-	-	1.21	L	250	3.49	-	-
L3		P	1.5	1.5	10	10		-	-	-	0.01	NA	1.65	-	-
9	Spare	-	-	-	60898	B	-	-	-	-	-	-	3.49	-	-
L1		-	-	-	10	10		-	-	-	-	-	-	-	-
9	Spare	-	-	-	60898	B	-	-	-	-	-	-	3.49	-	-
L2		-	-	-	10	10		-	-	-	-	-	-	-	-
9	Fan in Servery	1	T+E	B	60898	B	0.4	-	-	0.32	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.76	-	-
10	1.5kw Heater in Kitchen	1	T+E	B	60898	B	0.4	-	-	0.12	200	500	2.18	-	-
L1		P	1.5	1	16	10		-	-	-	200	NA	0.56	-	-
10	Spare	-	-	-	60898	B	-	-	-	-	-	-	2.18	-	-
L2		-	-	-	16	10		-	-	-	-	-	-	-	-
10	Spare	-	-	-	60898	B	-	-	-	-	-	-	2.18	-	-
L3		-	-	-	16	10		-	-	-	-	-	-	-	-
11	Spare	-	-	-	60898	B	-	-	-	-	-	-	1.74	-	-
L123		-	-	-	20	10		-	-	-	-	-	-	-	-

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served Polarity	Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 r2 R1+R2 R2	L/L L/E	Test Voltage AFDD Function	Max Z s Zs Ω	Rating mA Test Button		x1 x5 ms	
12 L123	Combi Oven	1 P	FLEX 16	B 16	60898 32	B 10	0.4	- - 0.02	- - -	200 200	500 NA	1.08 0.45	- -	- -	

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	19/02/2020	Multi-tester	493/21MLT		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 185 mm²

Internal Rating

Unknown



Earthing Arrangements

PFC 5.2 kA
Earth Loop 0.10 Ohms
PVC Singles, 95 mm²

Supplied From Main Intake Panel 2L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Z _s Ω	mA	x5 ms
1	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-
4	DB D/D S36832	1	SWA	B	60947	2	5	-	-	0.16	200	500	1.15	-
L2		P	16	16	32	25	-	-	-	-	200	NA	0.25	-
4	DB D/F S36812	1	SWA	B	60947	2	5	-	-	0.10	200	500	1.15	-
L3		P	16	16	63	25	-	-	-	-	200	NA	0.19	-
5	Sewage Pump	1	SWA	B	60947	2	5	-	-	L	L	-	2.30	-
L123		L	2.5	2.5	16	25	-	-	-	-	L	NA	L	-
6	Power Factor Correction	1	SWA	B	60947	2	5	-	-	L	L	-	0.37	-
L123		L	35	35	100	25	-	-	-	-	L	NA	L	-
7	Spare	-	-	-	60947	2	-	-	-	-	-	-	0.37	-
L123		-	-	-	100	25	-	-	-	-	-	-	-	-
8	DB D/E S36802	1	SWA	A	60947	2	5	-	-	0.12	200	500	0.37	-
L123		P	35	16	100	25	-	-	-	-	200	NA	0.21	-
9	Supply to Mechanical Panel	1	SWA	A	60947	2	5	-	-	L	L	-	0.30	-
L123		L	16	CS	125	25	-	-	-	-	L	NA	L	-
10	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
11	DB D/B S36800	1	TRI FLEX	B	60947	2	5	-	-	0.01	200	500	0.30	-
L123		P	70	35	125	25	-	-	-	-	200	NA	0.10	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs Ω	mA Test Button	x5 ms
12	DB D/C S36801	1	TRI FLEX	B	60947	2	5	-	-	0.01	200	500	0.30	-	-
L123		P	70	35	125	25		-	-	-	200	NA	0.10	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	20/03/2020	Multi-tester	493/21MLT		


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 16 mm²

Internal Rating

Unknown



Earthing Arrangements

PFC 0.92 kA
 Earth Loop 0.25 Ohms
 Cable Sheath


Supplied From DB D/A 4L2
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
1 L2	Socket Front Entrance	1 P	S 2.5	B 2.5	3871 15	1 6	0.4	- -	- -	1.26 -	200 200	500 NA	1667 1.54	30 -	- -
2 L2	Emergency Lights	5 P	S 1.5	B 1.5	3871 5	1 6	0.4	- -	- -	0.64 -	L L	- NA	1667 1.89	30 -	- -
3 L2	Lights Rear & Main Walkway	7 P	S 1.5	B 1.5	3871 5	1 6	0.4	- -	- -	1.52 -	L L	- NA	1667 1.77	30 -	- -
4 L2	Walkway Lights	6 P	S 1.5	B 1.5	3871 5	1 6	0.4	- -	- -	1.59 -	L L	- NA	1667 1.84	30 -	- -
5 L2	Light Cockpit & Walkway	9 P	S 2X1.5	B 2X1.5	3871 5	1 6	0.4	- -	- -	1.48 -	L L	- NA	1667 1.73	30 -	- -
6 L2	Socket Beside DB	1 P	S 2.5	B 2.5	3871 5	1 6	0.4	- -	- -	0.02 -	200 200	500 NA	1667 0.27	30 -	- -

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
S Smith	16/03/2020	Multi-tester	9ABC		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
											AFDD Function	Ω	Test Button	ms	
1	CCTV	1	T+E	C	60898	B	0.4	-	-	0.06	200	500	2.18	-	-
L3		P	2.5	1.5	16	3		-	-	-	200	NA	0.25	-	-
2	Water Heater	1	T+E	C	60898	B	0.4	-	-	0.02	200	500	2.18	-	-
L3		P	2.5	2.5	16	3		-	-	-	200	NA	0.21	-	-
3	Spare	-	-	-	60898	B	-	-	-	-	-	-	1.08	-	-
L3		-	-	-	32	3		-	-	-	-	-	-	-	-
4	Tubular Heaters	3	T+E	B	60898	B	0.4	-	-	0.56	200	500	1.74	-	-
L3		P	2.5	1.5	20	3		-	-	-	200	NA	0.75	-	-
5	Ladies Hand Dryer & Fan	2	T+E	B	60898	B	0.4	-	-	0.41	200	500	1.74	-	-
L3		P	2.5	1.5	20	3		-	-	-	200	NA	0.60	-	-
6	Gents Hand Dryer & Fan	3	T+E	B	60898	B	0.4	-	-	0.16	200	500	1.74	-	-
L3		P	2.5	1.5	20	3		-	-	-	200	NA	0.35	-	-
7	Lights Gents, Disabled & Cupboard	7	T+E	B	60898	B	0.4	-	-	0.64	L	-	5.82	-	-
L3		P	1.5	1	6	3		-	-	-	L	NA	0.83	-	-
8	Lights Ladies & Hall	6	T+E	B	60898	B	0.4	-	-	0.58	L	-	5.82	-	-
L3		P	1.5	1	6	3		-	-	-	L	NA	0.77	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Stu Smith Sean Smith	11/03/2020	Multi-tester	9ABC		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 35 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 2.2 kA
Earth Loop 0.21 Ohms
PVC Singles, 16 mm²
Cable Sheath

Supplied From DB D/A 8L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
1 L1	Socket Pillar	1 P	S 2X2.5	B MF	61009 32	C 10	0.4	0.50 0.50	-	0.17 -	200 200	500 NA	1667 0.38	30 P	37 37
1 L2	Sockets Pillar	3 P	S 2X2.5	B MF	61009 32	C 10	0.4	0.65 0.65	-	0.11 -	200 200	500 NA	1667 0.32	30 P	78 38
1 L3	Sockets Pillar	3 P	S 2X2.5	B MF	61009 32	C 10	0.4	0.44 0.44	-	0.10 -	200 200	500 NA	1667 0.31	30 P	58 38
2 L1	Sockets Pillar	2 P	S 2X4	B MF	61009 32	C 10	0.4	0.45 0.43	-	0.05 -	200 200	500 NA	1667 0.26	30 P	88 38
2 L2	Sockets Pillar	2 P	S 2X4	B MF	61009 32	B 10	0.4	0.39 0.39	-	0.07 -	200 200	500 NA	1667 0.28	30 P	78 77
2 L3	H/L Smoke Beams	L -	S 1.5	B 1.5	60898 6	C 10	0.4	- -	-	- -	- -	- -	2.91 -	- -	- -
3 L123	Isolator Fan	1 P	S 1.5	B 1.5	60898 16	C 10	0.4	- -	-	0.63 -	200 200	500 NA	1.08 0.84	- -	- -
4 L1	FCU Security Panel	1 P	S 2.5	B 2.5	60898 10	C 10	0.4	- -	-	0.34 -	200 200	500 NA	1.74 0.55	- -	- -
4 L2	Blank	- -	- -	- -	- -	- -	- -	- -	-	- -	- -	- -	- -	- -	- -
4 L3	Isolator A/C Unit	1 P	SWA 4	C 4	60898 32	C 10	0.4	- -	-	0.14 -	200 200	500 NA	0.54 0.35	- -	- -
5 L123	Isolator Hoist	1 -	SWA 4	C CS	60898 16	C 10	0.4	- -	-	- -	- -	- -	1.08 -	- -	- -
6 L1	Isolator A/C Unit Learning Centre	1 P	SWA 6	C 6	60898 32	C 10	0.4	- -	-	0.19 -	200 200	500 NA	0.54 0.40	- -	- -
6 L2	Isolator A/C Unit Classroom	1 P	SWA 4	C 4	60898 32	C 10	0.4	- -	-	0.20 -	200 200	500 NA	0.54 0.41	- -	- -

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs Ω	mA Test Button	x5 ms
6	Socket Below	1	S	B	60898	B	0.4	-	-	0.01	200	500	1.74	-	-
L3		P	2.5	2.5	20	10		-	-	-	200	NA	0.22	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith	12/03/2020	Multi-tester	9ABC		
Stu Smith					


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
PVC Singles 95 mm²

Internal Rating

Unknown



Earthing Arrangements

PFC 5.2 kA
Earth Loop 0.10 Ohms
PVC Singles, 50 mm²

Supplied From DB D/A 11L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
1	LX9 (4) LX12 (3) LX20 (2) H/L	3	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	6	6	16	10		-	-	-	L	NA	L	-	-
1	LX21 (1,2,3) H/L	3	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	4	4	16	10		-	-	-	L	NA	L	-	-
2	Unknown	L	S	B	60898	C	0.4	-	-	L	L	-	2.91	-	-
L1		L	2.5	2.5	6	10		-	-	-	L	NA	L	-	-
2	Runway Lights	20	S	B	60898	C	0.4	-	-	2.40	L	250	2.91	-	-
L2		P	2.5	2.5	6	10		-	-	-	0.01	NA	2.55	-	-
2	LX14 (2,3) H/L	2	S	L	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
3	LX13 (3) H/L	1	S	L	60898	C	0.4	-	-	L	L	-	1.74	-	-
L1		L	2.5	2.5	10	10		-	-	-	L	NA	L	-	-
3	Concorde Wheel Lights	2	S	B	60898	C	0.4	-	-	1.15	L	250	2.91	-	-
L2		P	4	4	6	10		-	-	-	999	NA	1.25	-	-
3	LX11 (4) LX12 (1) H/L	2	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L3		L	4	4	10	10		-	-	-	L	NA	L	-	-
4	Concorde Wheel Lights	2	S	B	60898	C	0.4	-	-	18.6	L	250	2.91	-	-
L1		P	2.5	2.5	6	10		-	-	-	999	NA	18.7	-	-
4	LX16 (2,3,4) H/L	3	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
4	Spare	-	-	-	60898	C	-	-	-	-	-	-	1.74	-	-
L3		-	-	-	10	10		-	-	-	-	-	-	-	-
5	LX6 (4) H/L	1	S	L	60898	C	0.4	-	-	L	L	-	1.74	-	-
L1		L	2.5	2.5	10	10		-	-	-	L	NA	L	-	-

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
5	Unknown	L	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
5	Sea Harrier Lights L/H/S	2	S	B	60898	C	0.4	-	-	0.72	L	250	1.08	-	-
L3		P	2.5	2.5	16	10		-	-	-	888	NA	0.82	-	-
6	LX15 (1,2,5) H/L	2	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
6	Spare	-	-	-	60898	C	-	-	-	-	-	-	1.74	-	-
L2		-	-	-	10	10		-	-	-	-	-	-	-	-
6	Sea Harrier Lights L/H/S	2	S	B	60898	C	0.4	-	-	0.45	L	250	1.08	-	-
L3		P	2.5	2.5	16	10		-	-	-	999	NA	0.55	-	-
7	LX14 (1) LX19 (1) H/L	2	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
7	Sea Harrier Lights R/H/S	2	S	B	60898	C	0.4	-	-	L	L	250	1.08	-	-
L2		P	2.5	2.5	16	10		-	-	-	999	NA	0.98	-	-
7	LX6 (1) H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L3		L	2.5	2.5	10	10		-	-	-	L	NA	L	-	-
8	H/L Lights Above Sea Barrier	5	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
8	Sea Harrier Lights R/H/S	2	S	B	60898	C	0.4	-	-	0.81	L	250	1.08	-	-
L2		P	2.5	2.5	16	10		-	-	-	999	NA	0.91	-	-
8	LX10 (2) LX13 (1) H/L	2	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L3		L	1.5	1.5	10	10		-	-	-	L	NA	L	-	-
9	LX19 (3) H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
9	LX15 (4,6) H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
9	Unknown	2	S	L	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	4	4	16	10		-	-	-	L	NA	L	-	-
10	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-		-	-	-	-	-	-	-	-
10	LX10 (4) H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L2		L	1.5	1.5	10	10		-	-	-	L	NA	L	-	-
10	LX8 (3,4) H/L	2	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
11	LX7 (3,4) H/L	2	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
11	LX11 (1,2) H/L	1	S	L	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	1.5	1.5	16	10		-	-	-	L	NA	L	-	-
11	Spare	-	-	-	60898	C	0.4	-	-	-	-	-	1.74	-	-
L3		-	-	-	10	10		-	-	-	-	-	-	-	-
12	LX7 (2) H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L1		L	1.5	1.5	10	10		-	-	-	L	NA	L	-	-
12	LX6 (7) H/L	1	S	L	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
12	POD No 6	1	S	B	60898	C	0.4	-	-	2.15	200	500	2.91	-	-
L3		P	1.5	1.5	6	10		-	-	-	200	NA	2.25	-	-
13	Track Lights Introduction	3	S	B	60898	C	0.4	-	-	0.92	L	250	1.08	-	-
L1		P	2.5	2.5	16	10		-	-	-	999	NA	1.02	-	-
13	LX2 (2,3) H/L	2	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
13	Unknown	L	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
14	Track Lights Introduction	2	S	B	60898	C	0.4	-	-	0.93	L	250	1.08	-	-
L1		P	2.5	2.5	16	10		-	-	-	999	NA	1.03	-	-
14	LX2 (1) H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L2		L	2.5	2.5	10	10		-	-	-	L	NA	L	-	-
14	Unknown	L	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L3		L	2.5	2.5	10	10		-	-	-	L	NA	L	-	-
15	Contactor Sw Supply	1	S	B	60898	C	0.4	-	-	0.03	L	250	2.91	-	-
L1		P	1.5	1.5	6	10		-	-	-	999	NA	0.13	-	-
15	Contactor Sw Supply	1	S	B	60898	C	0.4	-	-	0.69	L	250	2.91	-	-
L2		P	1.5	1.5	6	10		-	-	-	999	NA	0.79	-	-
15	LX6 (2,5,6) H/L	3	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
16	Contactor Sw Supply	1	S	B	60898	C	0.4	-	-	0.03	L	250	2.91	-	-
L1		L	1.5	1.5	6	10		-	-	-	200	NA	0.13	-	-
16	LX4 (3) LX9 (1) H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L2		L	1.5	1.5	10	10		-	-	-	L	NA	L	-	-
16	Unknown	L	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
17	Contactor Sw Supply	1	S	B	60898	C	0.4	-	-	0.03	L	250	2.91	-	-
L1		P	1.5	1.5	6	10		-	-	-	999	NA	0.13	-	-

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
17	Contactor Sw	1	S	B	60898	C	0.4	-	-	0.03	L	250	2.91	-	-
L2		P	1.5	1.5	6	10		-	-	-	999	NA	0.13	-	-
17	LX10 (3) H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L3		L	1.5	1.5	10	10		-	-	-	L	NA	L	-	-
18	LX4 (1) H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L1		L	1.5	1.5	10	10		-	-	-	L	NA	L	-	-
18	Contactor Sw Supply	1	S	B	60898	C	0.4	-	-	0.03	L	250	2.91	-	-
L2		P	1.5	1.5	6	10		-	-	-	999	NA	0.13	-	-
18	Walkway Lights	23	S	B	60898	C	0.4	-	-	0.83	L	250	1.74	-	-
L3		P	2.5	2.5	10	10		-	-	-	999	NA	0.93	-	-
19	Spare	-	-	-	60898	C	-	-	-	-	-	-	1.08	-	-
L1		-	-	-	16	10		-	-	-	-	-	-	-	-
19	Spare	-	-	-	60898	C	-	-	-	-	-	-	1.08	-	-
L2		-	-	-	16	10		-	-	-	-	-	-	-	-
19	Cables for Future Use (Spare)	L	S	L	60898	C	0.4	-	-	-	-	-	1.08	-	-
L3		-	2.5	2.5	16	10		-	-	-	-	-	-	-	-
20	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-		-	-	-	-	-	-	-	-
20	Unknown	2	S	L	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
20	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-		-	-	-	-	-	-	-	-
21	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-		-	-	-	-	-	-	-	-
21	LX9 (1,3,5) H/L	3	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
21	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-		-	-	-	-	-	-	-	-
22	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-		-	-	-	-	-	-	-	-
22	Track Lights Introduction	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L2		L	1.5	1.5	10	10		-	-	-	L	NA	0.98	-	-
22	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-		-	-	-	-	-	-	-	-
23	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-		-	-	-	-	-	-	-	-

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
24	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	20/03/2020	Multi-tester	493/21MLT		


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length 1 metre
 PVC Singles 95 mm²

Internal Rating

Unknown



Earthing Arrangements

PFC 4.2 kA
 Earth Loop 0.10 Ohms
 PVC Singles, 50 mm²

Supplied From DB D/A 12L123
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Z _s	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Unknown	L	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
1	Uplighters H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
1	Uplighters H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
2	Uplighters H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
2	Uplighters H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
2	Uplighters H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
3	Uplighters H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
3	Unknown	L	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L2		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
3	Uplighters H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L3		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-
4	AV Theatre Sockets	3	S	B	60898	C	0.4	-	-	0.43	200	500	1.08	-	-
L1		P	6	6	16	10		-	-	-	200	NA	0.53	-	-
4	LX5 Plug 3 H/L	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L2		L	1.5	1.5	10	10		-	-	-	L	NA	L	-	-
4	Cables for Future Use (Sare)	-	S	B	60898	C	0.4	-	-	-	-	-	1.74	-	-
L3		-	2.5	2.5	10	10		-	-	-	-	-	-	-	-
5	Unknown	L	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L1		L	4	4	10	10		-	-	-	L	NA	L	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
5 L2	LX5 Plug 1 H/L	1 L	S 1.5	B 1.5	60898 10	C 10	0.4	- -	- -	L -	L NA	- L	1.74	-	-
5 L3	Cables for Future Use (Spare)	- -	S 4	B 4	60898 10	C 10	0.4	- -	- -	- -	- -	- -	1.74	-	-
6 L1	POD No 10 Sear Barrier	1 P	S 1.5	B 1.5	60898 10	C 10	0.4	- -	- -	1.21 -	L 60	500 NA	1.74 1.31	-	-
6 L2	POD No 5	1 P	S 1.5	B 1.5	60898 6	C 10	0.4	- -	- -	2.20 -	L 60	500 NA	2.91 2.30	-	-
6 L3	POD No 4	1 P	S 1.5	B 1.5	60898 6	C 10	0.4	- -	- -	2.08 -	L 60	500 NA	2.91 2.18	-	-
7 L1	POD No 8	1 P	S 1.5	B 1.5	60898 10	C 10	0.4	- -	- -	1.14 -	L 60	500 NA	1.74 1.24	-	-
7 L2	POD No 2	1 P	S 1.5	B 1.5	60898 10	C 10	0.4	- -	- -	1.17 -	L 60	500 NA	1.74 1.27	-	-
7 L3	Cables for Future Use (Spare)	- -	S 2.5	B 2.5	60898 10	C 10	0.4	- -	- -	- -	- -	- -	1.74	-	-
8 L1	Concorde Showcase (Spare)	1 -	S 2.5	B 2.5	60898 16	C 10	0.4	- -	- -	- -	- -	- -	1.08	-	-
8 L2	Concorde Showcase (Spare)	1 -	S 2.5	B 2.5	60898 16	C 10	0.4	- -	- -	- -	- -	- -	1.08	-	-
8 L3	POD No 7	1 P	S 1.5	B 1.5	60898 6	C 10	0.4	- -	- -	2.02 -	L 60	500 NA	2.91 2.12	-	-
9 L1	Spare	- -	- -	- -	60898 10	C 10	-	- -	- -	- -	- -	- -	1.74	-	-
9 L2	Lights Concorde Engine	4 L	S 1.5	B 1.5	60898 10	C 10	0.4	- -	- -	L -	L NA	- L	1.74	-	-
9 L3	Harrier Showcase	2 L	S 2.5	B 2.5	60898 10	C 10	0.4	- -	- -	L -	L NA	- L	1.74	-	-
10 L1	Spare	6 -	S 1.5	B 1.5	60898 6	C 10	0.4	- -	- -	- -	- -	- -	2.01	-	-
10 L2	Spare	- -	- -	- -	60898 6	C 10	-	- -	- -	- -	- -	- -	2.01	-	-
10 L3	Cables for Future Use (Spare)	- -	- -	- -	60898 10	C 10	-	- -	- -	- -	- -	- -	1.74	-	-
11 L1	CSTOL AV Lights	1 P	S 4	B 4	60898 6	C 10	0.4	- -	- -	0.54 -	L 60	500 NA	2.91 0.64	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
11	Spare	-	-	-	60898	C	-	-	-	-	-	2.91	-	-	
L2		-	-	-	6	10	-	-	-	-	-	-	-	-	
11	Spare	-	-	-	60898	C	-	-	-	-	-	1.74	-	-	
L3		-	-	-	10	10	-	-	-	-	-	-	-	-	
12	VSTOL 6A	L	S	B	60898	C	0.4	-	-	0.52	L	250	2.91	-	
L1		P	4	4	6	10	-	-	-	-	60	NA	0.62	-	
12	Speed AV - Unknown	L	S	B	60898	C	0.4	-	-	L	L	-	2.91	-	
L2		L	4	4	6	10	-	-	-	-	L	NA	L	-	
12	Cables for Future Use (Spare)	-	-	-	60898	C	-	-	-	-	-	-	1.74	-	
L3		-	-	-	10	10	-	-	-	-	-	-	-	-	
13	Unknown	L	S	B	60898	C	0.4	-	-	L	L	500	2.91	-	
L1		L	4	4	6	10	-	-	-	-	60	NA	L	-	
13	Contactor Sw Supply	1	S	B	60898	C	0.4	-	-	0.03	L	500	2.91	-	
L2		P	1.5	1.5	6	10	-	-	-	-	200	NA	0.13	-	
13	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	
14	Flood No 1	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	
L1		L	4	4	10	10	-	-	-	-	L	NA	L	-	
14	Flood No 2	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	
L2		L	2.5	2.5	10	10	-	-	-	-	L	NA	L	-	
14	Flood No 3	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	
L3		L	2.5	2.5	10	10	-	-	-	-	L	NA	L	-	
15	Flood No 4	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	
L1		L	2.5	2.5	10	10	-	-	-	-	L	NA	L	-	
15	Flood No 5	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	
L2		L	2.5	2.5	10	10	-	-	-	-	L	NA	L	-	
15	Flood No 6	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	
L3		L	4	2.5	10	10	-	-	-	-	L	NA	L	-	
16	Flood No 7	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	
L1		L	4	4	10	10	-	-	-	-	L	NA	L	-	
16	Flood No 8	1	S	B	60898	C	0.4	-	-	I	L	-	1.74	-	
L2		L	4	4	10	10	-	-	-	-	L	NA	L	-	
16	Flood No 9	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	
L3		L	4	4	10	10	-	-	-	-	L	NA	L	-	
17	Flood No 10	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	
L1		L	4	4	10	10	-	-	-	-	L	NA	L	-	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT		Points Served	Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation		Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Z _s Ω	mA	x5 ms	
17	Flood No 11	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L2		L	10	10	10	10		-	-	-	L	NA	L	-	-
17	Flood No 12	1	S	B	60898	C	0.4	-	-	L	L	-	1.74	-	-
L3		L	4	4	10	10		-	-	-	L	NA	L	-	-
18	Em Lights	7	S	B	60898	C	0.4	-	-	L	L	-	2.91	-	-
L1		L	1.5	1.5	6	10		-	-	-	L	NA	L	-	-
18	Em Lights	L	S	B	60898	C	0.4	-	-	L	L	-	2.91	-	-
L2		L	1.5	1.5	6	10		-	-	-	L	NA	L	-	-
18	Em Lights	L	S	B	60898	C	0.4	-	-	L	L	-	2.91	-	-
L3		L	1.5	1.5	6	10		-	-	-	L	NA	L	-	-
19	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
19	Contactor Sw Supply	1	S	B	60898	C	0.4	-	-	0.03	L	250	2.91	-	-
L2		P	1.5	1.5	6	10		-	-	-	200	NA	0.73	-	-
19	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
20	Pillar Sockets	3	S	B	61009	C	0.4	0.50	MF	0.14	200	500	0.54	30	86.4
L1		P	2X4	MF	32	10		0.50		-	200	NA	0.24	P	37.2
20	Spare	-	-	-	61009	C	-	-	-	-	-	-	0.54	30	-
L2		-	-	-	32	10		-	-	-	-	-	-	-	-
20	Spare	-	-	-	61009	C	-	-	-	-	-	-	0.54	30	-
L3		-	-	-	32	10		-	-	-	-	-	-	-	-
21	Pillar Sockets Near	5	S	B	61009	C	0.4	0.70	0.42	0.20	200	500	0.54	30	79
L1		P	2X2.5	2X2.5	32	10		0.70		-	200	NA	0.30	P	39
21	Pillar Sockets Far	2	S	B	61009	C	0.4	0.80	0.63	0.21	200	500	0.54	30	57.2
L2		P	2X2.5	2X2.5	32	10		0.80		-	200	NA	0.31	P	36.4
21	Spare	-	-	-	61009	C	-	-	-	-	-	-	0.54	30	-
L3		-	-	-	32	10		-	-	-	-	-	-	-	-
22	Sockets by Fire Exit	2	S	B	61009	C	0.4	0.90	1.18	0.41	200	500	0.54	30	6.4
L1		P	2X2.5	2X2.5	32	10		0.92		-	200	NA	0.51	P	39
22	Spare	-	-	-	61009	C	-	-	-	-	-	-	0.54	30	-
L2		-	-	-	32	10		-	-	-	-	-	-	-	-
22	Spare	-	-	-	61009	C	-	-	-	-	-	-	0.54	30	-
L3		-	-	-	32	10		-	-	-	-	-	-	-	-
23	Security Cameras	L	S	B	60898	C	0.4	-	-	L	L	-	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	L	NA	L	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs Ω	mA Test Button	x5 ms
23	Spare	-	-	-	60898	C	-	-	-	-	-	-	1.08	-	-
L2		-	-	-	16	10	-	-	-	-	-	-	-	-	-
23	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
24	3 Phase Socket Below	1	S	B	60898	C	0.4	-	-	0.01	200	500	0.54	-	-
L123		P	6	6	32	10	-	-	-	-	200	NA	0.11	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	20/03/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2 R2	L/L L/E		Test Voltage AFDD Function	Max Z s Zs	Rating mA Test Button
1	Busbar S36758 L123	1 P	BUSBAR 240	B MF	88 200	2 80	5	-	-	0.01 -	200 200	500 NA	0.14 0.10	- -	- -

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		10/02/2020	Multi-tester		493/21MLT			


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length 0.5 metres
 PVC Singles 120 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 4.64 kA
 Earth Loop 0.10 Ohms
 PVC Singles, 16 mm²


Supplied From Sub A ISO 1 1L123 via C/O Switch
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
1 L123	Isolator DB A/4 S36759	1 P	S 25	B MF	- -	- -	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.11	- -	- -
2 L123	Isolator DB A/1 & 2 S36760	1 P	S 25	B MF	- -	- -	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.11	- -	- -
3 L123	Isolator DB A/5 & 7 S36761	1 P	S 25	B MF	- -	- -	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.11	- -	- -
4 L123	DB A/ Above S36767	1 P	PVC/PVC 25	B 16	- -	- -	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.11	- -	- -
5 L123	Isolator DB A/8 & 9 S36762	1 P	S 25	B MF	- -	- -	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.11	- -	- -
6 L123	Isolator DB A/1 S36763	1 P	S 25	B MF	- -	- -	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.11	- -	- -
7 L123	Isolator DB A/10 S36766	1 P	PVC/PVC 25	B MF	- -	- -	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.11	- -	- -
8 L123	Isolator DB A/3 S36764	1 P	S 95	B MF	- -	- -	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.11	- -	- -
9 L123	Isolator DB A/12 S36765	1 P	S 6	B MF	- -	- -	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.11	- -	- -

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	10/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	DB A/4 S36791	1	SWA	E	88	2	5	-	-	0.44	200	500	1.39	-	-
L123		P	6	6	32	80		-	-	-	200	NA	0.55	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	04/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables
 Length Unknown
 SWA 6 mm²

Internal Rating
 IP2X

DB A/4 1st Floor Merlin Exhibition
Hager Distribution Board RCD TP&N 12 ways (total)
RCD Details BS (EN) 61008 100 A 100 mA 2 pole
Test Results 1x 44 ms 5x 17 ms
Test Button Fail Asset No. S36791

Earthing Arrangements
 PFC 0.82 kA
 Earth Loop 0.55 Ohms
 PVC Singles, 6 mm²


Supplied From IS DB A/4 1L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Power Radar Monitor & Ceiling	2	T+E	C	60898	B	0.4	-	-	0.13	200	500	2.18	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.68	-	-
1	Power End Pod TV Monitor	1	T+E	C	60898	B	0.4	-	-	0.40	200	500	2.18	-	-
L2		P	2.5	1.5	16	10		-	-	-	200	NA	0.25	-	-
1	Power DVD Players Below	2	T+E	B	60898	B	0.4	-	-	0.01	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.56	-	-
2	End Pod Plasma Screen	1	T+E	C	60898	B	0.4	-	-	0.11	200	500	2.18	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.66	-	-
2	Power Central Feature	4	T+E	C	60898	B	0.4	-	-	0.15	L	250	2.18	-	-
L2		P	2.5	1.5	16	10		-	-	-	1	NA	0.70	-	-
2	Bottom of Stairs DB A/21	7	SWA	E	60898	B	0.4	-	-	L	L	-	1.08	-	-
L3		L	4	2.5	32	10		-	-	-	L	NA	L	-	-
3	Lighting Sonar & Ads Pods	15	T+E	C	60898	B	0.4	-	-	0.67	L	250	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	0.01	NA	1.22	-	-
3	Lighting CCU Ring Over TV (TxS)	3	T+E	E	60898	D	0.4	-	-	0.35	L	250	0.87	-	-
L2		P	2.5	1.5	10	10		-	-	-	0.01	NA	0.90	-	-
3	Power Sonar & Ads Pods	2	T+E	C	60898	B	0.4	-	-	0.09	200	500	3.49	-	-
L3		P	2.5	1.5	10	10		-	-	-	200	NA	0.64	-	-
4	Lighting Ring Over Plasma TV (TxS)	3	T+E	E	60898	D	0.4	-	-	0.40	L	250	0.87	-	-
L1		P	2.5	1.5	10	10		-	-	-	0.01	NA	0.95	-	-
4	Lighting Central Feature	3	T+E	E	60898	D	0.4	-	-	0.23	L	250	0.87	-	-
L2		P	2.5	1.5	10	10		-	-	-	0.01	NA	0.78	-	-
4	Lighting & Power Torpedo Display	2	T+E	E	60898	B	0.4	-	-	0.27	200	500	3.49	-	-
L3		P	2.5	1.5	10	10		-	-	-	200	NA	0.82	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	27/01/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5	
			mm ²	mm ²	A	kA	s					Ω	Test Button	ms	
1	DB A/1 S36824	1	S	B	88	2	5	-	-	0.01	999	500	0.31	-	-
L123		P	25	MF	100	80		-	-	-	999	NA	0.12	-	-
1	Switch Fuse DB A/2 S36822 via DB	1	SWA	E	88	2	5	-	-	0.13	200	500	0.31	-	-
L123	A/1	P	25	CS	100	80		-	-	-	200	NA	0.24	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	27/01/2020	Multi-tester	493/21MLT		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length 1.5 metres
PVC Singles 25 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 3.88 kA
Earth Loop 0.12 Ohms
Trunking/Conduit

Supplied From IS DB/A/1 & 2 1L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Ω	mA	x5 ms
1	Old Supply - No Longer in Use	L	S	B	3871	C	0.4	-	-	-	-	-	3.49	-	-
L1		-	1.5	L	5	3		-	-	-	-	-	-	-	-
1	High Bay Lights Carrier Side	5	S	B	3871	C	0.4	-	-	1.47	L	250	1.74	-	-
L2		P	2X1.5	1.5	10	3		-	-	-	0.01	NA	1.58	-	-
1	Conservation DB A/15 S36815	1	T+E	B	3871	C	5	-	-	0.15	200	500	0.34	-	-
L3		P	6	2.5	50	3		-	-	-	200	NA	0.27	-	-
2	Old Supply - No Longer in Use	L	S	B	3871	C	0.4	-	-	-	-	-	3.49	-	-
L1		-	1.5	L	5	3		-	-	-	-	-	-	-	-
2	Spare	-	-	-	3871	C	-	-	-	-	-	-	1.74	-	-
L2		-	-	-	10	3		-	-	-	-	-	-	-	-
2	Old Supply - No Longer in Use	L	S	B	3871	C	0.4	-	-	-	-	-	1.74	-	-
L3		-	1.5	L	10	3		-	-	-	-	-	-	-	-
3	Old Supply - No Longer in Use	L	S	B	3871	C	0.4	-	-	-	-	-	3.49	-	-
L1		-	1.5	L	5	3		-	-	-	-	-	-	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-		-	-	-	-	-	-	-	-
3	High Bay Lights Dennis White Gallery	5	S	B	3871	C	0.4	-	-	1.52	L	250	1.74	-	-
L3		P	2X1.5	1.5	10	3		-	-	-	0.01	NA	1.63	-	-
4	Old Supply - No Longer in Use	L	S	B	3871	C	0.4	-	-	-	-	-	3.49	-	-
L1		-	1.5	L	5	3		-	-	-	-	-	-	-	-
4	Spare	-	-	-	3871	C	-	-	-	-	-	-	1.74	-	-
L2		-	-	-	10	3		-	-	-	-	-	-	-	-
4	Old Supply - No Longer in Use	L	S	B	3871	C	0.4	-	-	-	-	-	1.74	-	-
L3		-	1.5	L	10	3		-	-	-	-	-	-	-	-
5	DB A/17 Korea S36811	1	S	B	3871	C	5	1.86	-	0.32	200	500	0.57	-	-
L1		P	2X2.5	L	30	3		-	-	-	200	NA	0.44	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
5	Spare	-	-	-	3871	C	-	-	-	-	-	0.57	-	-	
L2		-	-	-	30	3	-	-	-	-	-	-	-	-	
5	Socket by Door to Coastguard Rescue	L	S	B	3871	C	0.4	2.04	L	0.54	0.01	250	0.57	-	
L3		P	2X2.5	L	30	3	-	L	-	-	0.01	NA	0.63	-	
6	High Bay Lights Duer Martlett	L	S	B	3871	C	0.4	L	L	L	200	500	0.57	-	
L1		L	2X2.5	1.5	30	3	-	L	-	-	200	NA	L	-	
6	High Bay Lights	4	S	B	3871	C	0.4	-	-	1.02	L	250	1.16	-	
L2		P	2.5	L	15	3	-	-	-	-	0.01	NA	1.13	-	
6	High Bay Lights Upper Battle Atlantic	4	S	B	3871	C	0.4	-	-	1.02	L	250	0.57	-	
L3		P	2.5	1.5	30	3	-	-	-	-	0.01	NA	1.58	-	
7	Old Supply - No Longer in Use	L	S	B	3871	C	0.4	-	-	-	-	-	1.16	-	
L1		-	2.5	L	15	3	-	-	-	-	-	-	-	-	
7	Spare	-	-	-	3871	C	-	-	-	-	-	-	0.57	-	
L2		-	-	-	30	3	-	-	-	-	-	-	-	-	
7	Sockets Pillars Opposite	3	S	B	3871	C	0.4	0.80	-	0.22	200	500	0.57	-	
L3		P	2X2.5	MF	30	3	-	0.80	-	-	200	NA	0.34	-	
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	
8	Wren DB A/14/RCD T44664	1	SWA	E	3871	-	5	-	-	0.01	200	500	0.57	-	
L3		P	6	6	30	-	-	-	-	-	200	NA	0.13	-	
9	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	
10	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	
11	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	
12	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	20/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
								Ω	Ω	Ω		Ω	Test Button	ms	
1	Sockets this Wall	2	T+E	B	60898	B	0.4	0.11	0.18	0.06	200	500	1.08	-	-
L3		P	2X2.5	2X1.5	32	6		0.11		-	200	NA	0.33	-	-
2	Sockets other Walls	5	T+E	B	60898	B	0.4	0.30	0.45	0.21	200	500	1.08	-	-
L3		P	2X2.5	2X1.5	32	6		0.30		-	200	NA	0.48	-	-
3	Radial in Store	9	T+E	B	60898	B	0.4	-	-	0.22	200	500	1.74	-	-
L3		P	2.5	1.5	20	6		-	-	-	200	NA	0.49	-	-
4	Office Lights	16	T+E	B	60898	B	0.4	-	-	0.47	L	250	5.82	-	-
L3		P	1.5	1.5	6	6		-	-	-	0.01	NA	0.74	-	-
5	Store Lights	11	T+E	B	60898	B	0.4	-	-	1.13	L	250	5.82	-	-
L3		P	1.5	1.5	6	6		-	-	-	0.01	NA	1.40	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	30/01/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 PVC Singles 6 mm²

Internal Rating

Not IP2X

DB A/17 Carrier Exhibition Korea End
Crabtree Distribution Board RCD SP&N L1 phase 6 ways
RCD Details BS (EN) 4293 100 A 30 mA 2 pole
Test Results 1x 38 ms 5x 13 ms
Test Button Pass Asset No. S36811

Earthing Arrangements

PFC 0.52 kA
 Earth Loop 0.44 Ohms
 Integral C.P.C., 2.5 mm²


Supplied From DB A/1 5L1
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Spare	-	-	-	3871	1	-	-	-	-	-	7.28	30	-	
L1		-	-	-	6	6	-	-	-	-	-	-	-	-	
2	Spare	-	-	-	3871	1	-	-	-	-	-	7.28	30	-	
L1		-	-	-	6	6	-	-	-	-	-	-	-	-	
3	Korea Hut	L	FLEX	E	3871	1	0.4	-	-	0.95	L	250	7.28	30	
L1		P	1.5	1.5	6	6	-	-	-	-	0.01	NA	0.83	-	
4	Track Lighting Far	2	FLEX	E	3871	1	0.4	-	-	0.43	200	500	2.18	30	
L1		P	1.5	1.5	20	6	-	-	-	-	200	NA	0.87	-	
5	Track Lighting Middle	2	FLEX	E	3871	1	0.4	-	-	0.24	200	500	2.18	30	
L1		P	1.5	1.5	20	6	-	-	-	-	200	NA	0.68	-	
6	Track Lighting Near	2	FLEX	E	3871	1	0.4	-	-	0.21	200	500	1.36	30	
L1		P	1.5	1.5	32	6	-	-	-	-	200	NA	0.65	-	

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		31/01/2020	Multi-tester		493/21MLT			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
											AFDD Function	Ω	Test Button	ms	
1	Wrens Gallery Cupboard T44663	1	SWA	E	61009	B	5	-	-	0.06	200	500	1.08	30	23.7
L3		P	6	6	32	6		-	-	-	200	NA	0.17	P	23.7

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		22/01/2020	Multi-tester		493/21MLT			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	Floor Sockets	1	S	B	60898	B	0.4	-	-	0.70	999	250	2.16	-	-
L3		P	2.5	1.5	16	6		-	-	-	999	NA	0.87	-	-
2	Lighting Track/Sockets	-	S	B	60898	C	0.4	-	-	0.84	L	250	2.97	-	-
L3		P	1.5	1.5	6	10		-	-	-	0.01	NA	1.01	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	22/01/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
											AFDD Function	Ω	Test Button	ms	
1	DB A/2 S36823	1	SWA	A	L	L	5	-	-	0.02	200	500	L	-	-
L2		P	16	CS	L	L		-	-	-	200	NA	0.26	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		10/02/2020	Multi-tester		493/21MLT			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
											AFDD Function	Ω	Test Button	ms	
1	LHS Radial & CCTV	L P	T+E 2.5	B 1.5	3871 20	1 3	0.4	- -	- -	0.78 -	L 0.40	250 NA	2.18 1.04	- -	- -
2	RHS Radial	L P	T+E 2.5	B 1.5	3871 20	1 3	0.4	- -	- -	0.75 -	200 200	250 NA	2.18 1.01	- -	- -
3	Eye Ball Lights	12 P	T+E 1.5	B 1	3871 6	1 3	0.4	- -	- -	L -	L 0.01	250 NA	7.28 L	- -	- -
4	LHS Fluorescents	3 P	T+E 1.5	B 1	3871 6	1 3	0.4	- -	- -	0.94 -	L 0.01	250 NA	7.28 1.10	- -	- -
5	RHS Fluorescents	3 P	T+E 1.5	B 1	3871 6	1 3	0.4	- -	- -	0.99 -	L 0.01	250 NA	7.28 1.25	- -	- -
6	Emergency Lights	6 P	T+E 1.5	B 1	3871 6	1 3	0.4	- -	- -	0.62 -	L 0.01	250 NA	7.28 0.88	- -	- -

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		20/02/2020	Multi-tester		493/21MLT			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	S36789 DB A/7, S36790 I52/DB A/5 L123	2 P	S 16	B MF	88 63	2 80	5	- -	- -	0.13 -	200 200	500 -	0.62 0.24	- -	- -

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	04/02/2020	Multi-tester	493/21MLT		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
PVC Singles 16 mm²

Internal Rating

Unknown



Earthing Arrangements

PFC 2 kA
Earth Loop 0.23 Ohms
Trunking/Conduit

Supplied From IS DB/A/5 & 7 1L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Z _s	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Emergency Lights Hall 2	4	T+E	B	3871	C	0.4	-	-	0.31	L	250	1.74	-	-
L1		P	2X1.5	2X1	10	3		-	-	-	0.01	NA	0.54	-	-
1	Lights in Cupboard	3	T+E	C	3871	C	0.4	-	-	0.38	L	250	1.74	-	-
L2		P	1.5	1	10	3		-	-	-	1.0	NA	0.61	-	-
1	Unidentified	L	T+E	L	3871	C	0.4	-	-	L	L	-	1.16	-	-
L3		L	2.5	1.5	15	3		-	-	-	L	NA	L	-	-
2	Emergency Lights in CM Rm/Library	L	T+E	B	3871	C	0.4	-	-	0.75	L	250	1.74	-	-
L1		L	1.5	1	10	3		-	-	-	0.01	NA	0.98	-	-
2	Single Socket Rm 28	1	T+E	B	3871	C	0.4	-	-	0.16	200	-	1.16	-	-
L2		P	2.5	1.5	15	3		-	-	-	200	NA	0.39	-	-
2	Spare	-	-	-	3871	C	-	-	-	-	-	-	0.34	-	-
L3		-	-	-	50	3		-	-	-	-	-	-	-	-
3	Lights Far End Library	17	T+E	B	3871	C	0.4	-	-	1.40	L	250	1.74	-	-
L1		P	1.5	1	10	3		-	-	-	0.01	NA	1.63	-	-
3	TV Socket via Switch Below	1	T+E	C	3871	C	0.4	-	-	0.18	200	500	1.16	-	-
L2		P	2.5	1.5	15	3		-	-	-	200	NA	0.41	-	-
3	Unidentified	L	T+E	B	3871	C	0.4	-	-	L	L	-	1.16	-	-
L3		L	2.5	1.5	15	3		-	-	-	L	NA	L	-	-
4	Sockets Library Soffan Rm & Top of Library	4	T+E	B	3871	C	0.4	0.27	0.60	0.36	200	500	0.57	-	-
L1		P	2X2.5	2X1.5	30	3		0.27	-	-	200	NA	0.59	-	-
4	Sockets Corridor & Acquisition Rm	4	T+E	B	3871	C	0.4	L	L	0.60	200	500	0.57	-	-
L2		P	2X2.5	2X1.5	30	3		L	-	-	200	NA	0.83	-	-
4	Unidentified	L	T+E	B	3871	C	0.4	-	-	L	L	-	1.16	-	-
L3		L	2.5	1.5	15	3		-	-	-	L	NA	L	-	-
5	Unidentified	L	T+E	L	3871	C	0.4	-	-	L	L	-	1.16	-	-
L1		L	2.5	1.5	15	3		-	-	-	L	NA	L	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
5	Unidentified	L	T+E	L	3871	C	0.4	-	-	L	L	-	1.16	-	-
L2		L	2.5	1.5	15	3		-	-	-	L	NA	L	-	-
5	Double Socket Far End of Library	1	T+E	B	3871	C	0.4	-	-	0.72	200	500	1.16	-	-
L3		P	2.5	1.5	15	3		-	-	-	200	NA	0.98	-	-
6	Heater Point Room 118	1	T+E	A	3871	C	0.4	-	-	0.08	200	500	0.57	-	-
L1		P	2.5	1.5	30	3		-	-	-	200	NA	0.31	-	-
6	Heater Point Room 118	1	T+E	A	3871	C	0.4	-	-	0.46	200	500	0.57	-	-
L1		P	2.5	1.5	30	3		-	-	-	200	NA	0.69	-	-
6	Sockets Room 28	L	T+E	L	3871	C	0.4	-	-	L	200	500	0.57	-	-
L1		L	2.5	1.5	30	3		-	-	-	200	NA	L	-	-
6	Socket Room 28	2	T+E	B	3871	C	0.4	-	-	0.12	200	500	0.87	-	-
L2		P	2.5	1.5	20	3		-	-	-	200	NA	0.35	-	-
6	4 Board DB A/16 T44667	1	T+E	B	3871	C	0.4	-	-	0.29	200	500	1.16	-	-
L3		P	2.5	1.5	15	3		-	-	-	200	NA	0.52	-	-
7	Unidentified	L	T+E	B	3871	C	0.4	-	-	L	L	-	1.16	-	-
L1		L	2.5	1.5	15	3		-	-	-	L	NA	L	-	-
7	Single Socket by Right of Room 120	1	T+E	B	3871	C	0.4	-	-	0.22	200	500	1.16	-	-
L2		P	2.5	1.5	15	3		-	-	-	200	NA	0.45	-	-
7	Double Socket on Beam to Right	1	T+E	B	3871	C	0.4	-	-	0.14	200	500	0.87	-	-
L3		P	2.5	1.5	20	3		-	-	-	200	NA	0.37	-	-
8	Spare	-	-	-	3871	C	-	-	-	-	-	-	0.57	-	-
L1		-	-	-	30	3		-	-	-	-	-	-	-	-
8	Power Curators Room 120 & Extract Fan	6	T+E	B	3871	C	0.4	0.21	0.33	0.20	200	500	0.57	-	-
L2		P	2X2.5	2X1.5	30	3		0.21		-	200	NA	0.43	-	-
8	Lights Curators Room 120 & Em	5	T+E	B	3871	C	0.4	-	-	0.23	L	250	3.49	-	-
L3		P	1.5	1.5	5	3		-	-	-	0.01	NA	0.46	-	-

Tested By

Test Date

Instrument Type

Serial No

Instrument Type

Serial No


P Anderson

04/02/2020

Multi-tester

493/21MLT

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating	x1
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	Socket Below	1	T+E	C	60898	B	0.4	-	-	0.01	200	500	2.18	-	-
L3		P	2.5	1.5	16	3		-	-	-	200	NA	0.53	-	-
2	Spare	-	-	-	60898	B	-	-	-	-	-	-	2.18	-	-
L3		-	-	-	16	3		-	-	-	-	-	-	-	-
3	Feed to Lighting L/H/S	1	T+E	C	60898	B	0.4	-	-	0.01	200	500	5.82	-	-
L3		P	1.5	1	6	3		-	-	-	200	NA	0.53	-	-
4	Lights	2	T+E	C	60898	B	0.4	-	-	1.34	L	250	5.82	-	-
L3		P	1.5	1	6	6		-	-	-	0.01	NA	1.86	-	-
5	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-	-
L3		-	-	-	6	10		-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	20/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	DB A/5 S38796	1	SWA	E	88	2	5	-	-	0.08	200	500	0.62	-	-
L123		P	10	10	63	80		-	-	-	200	NA	0.32	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		03/02/2020	Multi-tester		493/21MLT			


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 10 mm²

Internal Rating

IP2X



Earthing Arrangements

PFC 1.45 kA
 Earth Loop 0.32 Ohms
 Integral C.P.C., 10 mm²

Supplied From 152 DB A/5 1L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	V	Ω	mA	ms
1	Sockets this Rm & End Office	5	T+E	B	60898	B	0.4	0.49	-	0.81	L	250	1.08	-	-
L1		P	2X2.5	2X1.5	32	10		0.49	-	-	0.01	NA	0.51	-	-
1	Lights Under Ramp & End of Library & Emergency Lts	10	T+E	B	60898	B	0.4	-	-	0.92	L	250	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	0.01	NA	1.24	-	-
1	Lights this Room & End Office	18	T+E	B	60898	B	0.4	-	-	0.36	L	250	3.49	-	-
L3		P	2X1.5	2X1.5	10	10		-	-	-	0.01	NA	0.68	-	-
2	Computer Sockets this Rm & End Rm	11	T+E	B	60898	B	0.4	0.86	-	1.14	200	500	1.08	-	-
L1		P	2X2.5	2X1.5	32	10		0.85	-	-	200	NA	0.80	-	-
2	Sockets Retail Manager	L	T+E	B	60898	B	0.4	L	L	0.27	200	500	1.08	-	-
L2		P	2X2.5	2X1.5	32	10		L	-	-	200	NA	0.59	-	-
2	Lights Retail Managers Office	4	T+E	B	60898	B	0.4	-	-	0.99	L	250	5.82	-	-
L3		P	2X1.5	2X1	6	10		-	-	-	0.01	NA	1.31	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Sockets SOFs	3	T+E	B	60898	B	0.4	-	-	0.21	200	500	1.74	-	-
L2		P	2.5	1.5	20	10		-	-	-	200	NA	0.53	-	-
3	Unidentified	L	T+E	B	60898	B	0.4	-	-	L	200	250	1.74	-	-
L3		L	2.5	1.5	20	10		-	-	-	200	NA	L	-	-
4	Unidentified	L	T+E	B	60898	B	0.4	-	-	L	200	250	1.74	-	-
L1		L	2.5	1.5	20	10		-	-	-	200	NA	L	-	-
4	Unidentified	L	T+E	B	60898	B	0.4	-	-	L	200	250	1.74	-	-
L2		L	2.5	1.5	20	10		-	-	-	200	NA	L	-	-
4	Feed to Time Clock	1	T+E	B	60898	B	0.4	-	-	0.06	200	500	5.82	-	-
L3		P	2.5	1.5	6	10		-	-	-	200	NA	0.38	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
5	Em Lights in this Office	4	T+E	B	60898	B	0.4	-	-	0.68	L	250	5.82	-	-
L2		P	2X1.5	2X1	6	10		-	-	-	0.01	NA	1.00	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
6	Lights Study & End of Library	8	T+E	B	60898	B	0.4	-	-	0.33	L	250	3.49	-	-
L1		P	2.5	1.5	10	10		-	-	-	0.01	NA	0.65	-	-
6	Office L/H/S & Emergency Lights	12	T+E	E	60898	B	0.4	-	-	0.24	L	250	2.18	-	-
L2	26/27	P	2.5	1.5	16	10		-	-	-	0.01	NA	0.56	-	-
6	Lights Research Room	3	T+E	B	60898	B	0.4	-	-	0.21	L	250	5.82	-	-
L3		P	1.5	1	6	10		-	-	-	0.01	NA	0.53	-	-
7	Data Network Socket	1	T+E	B	60898	D	0.4	-	-	0.21	200	500	0.54	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.53	-	-
7	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
7	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	03/02/2020	Multi-tester	493/21MLT		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length 1 metre
PVC/PVC Tails 25 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 4.16 kA
Earth Loop 0.11 Ohms
PVC Singles, 16 mm²

Supplied From Sub A /BB 4L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
1	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	Emergency Lighting Switch Room, Kamikaze	3	S	B	3871	C	0.4	-	-	0.27	200	250	1.74	-	-
L2		P	1.5	1.5	10	3		-	-	-	200	NA	0.38	-	-
2	Kamikaze Model Ship & Above	2	S	B	3871	C	0.4	-	-	1.20	L	250	1.74	-	-
L3		P	1.5	1.5	10	3		-	-	-	0.01	NA	1.31	-	-
3	Lights Top of Stairs Viewing Gallery	6	S	B	3871	2	0.4	-	-	1.11	L	250	4.99	-	-
L1	Merlin Area	P	2X1.5	2X1.5	5	3		-	-	-	0.01	NA	1.22	-	-
3	Strip Lights Top Floor	10	S	B	3871	2	0.4	-	-	1.09	L	250	2.49	-	-
L2		P	1.5	1.5	10	3		-	-	-	0.01	NA	1.20	-	-
3	Lights Emergency Stairwell	L	S	B	3871	2	0.4	-	-	0.72	L	250	4.99	-	-
L3		L	2X1.5	2X1.5	5	3		-	-	-	0.01	NA	0.83	-	-
4	High Level Sockets Viewing Area	3	S	B	3871	2	0.4	-	-	0.77	200	500	1.24	-	-
L1		P	2.5	2.5	20	3		-	-	-	200	NA	0.88	-	-
4	Sockets Switch Room & Rear Lights	14	FLEX	C	3871	2	0.4	-	-	1.70	L	250	1.24	-	-
L2	Bays 3, 4 & 5	P	2.5	2.5	20	3		-	-	-	0.01	NA	1.81	-	-
4	Sockets Bay 2 Ground Floor	2	S	B	3871	2	0.4	-	-	0.92	200	500	1.24	-	-
L3		P	2.5	2.5	20	3		-	-	-	200	NA	1.03	-	-
5	Socket Bay 6 Ground Floor	1	S	B	3871	2	0.4	-	-	0.35	200	500	1.24	-	-
L1		P	2.5	2.5	20	3		-	-	-	200	NA	0.66	-	-
5	Socket Bay 4 & 5 Ground Floor	4	S	B	3871	2	0.4	-	-	0.53	200	500	1.24	-	-
L2		P	2.5	2.5	20	3		-	-	-	200	NA	0.64	-	-
5	Brush With War Lights Con End	3	S	B	3871	2	0.4	-	-	0.15	200	500	1.24	-	-
L3	Sockets	P	2.5	2.5	20	3		-	-	-	200	NA	0.26	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No Ø	Designation	Points Served Polarity	Wiring Phase mm ²	Method CPC mm ²	BS No Rating A		Type Rating kA	r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ		Test Voltage AFDD Function	Max Z s Zs Ω
6 L123	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -
7 L1	Projector Spur Opposite	1 P	T+E 2.5	C 1.5	3871 10	2 3	0.4	- -	- -	0.13 -	200 200	500 NA	2.49 0.24	- -
7 L2	Spare	- -	- -	- -	3871 5	2 3	-	- -	- -	- -	- -	- -	4.99 -	- -
7 L3	Lights Sodium Bay 1,2,3	3 L	S 1.5	B 1.5	3871 10	2 3	0.4	- -	- -	L -	L 0.01	250 NA	2.49 L	- -
8 L1	Lights Sodium Bay 4,5,6	3 L	S 1.5	B 1.5	3871 10	2 3	0.4	- -	- -	L -	L 0.01	250 NA	2.49 L	- -
8 L2	Not Found	L L	S 1.5	B 1.5	3871 5	2 3	0.4	- -	- -	L -	L 200	250 NA	4.99 L	- -
8 L3	Rear Row Strip Lights 1st Floor	10 P	S 1.5	B 1.5	3871 10	2 3	0.4	- -	- -	1.11 -	L 0.01	250 NA	2.49 1.22	- -
9 L1	Not Found	L L	S 1.5	B 1.5	3871 5	2 3	0.4	- -	- -	L -	L 200	250 NA	4.99 L	- -
9 L2	Fire Exit Door CCTV Merlin	2 L	S 2.5	B 2.5	3871 20	2 3	0.4	- -	- -	L -	L 0.01	250 NA	1.24 L	- -
9 L3	Not Found	L L	S 2.5	B 2.5	3871 20	2 3	0.4	- -	- -	L -	L 200	250 NA	1.24 L	- -
10 L1	Sockets Bay 4,5,6 1st Floor	3 P	S 2.5	B 2.5	3871 20	2 3	0.4	- -	- -	0.45 -	200 200	500 NA	1.24 0.56	- -
10 L2	Sockets Bay 1 Ground Floor	1 P	S 2.5	B 2.5	3871 20	2 3	0.4	- -	- -	0.43 -	200 200	500 NA	1.24 0.54	- -
10 L3	Sockets Bay 3 Ground Floor	2 P	S 2.5	B 2.5	3871 20	2 3	0.4	- -	- -	0.55 -	200 200	500 NA	1.24 0.66	- -

Tested By

Test Date

Instrument Type

Serial No

Instrument Type

Serial No


P Anderson

05/02/2020

Multi-tester

493/21MLT

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	DB A/8 S36768	1	S	B	88	2	5	-	-	0.01	L	250	0.62	-	-
L123		P	16	MF	63	80		-	-	-	0.01	NA	0.12	-	-
1	DB A/9 S36769 via DB A/8 Main	1	PVC/PVC	B	88	2	5	-	-	0.01	L	250	0.62	-	-
L123	Switch	P	16	MF	63	80		-	-	-	0.01	NA	0.12	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	24/01/2020	Multi-tester	493/21MLT		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
PVC Singles 25 mm²

Internal Rating

IP2X



Earthing Arrangements

PFC 3.4 kA
Earth Loop 0.12 Ohms
Cable Sheath

Supplied From Workshop DB1-1 1-2 Isolator 1L123 via Meter R/H/S
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Ω	mA	x5 ms
1	Unidentified	L	S	B	3871	2	0.4	-	-	L	L	500	1.24	-	-
L1		L	2.5	1.5	20	3		-	-	-	999	NA	L	-	-
1	Lighting Track Harvard III	1	S	B	3871	2	0.4	-	-	0.24	L	500	1.24	-	-
L2		P	2.5	2.5	20	3		-	-	-	999	NA	0.36	-	-
1	Track Light Over Emergency Exit	1	S	B	3871	2	0.4	-	-	0.55	L	500	2.49	-	-
L3		P	2.5	1.5	10	3		-	-	-	999	NA	0.67	-	-
2	Dispatch Rider Track Lights	1	S	B	3871	2	0.4	-	-	0.44	L	500	2.49	-	-
L1		P	2.5	1.5	10	3		-	-	-	999	NA	0.56	-	-
2	Track Lights Over Women in Aviation	2	S	B	3871	2	0.4	-	-	0.86	L	500	2.49	-	-
L2		P	2.5	1.5	10	3		-	-	-	999	NA	0.98	-	-
2	Lights Rear Harvard III	2	S	B	3871	2	0.4	-	-	0.79	L	500	4.99	-	-
L3		P	2.5	1.5	5	3		-	-	-	999	NA	0.91	-	-
3	Lathe No 2	1	S	B	3871	2	0.4	-	-	0.36	999	500	2.49	-	-
L123		P	2.5	1.5	10	3		-	-	-	999	NA	0.48	-	-
3	Milling Machine	1	S	B	3871	2	0.4	-	-	0.28	999	500	2.49	-	-
L123		P	2.5	1.5	10	3		-	-	-	999	NA	0.40	-	-
4	Power to Centre Bench	3	S	B	3871	2	0.4	-	-	0.32	200	500	1.24	-	-
L1		P	2.5	2.5	20	3		-	-	-	200	NA	0.44	-	-
4	Lights Window End	8	S	B	3871	2	0.4	-	-	0.40	L	500	2.49	-	-
L2		P	2.5	2.5	10	3		-	-	-	0.01	NA	0.52	-	-
4	Emergency Light Above Fire Exit	1	FLEX	E	3871	2	0.4	-	-	0.05	200	500	2.49	-	-
L2		P	1	1	10	3		-	-	-	200	NA	0.17	-	-
4	Lights Door End	6	S	B	3871	2	0.4	-	-	0.63	L	500	2.49	-	-
L3		P	2.5	2.5	10	3		-	-	-	999	NA	0.75	-	-
5	Socket R/H/S of Windows	1	S	B	3871	2	0.4	-	-	0.24	999	500	0.83	-	-
L1		P	2.5	2.5	30	3		-	-	-	999	NA	0.36	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L L/E	Test Voltage AFDD Function		Max Z s Zs	Rating mA
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Ω	Test Button	x5 ms	
5	Water Heater	1	S	B	3871	2	0.4	-	-	0.31	999	500	0.83	-	-
L1		P	2.5	2.5	30	3		-	-	-	999	NA	0.43	-	-
5	Machine Hacksaw	1	S	B	3871	2	0.4	-	-	0.33	999	500	1.66	-	-
L23		P	2.5	2.5	15	3		-	-	-	999	NA	0.45	-	-
6	Machine Hacksaw	1	S	B	3871	2	0.4	-	-	0.33	999	500	1.66	-	-
L1		P	2.5	2.5	15	3		-	-	-	999	NA	0.45	-	-
6	Unidentified	L	S	L	3871	2	0.4	-	-	L	L	500	0.49	-	-
L2		L	10	10	50	3		-	-	-	999	NA	L	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
A Robinson	24/01/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Supply Cables
 Length 1 metre
 PVC/PVC Tails 16 mm²

Internal Rating
 Not IP2X

Earthing Arrangements
 PFC 3.76 kA
 Earth Loop 0.12 Ohms
 PVC Singles, 10 mm²


Supplied From Workshop DB1-1 1-2 Isolator 1L123 via DB A/8 M/Switch
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Z _s	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Socket in Void L/H/S of WRNS 1st Floor	1	T+E	A	3871	C	0.4	-	-	0.30	999	500	3.49	-	-
L1		P	2.5	2.5	5	3		-	-	-	999	NA	0.42	-	-
1	Heater 3 via Contactor	1	S	B	3871	C	0.4	-	-	0.18	999	500	0.87	-	-
L2		P	2.5	2.5	20	3		-	-	-	999	NA	0.30	-	-
1	Heater 4 via Contactor	1	S	B	3871	C	0.4	-	-	0.08	999	500	0.87	-	-
L3		P	2.5	2.5	20	3		-	-	-	999	NA	0.20	-	-
2	Heater 2 via Contactor	1	S	B	3871	C	0.4	-	-	0.16	999	500	0.87	-	-
L1		P	2.5	2.5	20	3		-	-	-	999	NA	0.28	-	-
2	Heater 1 via Contactor	1	S	B	3871	C	0.4	-	-	0.08	999	500	0.87	-	-
L2		P	2.5	2.5	20	3		-	-	-	999	NA	0.20	-	-
2	Contactor Below	1	S	B	3871	C	0.4	-	-	0.01	999	500	0.87	-	-
L3		P	2.5	2.5	2	3		-	-	-	999	NA	0.13	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Unused in Joint Box in Void Above	1	FLEX	B	3871	C	0.4	-	-	0.25	999	500	1.74	-	-
L2		P	2.5	2.5	10	3		-	-	-	999	NA	0.37	-	-
3	Bench Power R/H/S	1	S	B	3871	C	0.4	-	-	0.17	999	500	1.74	-	-
L3		P	2.5	2.5	10	5		-	-	-	999	NA	0.29	-	-
4	Spare	-	-	-	3871	C	-	-	-	-	-	-	0.57	-	-
L123		-	-	-	30	3		-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	10/02/2020	Multi-tester	493/21MLT		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	DB A/11 S36771	1	S	B	88	2	5	-	-	0.06	999	500	0.39	-	-
L123		P	16	6	63	80		-	-	-	999	NA	0.17	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	24/01/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
								Ω	Ω	Ω	MΩ	Ω	Test Button	ms	
1	Switch Fuse Above Crew Room Door L123	1	SWA 6	B CS	3871 50	2 3	0.4	-	-	0.05	999 999	500 NA	0.49 0.22	-	-
2	Office Lights Adjacent & First Aid L1	6	T+E 1.5	B 1	3871 10	2 3	0.4	-	-	0.71	L 999	250 NA	2.49 0.88	-	-
2	Spare L2	-	-	-	3871 15	2 3	-	-	-	-	-	-	1.66	-	-
2	Sockets Engineers Office, First Aid, Workshop L3	5	T+E 2X2.5	B 2X1.5	3871 30	2 3	0.4	0.51 0.51	1.46	0.33	999 999	500 NA	0.83 0.50	-	-
3	Blank L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Spare L2	-	-	-	3871 10	2 3	-	-	-	-	-	-	2.49	-	-
3	Spare L3	-	-	-	3871 15	2 3	-	-	-	-	-	-	1.66	-	-
4	Spare L1	-	-	-	3871 20	2 3	-	-	-	-	-	-	-	-	-
4	Heater Engineers Office L2	1	T+E 2.5	B 1.5	3871 15	2 3	0.4	-	-	0.17	999 999	500 NA	1.66 0.34	-	-
4	DB A/11A L3	1	T+E 10	B 4	3871 40	2 3	0.4	-	-	0.04	200 200	500 NA	0.62 0.21	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	24/01/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Sockets Mess Room Kitchen & TV	6	T+E	A	61009	B	0.4	0.24	0.39	0.14	L	250	1.08	30	18.2
L3		P	2X2.5	2X1.5	32	6		0.27		-	0.08	0.35	P	27.1	
2	Sockets Below DB R/H/S Mess Room	5	T+E	A	61009	B	0.4	0.33	0.62	0.10	L	250	2.18	30	18.9
L3		P	2.5	1.5	16	6		0.33		-	0.08	0.31	P	29.1	
3	Lights Workshop/Mess Room & Corridor	7	T+E	A	61009	B	0.4	-	-	0.45	L	250	5.82	30	18.3
L3		P	1.5	1.5	6	6		-	-	-	200	0.66	P	18.2	
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		24/01/2020	Multi-tester		493/21MLT			

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	DB A/10 S36770	1	SWA	E	3036	-	5	-	-	0.03	999	500	0.84	-	-
L123		P	16	CS	60	4		-	-	-	999	NA	0.14	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		08/11/2019	Multi-tester		493/21MLT			

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Z _s	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Isolator by Window	1	SWA	B	3871	2	0.4	-	-	0.11	999	500	0.83	-	-
L123		P	4	4	30	3		-	-	-	999	NA	0.25	-	-
2	Lathe via Switch Below	1	S	B	3871	2	0.4	-	-	0.27	999	500	1.66	-	-
L123		P	2.5	2.5	15	3		-	-	-	999	NA	0.41	-	-
3	Blue Welder (Mig) Socket Below	1	S	B	3871	2	0.4	-	-	0.01	999	500	0.62	-	-
L123		P	6	6	40	3		-	-	-	999	NA	0.15	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
6	Tig Welder	1	S	B	60898	C	5	-	-	0.01	999	500	0.27	-	-
L23		P	10	10	63	10		-	-	-	999	NA	0.15	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	08/11/2019	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	DB A/3 S36820	1	S	B	SL	-	5	-	-	0.11	200	500	L	-	-
L123		P	120	MF	-	-		-	-	-	200	NA	0.22	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		26/02/2020	Multi-tester		493/21MLT			


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 PVC Singles 120 mm²

Internal Rating

IP2X



Earthing Arrangements

PFC 2.08 kA
 Earth Loop 0.22 Ohms
 Trunking/Conduit

Supplied From IS DB A/3 1L123
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
1 L1	Hut 4 Nut on Door & Warnford Lights Switch 1/2	5 P	T+E 1.5	B 1	60898 10	C 10	0.4	- -	- -	0.81 -	L 0.01	250 NA	1.74 1.03	- -	- -
1 L2	Lights via Switch 3/4	3 P	S 1.5	B 1.5	60898 10	C 10	0.4	- -	- -	0.24 -	L 0.01	250 NA	1.74 0.45	- -	- -
1 L3	Lights via Switch 5/6	6 P	S 1.5	B 1.5	60898 10	C 10	0.4	- -	- -	0.54 -	L 0.01	250 NA	1.74 0.75	- -	- -
2 L1	Lights Gallery Switch 7/8	10 P	T+E 1.5	B 1	60898 10	C 10	0.4	- -	- -	0.58 -	L 0.01	250 NA	1.74 0.79	- -	- -
2 L2	Gallery Track Lights SW 9/10 & Ramp Area Sockets	21 P	T+E 1.5	B 1	60898 10	C 10	0.4	- -	- -	1.58 -	L 0.01	250 NA	1.74 1.79	- -	- -
2 L3	High Level Hall 1 & High Sockets Switch 11/12	21 P	S 1.5	B 1.5	60898 16	C 10	0.4	- -	- -	0.39 -	L 0.01	250 NA	1.08 0.51	- -	- -
3 L1	High Level Hall 1 Switch 13/14	3 P	T+E 1.5	B 1	60898 10	C 10	0.4	- -	- -	1.68 -	L 0.01	250 NA	1.74 1.90	- -	- -
3 L2	High Level Hall 1 Switch 15/16	4 P	T+E 1.5	B L	60898 10	C 10	0.4	- -	- -	L -	L 0.01	250 NA	1.74 1.38	- -	- -
3 L3	High Level Hall 1 Switch 17/18	6 P	L 1.5	B L	60898 10	C 10	0.4	- -	- -	1.32 -	L 0.01	250 NA	1.74 1.54	- -	- -
4 L1	High Level Hall 1 Switch 19/20	4 P	T+E 1.5	B L	60898 10	C 10	0.4	- -	- -	1.37 -	L 0.01	250 NA	1.74 1.59	- -	- -
4 L2	Switch 21 & 22	L L	L 1.5	L L	60898 10	C 10	0.4	- -	- -	L -	L 34.5	250 NA	1.74 L	- -	- -
4 L3	Switch 23 & 24	L L	L 1.5	L L	60898 10	C 10	0.4	- -	- -	L -	200 200	250 NA	1.74 L	- -	- -
5 L1	Lights Physics of Flight SW 25/26	12 P	T+E 1.5	B 1	60898 10	C 10	0.4	- -	- -	0.38 -	L 0.01	250 NA	1.74 0.60	- -	- -

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs Ω	mA Test Button	x5 ms
5	Lights Physics of Flight SW 27/28	30	FLEX	B	60898	C	0.4	-	-	0.49	L	250	1.74	-	-
L2		P	1	1	10	10		-	-	-	0.01	NA	0.71	-	-
5	Switch 29 & 30	L	T+E	L	60898	C	0.4	-	-	L	200	250	1.74	-	-
L3		L	1.5	L	10	10		-	-	-	200	NA	0.17	-	-
6	Switch 31 & 32	L	T+E	L	60898	C	0.4	-	-	L	200	250	1.74	-	-
L1		L	1.5	L	10	10		-	-	-	200	NA	L	-	-
6	Switch 35 & 36	L	T+E	L	60898	C	0.4	-	-	L	200	250	1.74	-	-
L2		L	1.5	L	10	10		-	-	-	200	NA	L	-	-
6	Switch 37 & 38	L	T+E	L	60898	C	0.4	-	-	L	200	250	1.74	-	-
L3		L	1.5	L	10	10		-	-	-	200	NA	L	-	-
7	Switch 39 & 40	L	T+E	L	60898	C	0.4	-	-	L	200	250	1.74	-	-
L1		L	1.5	L	10	10		-	-	-	200	NA	L	-	-
7	Unidentified	L	T+E	L	60898	C	0.4	-	-	L	200	250	1.74	-	-
L2		L	1.5	L	10	10		-	-	-	200	NA	L	-	-
7	Connector Block Behind Switch 44	L	T+E	L	60898	C	0.4	-	-	L	200	500	1.74	-	-
L3		P	1.5	L	10	10		-	-	-	200	NA	0.28	-	-
8	Switch 41 & 42	L	T+E	L	60898	C	0.4	-	-	L	200	250	1.74	-	-
L1		L	1.5	L	10	10		-	-	-	200	NA	L	-	-
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
9	Hall & Warnfords Sockets via Switch L/H/S	7	T+E	A	60898	C	0.4	1.42	-	0.27	200	500	0.54	-	-
L1		P	2X2.5	MF	32	10		1.42	-	-	200	NA	0.49	-	-
9	Pillar Sockets G/F Entrance	4	S	B	60898	C	0.4	1.40	0.60	0.37	200	500	0.54	-	-
L2		P	2X2.5	2X2.5	32	10		1.40	-	-	200	NA	0.59	-	-
9	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
10	Conference DB A/18 S36797	1	SWA	E	60898	C	5	-	-	0.01	200	500	0.27	-	-
L123		P	16	CS	63	10		-	-	-	200	NA	0.22	-	-
11	Unidentified	1	T+E	L	60898	C	0.4	-	-	L	200	250	1.08	-	-
L1		L	2.5	L	16	10		-	-	-	200	NA	L	-	-
11	Physics of Flight - Unused Point L/H/S Tray	1	T+E	E	60898	C	0.4	-	-	0.48	200	500	1.08	-	-
L2		P	2.5	1.5	16	10		-	-	-	200	NA	0.70	-	-
11	Unidentified	L	T+E	L	60898	C	0.4	-	-	L	200	250	1.08	-	-
L3		L	2.5	1.5	16	10		-	-	-	200	NA	L	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
12	Physics of Flight - Projector L/H/S	1	T+E	E	60898	C	0.4	-	-	0.36	200	500	1.08	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.58	-	-
12	Physics of Flight Far L/H/S	1	T+E	E	60898	C	0.4	-	-	0.47	200	500	1.08	-	-
L2		P	2.5	1.5	16	10		-	-	-	200	NA	0.69	-	-
12	Physics of Flight Far Right Corner	1	T+E	E	60898	C	0.4	-	-	0.56	200	500	1.08	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.78	-	-
13	Physics of Flight - Projector Centre	1	T+E	E	60898	C	0.4	-	-	0.48	200	500	1.08	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.70	-	-
13	Physics of Flight - Projector R/H/S	1	T+E	E	60898	C	0.4	-	-	0.39	200	500	1.74	-	-
L2		P	2.5	1.5	10	10		-	-	-	200	NA	0.61	-	-
13	Physics of Flight Socket & Printing Room	6	T+E	B	61009	C	0.4	0.88	1.24	0.37	200	500	1667	30	38.9
L3		P	2X2.5	2X1	32	10		0.88	-	-	200	NA	0.59	P	28.8
14	Em Lights Zone 1 Gallery	6	T+E	B	60898	C	0.4	-	-	1.92	L	250	2.91	-	-
L1		P	1.5	1	6	10		-	-	-	0.01	NA	2.14	-	-
14	Em Lights Zone 2 Ramp	6	T+E	B	60898	C	0.4	-	-	2.01	L	250	2.91	-	-
L2		P	1.5	1	6	10		-	-	-	0.01	NA	2.23	-	-
14	Em Lights Zone 3 Hall 1 High Level	7	T+E	B	60898	C	0.4	-	-	1.19	L	250	2.91	-	-
L3		P	1.5	1	6	10		-	-	-	0.01	NA	1.41	-	-
15	Information via Switch L/H/S	1	FLEX	E	60898	C	0.4	-	-	0.33	200	250	2.91	-	-
L1		P	1.5	1.5	6	10		-	-	-	200	NA	0.55	-	-
15	Spare	-	-	-	60898	C	-	-	-	-	-	-	2.91	-	-
L2		-	-	-	6	10		-	-	-	-	-	-	-	-
15	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
16	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
16	Learning Centre DB A/20 S36838	1	SWA	E	60898	B	5	-	-	0.06	200	500	0.55	-	-
L2		P	10	10	63	10		-	-	-	200	NA	0.28	-	-
16	Account Office DB A/19 T44669	1	T+E	E	60898	C	5	-	-	0.09	200	500	0.43	-	-
L3		P	6	2.5	40	10		-	-	-	200	NA	0.31	-	-

Tested By

Test Date

Instrument Type

Serial No

Instrument Type

Serial No

P Anderson

30/01/2020

Multi-tester

493/21MLT


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 16 mm²

Internal Rating

IP2X



Earthing Arrangements

PFC 2.06 kA
Earth Loop 0.22 Ohms
Cable Sheath

Supplied From DB A/3 10L123 via ISO R/H/S
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
											AFDD Function	Ω	Test Button	ms	
1	Auditorium Lights Contactor & Emergency Lights	3	T+E	B	60898	B	0.4	-	-	1.26	L	250	3.49	-	-
L1		P	2X1.5	2X1.5	10	10		-	-	-	0.01	NA	1.48	-	-
1	Head CS Office Alarm Panel & Socket	2	T+E	B	61009	B	0.4	-	-	0.31	200	500	2.18	30	38.8
L2		P	2.5	1.5	16	10		-	-	-	200	NA	0.53	P	28.8
1	Wall Lights	5	T+E	B	60898	B	0.4	-	-	0.77	L	250	3.49	-	-
L3		P	1.5	1	10	10		-	-	-	0.01	NA	0.99	-	-
2	Lights Auditorium 2nd Row	5	T+E	B	60898	B	0.4	-	-	0.48	L	250	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	0.01	NA	0.70	-	-
2	Sockets & Data Cab This Room	4	T+E	B	61009	B	0.4	-	-	0.04	200	500	2.18	30	38.4
L2		P	2.5	1.5	16	10		-	-	-	200	NA	0.26	P	28.6
2	Air Conditioning O/S R/H Condenser	1	SWA	B	60898	C	0.4	-	-	0.27	200	500	0.54	-	-
L3		P	4	4	32	10		-	-	-	200	NA	0.49	-	-
3	Lights Auditorium 1st Row	4	T+E	B	60898	B	0.4	-	-	0.58	L	250	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	0.01	NA	0.80	-	-
3	Air Conditioning O/S L/H Condenser	1	SWA	B	60898	C	0.4	-	-	0.31	200	500	0.54	-	-
L2		P	4	4	32	10		-	-	-	200	NA	0.53	-	-
3	DB A/22 T44666 ACC, DB A/23 T44665 Main	2	T+E	B	60898	B	5	-	-	0.52	200	500	0.87	-	-
L3		P	6	2.5	40	10		-	-	-	200	NA	0.74	-	-
4	Lights Auditorium 5th Row	6	T+E	B	60898	B	0.4	-	-	0.62	L	250	3.49	-	-
L1		P	1.5	1	10	10		-	-	-	0.01	NA	0.84	-	-
4	Projector Socket	1	T+E	B	60898	B	0.4	-	-	0.38	200	500	3.49	-	-
L2		P	2.5	1.5	10	10		-	-	-	200	NA	0.60	-	-
4	Socket on Pillar & Accounts Passageway	2	T+E	B	61009	B	0.4	0.24	0.36	0.34	200	500	1.08	30	38
L3		P	2X2.5	2X1.5	32	10		0.24	-	-	200	NA	0.56	P	28.5
5	Lights Auditorium 2nd Row	4	T+E	B	60898	B	0.4	-	-	0.70	L	250	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	0.01	NA	0.92	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Z _s Ω	mA Test Button	x5 ms
5	Socket Back Wall Auditorium	1	T+E	B	61009	B	0.4	-	-	0.23	200	500	2.18	30	38.7
L2		P	2.5	1.5	16	10		-	-	-	200	NA	0.45	P	28.7
5	Socket Between Door Auditorium	1	T+E	B	61009	B	0.4	-	-	0.13	200	500	2.18	30	38.7
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.38	P	28.7
6	Lights Auditorium 3rd Row	4	T+E	B	60898	B	0.4	-	-	0.61	L	250	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	0.01	NA	0.83	-	-
6	Lecturn Lights	2	T+E	B	60898	B	0.4	-	-	0.77	L	250	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	0.01	NA	0.99	-	-
6	Auditorium Sockets	8	T+E	B	61009	B	0.4	0.67	1.16	0.42	200	500	1.08	30	38.6
L3		P	2X2.5	2X2.5	32	10		0.67	-	-	200	NA	0.64	P	28.7

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	30/01/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L L/E		Test Voltage AFDD Function	Max Z s Zs	Rating mA Test Button
1	Sockets Finance	4	T+E	B	60898	B	0.4	0.44	0.58	0.19	200	500	1.08	-	-
L3		P	2X2.5	2X15	32	6		0.44		-	200	NA	0.57	-	-
2	Socket Computer Below	1	T+E	B	60898	B	0.4	-	-	0.02	200	500	1.74	-	-
L3		P	2.5	1.5	20	6		-	-	-	200	NA	0.40	-	-
3	Sockets Radial, Registry	5	T+E	B	60898	B	0.4	-	-	0.32	200	500	1.74	-	-
L3		P	2.5	1.5	20	6		-	-	-	200	NA	0.70	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Emergency Lights Office/Exit Door via	3	T+E	C	60898	B	0.4	-	-	0.39	L	500	5.82	-	-
L3	Spur	P	2.5	1.5	6	6		-	-	-	200	NA	0.77	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	27/01/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Z _s Ω	mA	x5 ms	
1	Sockets Managers Office	5	T+E	B	3871	3	0.4	-	-	0.44	200	500	1.75	-	-
L3		P	2.5	1.5	10	3		-	-	-	200	NA	1.18	-	-
2	Lights Managers Office	6	T+E	B	3871	3	0.4	-	-	0.41	L	250	2.91	-	-
L3		P	1.5	1	6	3		-	-	-	0.01	NA	1.15	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	27/01/2020	Multi-tester	493/21MLT		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables
 Length Unknown
 SWA 10 mm²

Internal Rating
 IP2X

DB A/20 Learning Centre
Eaton Distribution Board RCD SP&N L2 phase 10 ways
RCD Details BS (EN) 61008 100 A 30 mA 2 pole Test Results 1x 38 ms 5x 28 ms Test Button Pass Asset No. S36838

Earthing Arrangements
 PFC 0.82 kA
 Earth Loop 0.28 Ohms
 Integral C.P.C., 10 mm²


Supplied From DB A/3 16L2
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Sockets Dado	10	S	B	60898	B	0.4	0.30	0.42	0.11	200	500	1.08	-	-
L3		P	2X2.5	2X2.5	32	10		0.32		-	200	NA	0.39	-	-
2	Computer Sockets Back Wall	6	S	B	60898	B	0.4	-	-	0.32	200	500	1.74	-	-
L3		P	2.5	2.5	20	10		-	-	-	200	NA	0.60	-	-
3	Ceiling Sockets Near	1	S	B	60898	B	0.4	-	-	0.17	200	500	1.74	-	-
L3		P	2.5	2.5	20	10		-	-	-	200	NA	0.45	-	-
3	Ceiling Sockets Far	1	S	B	60898	B	0.4	-	-	0.21	200	500	1.74	-	-
L3		P	2.5	2.5	20	10		-	-	-	200	NA	0.49	-	-
4	Cupboard & Outside Sockets	3	T+E	B	60898	B	0.4	-	-	0.27	200	500	1.74	-	-
L3		P	2.5	2.5	20	10		-	-	-	200	NA	0.55	-	-
5	Projector Socket via Switch	1	S	B	60898	B	0.4	-	-	0.20	200	500	2.18	-	-
L3		P	2.5	2.5	16	10		-	-	-	200	NA	0.48	-	-
6	Socket Above Dist Board	2	S	B	60898	B	0.4	-	-	0.03	200	500	2.18	-	-
L3		P	2.5	2.5	16	10		-	-	-	200	NA	0.31	-	-
7	Lights No 1	3	S	B	60898	B	0.4	-	-	0.24	L	250	5.82	-	-
L3		P	1.5	1.5	6	10		-	-	-	0.01	NA	0.52	-	-
8	Lights No 2	3	S	B	60898	B	0.4	-	-	0.32	L	250	5.82	-	-
L3		P	1.5	1.5	6	10		-	-	-	0.01	NA	0.60	-	-
9	Lights No 3	3	S	B	60898	B	0.4	-	-	0.50	L	250	5.82	-	-
L3		P	1.5	1.5	6	10		-	-	-	0.01	NA	0.78	-	-
10	Cupboard Lights	3	S	B	60898	B	0.4	-	-	0.68	L	250	5.82	-	-
L3		P	1.5	1.5	6	10		-	-	-	0.01	NA	0.96	-	-
10	Emergency Lights	4	S	B	60898	B	0.4	-	-	0.76	L	250	5.82	-	-
L3		P	1.5	1.5	6	10		-	-	-	0.01	NA	1.04	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	28/01/2020	Multi-tester	493/21MLT		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
1	Unidentified	L	T+E	L	60898	B	0.4	-	-	L	L	250	1.74	-	-
L3		L	2.5	1.5	20	6		-	-	-	83	NA	L	-	-
2	Sockets Room & Server	2	T+E	A	60898	B	0.4	0.06	0.38	0.04	200	500	2.18	-	-
L3		P	2X2.5	2X1.5	16	6		0.06	-	-	200	NA	0.35	-	-
3	Bridge Lights & Connector Joint in Room 4	L	T+E	A	60898	C	0.4	-	-	0.36	L	250	2.91	-	-
L3		L	1	1	6	6		-	-	-	0.14	NA	0.67	-	-
4	Lights Offices, Shop, CCTV	B	T+E	A	60898	B	0.4	-	-	0.64	L	250	3.40	-	-
L3		P	1	1	10	6		-	-	-	0.01	NA	0.95	-	-
5	Fire Alarm Panel Room 4	1	T+E	A	60898	B	0.4	-	-	0.38	200	500	5.82	-	-
L3		P	1.5	1	6	6		-	-	-	200	NA	0.69	-	-
6	Unidentified	L	T+E	L	60898	B	0.4	-	-	L	200	500	11.6	-	-
L3		L	1.5	1	3	6		-	-	-	200	NA	L	-	-
0	RCD for Circuits 7 & 8	-	-	-	-	-	-	-	-	-	-	-	-	30	20.4
		-	-	-	-	-	-	-	-	-	-	-	-	P	7.39
7	Sockets Far Point This Room, Next Room Opp, Server	4	T+E	A	60898	B	0.4	L	L	0.32	200	500	1.08	-	-
L3		P	2X2.5	2X1.5	32	6		L	-	-	200	NA	0.63	-	-
8	Sockets Information Office	13	T+E	A	60898	B	0.4	0.42	0.70	0.47	200	500	1.08	-	-
L3		P	2X2.5	2X1.5	32	6		0.44	-	-	200	NA	0.78	-	-
9	Bridge Lights Contactor	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	NA	-	-	-
10	Bridge Lights Contactor	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	NA	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	28/01/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs Ω	mA	x5 ms
1	DB A/12 T44638	1	SWA	E	L	L	5	-	-	0.07	200	500	L	-	-
L123		P	16	CS	L	L		-	-	-	200	NA	0.18	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	22/01/2020	Multi-tester	493/21MLT		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 16 mm²

Internal Rating

Unknown



Earthing Arrangements

PFC 2.50 kA
Earth Loop 0.18 Ohms
Cable Sheath

Supplied From IS DB A/12 1L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Socket on RSJ Above via Switch	1	S	B	3871	C	0.4	-	-	0.64	L	250	0.87	-	-
L1	Below	P	2.5	1.5	20	4.5		-	-	-	200	NA	0.82	-	-
1	Sockets 1st Floor L/H Wall via Switch	4	S	B	3871	C	0.4	-	-	0.15	L	250	0.87	-	-
L2	Below	P	2.5	1.5	20	4.5		-	-	-	0.02	NA	0.33	-	-
1	Sockets Bridge & CCTV Fulmer via	3	S	B	3871	C	0.4	-	-	0.26	L	250	0.87	-	-
L3	Switch Below	P	2.5	1.5	20	4.5		-	-	-	0.02	NA	0.44	-	-
2	Lights O/S Toilets via Switch Below	2	T+E	B	3871	C	0.4	-	-	0.65	L	250	3.49	-	-
L1		P	1.5	1	5	4.5		-	-	-	200	NA	0.83	-	-
2	Emergency Lights Toilets via Fuse	5	T+E	B	3871	C	0.4	-	-	0.93	L	250	3.49	-	-
L1	Unit R/H/S	P	1.5	1	5	4.5		-	-	-	0.01	NA	1.11	-	-
2	Lights Below Bridge via Switch Below	4	S	B	3871	C	0.4	-	-	0.38	L	250	1.74	-	-
L2		P	1.5	1.5	10	4.5		-	-	-	200	NA	0.56	-	-
2	Socket RSJ to R/H/S	1	T+E	C	3871	C	0.4	-	-	0.22	200	500	1.74	-	-
L3		P	2.5	1.5	10	4.5		-	-	-	200	NA	0.43	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Toilet Sump Pump	1	FLEX	E	3871	C	0.4	-	-	0.22	200	500	0.87	-	-
L123		P	2.5	L	20	4.5		-	-	-	200	NA	0.40	-	-
5	Unknown via Switch Below	-	-	-	3871	C	0.4	-	-	L	L	250	0.87	-	-
L1		L	-	-	20	4.5		-	-	-	200	NA	L	-	-
5	Sockets 1st Floor Balcony via Switch	4	S	B	3871	C	0.2	-	-	0.09	L	250	0.87	-	-
L2	Below	P	2.5	1.5	20	4.5		-	-	-	0.01	NA	0.27	-	-
5	DB B Toilets S36795	1	SWA	E	3871	C	5	-	-	0.08	200	500	0.28	-	-
L3		P	10	10	60	4.5		-	-	-	200	NA	0.26	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Ω	mA	x5	

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		22/01/2020	Multi-tester		493/21MLT			

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 10 mm²

Internal Rating

IP2X

DB A/13 Staff WC Hall 2
Plug in Systems Distribution Board RCD SP&N L3 phase 8 ways
RCD Details BS (EN) 4293 80 A 30 mA 2 pole Test Results 1x 24 ms 5x 10 ms Test Button Pass Asset No. S36795

Earthing Arrangements

PFC 0.88 kA
 Earth Loop 0.26 Ohms
 Integral C.P.C., 10 mm²

Supplied From DB A/12 5L3
Secondary Supply None

Circuit Schedule and Test Results


CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Shower	1	T+E	A	3871	B	0.4	-	-	1.02	200	500	0.77	-	-
L3		P	6	2.5	32	6		-	-	-	200	NA	0.42	-	-
2	Hand Dryer Ladies & Spur	2	T+E	A	3871	B	0.4	-	-	0.26	200	500	1.24	-	-
L3		P	2.5	1.5	20	6		-	-	-	200	NA	0.44	-	-
2	Hand Dryer Staff WC	1	T+E	A	3871	B	0.4	-	-	0.20	200	500	1.24	-	-
L3		P	2.5	1.5	20	6		-	-	-	200	NA	0.46	-	-
3	Hand Dryer Gents & Spur	2	T+E	A	3871	B	0.4	-	-	0.22	200	500	1.24	-	-
L3		P	2.5	1.5	20	6		-	-	-	200	NA	0.53	-	-
3	Hand Dryer Disabled & Alarm	1	T+E	A	3871	B	0.4	-	-	0.18	200	500	1.24	-	-
L3		P	2.5	1.5	20	6		-	-	-	200	NA	0.44	-	-
4	Water Heater Gents	1	T+E	A	3871	B	0.4	-	-	0.21	200	500	1.56	-	-
L3		P	2.5	1.5	16	6		-	-	-	200	NA	0.50	-	-
5	Water Heater Ladies	1	T+E	A	3871	B	0.4	-	-	0.18	200	500	1.56	-	-
L3		P	2.5	1.5	16	6		-	-	-	200	NA	0.46	-	-
6	Socket Behind DB	L	T+E	A	3871	B	0.4	-	-	L	200	500	1.56	-	-
L3		P	2.5	1.5	16	6		-	-	-	200	NA	0.38	-	-
7	Anti Frost Heaters	5	T+E	A	3871	B	0.4	-	-	0.68	200	500	4.16	-	-
L3		P	1.5	1.5	6	6		-	-	-	200	NA	0.87	-	-
8	Lights & Fans	12	T+E	A	3871	B	0.4	-	-	0.97	L	500	4.16	-	-
L3		P	1.5	1.5	6	6		-	-	-	0.01	NA	1.89	-	-
9	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	20/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables
 Length Unknown
 SWA 70 mm²

Internal Rating
 IP2X



Earthing Arrangements
 PFC 3.0 kA
 Earth Loop 0.15 Ohms
 Cable Sheath

Supplied From Main Intake Panel 6L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Z _s	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Lights 2nd Floor Retail, Marketing & by Lift	4	T+E	A	60898	C	0.4	-	-	1.83	L	250	2.91	-	-
L1		P	1.5	1	6	10		-	-	-	0.01	1.98	-	-	
1	Lights Stairs & Passage	10	T+E	A	60898	C	0.4	-	-	1.56	L	250	2.91	-	-
L2		P	1.5	1	6	10		-	-	-	0.01	1.71	-	-	
1	Unknown	L	T+E	L	60898	C	0.4	-	-	L	L	200	2.91	-	-
L3		L	2.5	1.5	6	10		-	-	-	200	L	-	-	
2	Spare	-	-	-	60898	B	-	-	-	-	-	5.82	-	-	
L1		-	-	-	6	10		-	-	-	-	-	-	-	
2	Lights Retail Managers Office 2nd Floor	6	T+E	A	60898	C	0.4	-	-	0.92	L	250	2.91	-	-
L2		P	1.5	1	6	10		-	-	-	0.01	1.07	-	-	
2	Intruder Alarm Shop Cupboard R/H/S	1	T+E	A	60898	C	0.4	-	-	0.52	200	500	1.08	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.67	-	
3	Sockets Education Room	8	T+E	B	60898	C	0.4	0.60	1.41	0.47	200	500	0.54	-	-
L1		P	2X2.5	2X1.5	32	10		0.60	-	-	200	NA	0.62	-	
3	Sockets Goods Inwards	L	T+E	A	60898	C	0.4	0.27	0.42	0.15	200	500	0.54	-	-
L2		P	2X2.5	2X1.5	32	10		0.27	-	-	200	NA	0.30	-	
3	Sockets No 2 Education Outer Office	L	T+E	B	60898	C	0.4	0.49	0.83	0.28	200	500	0.54	-	-
L3		P	2X2.5	2X1.5	32	10		0.48	-	-	200	NA	0.43	-	
4	Sockets on Stairs	1	T+E	A	60898	C	0.4	-	-	0.58	200	500	1.08	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.73	-	
4	Shop Store L/H/S & Office Above	4	T+E	A	60898	C	0.4	-	-	1.02	200	500	2.91	-	-
L2		P	1.5	1	6	10		-	-	-	200	NA	1.17	-	
4	Sockets Retail Man Office & Time Machine Entrance	6	T+E	A	60898	C	0.4	0.72	1.12	0.38	L	250	0.54	-	-
L3		P	2X2.5	2X1.5	32	10		0.72	-	-	0.01	NA	0.53	-	
5	Socket Shop Store	2	T+E	A	60898	C	0.4	0.27	0.81	0.24	200	500	0.54	-	-
L1		P	2X2.5	2X1.5	32	10		0.27	-	-	200	NA	0.39	-	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No Ø	Designation	Points Served Polarity	Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Max Z s Zs Ω	Rating mA Test Button
5 L2	Directors Office Lights & Meeting Room	4 P	T+E 2.5	A 1.5	60898 10	C 10	0.4	- -	- -	0.48 -	L 0.01	250 NA	1.74 0.65	- -	- -
5 L3	Spare	- -	- -	- -	60898 10	C 10	-	- -	- -	- -	- -	- -	1.74 -	- -	- -
6 L1	Shop T's & Royal Mail Machine	2 P	T+E 2.5	B 1.5	60898 10	C 10	0.4	- -	- -	0.24 -	200 200	500 NA	1.74 0.39	- -	- -
6 L2	Directors Office Sockets & Meeting Room	7 P	T+E 2X2.5	A 2X1.5	61009 16	C 10	0.4	1.09 1.09	1.21 -	0.99 -	L 0.01	250 NA	1667 1.14	30 P	58.9 38
6 L3	Ring Retail Managers Office	2 P	T+E 2X2.5	A 2X1.5	60898 32	B 10	0.4	0.50 0.45	0.72 -	0.25 -	200 200	500 NA	1.08 0.39	- -	- -
7 L1	Lights Education Office	6 P	T+E 1.5	A 1	60898 6	C 10	0.4	- -	- -	0.63 -	L 0.01	250 NA	2.91 0.78	- -	- -
7 L2	Lights Goods Inwards & Conference Cupboard	6 P	T+E 1.5	E 1	60898 6	C 10	0.4	- -	- -	0.43 -	L 0.01	250 NA	2.91 0.58	- -	- -
7 L3	Lights Outer Education Office	1 P	T+E 1.5	E 1	60898 6	C 10	0.4	- -	- -	0.53 -	200 200	500 NA	2.91 0.68	- -	- -
8 L1	Lights Education Centre	4 P	T+E 1.5	A 1	60898 6	C 10	0.4	- -	- -	0.30 -	L 0.01	250 NA	2.91 0.45	- -	- -
8 L2	Lights Shop Store	6 P	T+E 1.5	A 1	60898 6	C 10	0.4	- -	- -	1.50 -	L 0.01	250 NA	2.91 1.65	- -	- -
8 L3	Lights Stairs	5 P	T+E 1.5	A 1	60898 10	C 10	0.4	- -	- -	1.43 -	L 0.01	250 NA	1.74 1.58	- -	- -
8 L3	Lights Shop & Entrance	9 P	T+E 1.5	A 1	60898 10	C 10	0.4	- -	- -	1.09 -	L 0.01	250 NA	1.74 1.24	- -	- -
9 L1	Contactor	L L	L 1.5	L 1	60898 6	B 10	0.4	- -	- -	L -	200 200	250 NA	5.82 L	- -	- -
9 L2	Shop Till DB T44687	1 P	L 6	A 2.5	60898 32	B 10	0.4	- -	- -	0.28 -	200 200	500 NA	1.08 0.43	- -	- -
9 L3	Shop Sockets RHS	1 P	L 2.5	B 1.5	60898 16	B 10	0.4	- -	- -	0.18 -	200 200	500 NA	2.18 0.33	- -	- -
10 L1	Grid Lights C6 Shop - Unknown	L L	L 1.5	L 1	60898 6	B 10	0.4	- -	- -	L -	L 200	250 NA	5.82 L	- -	- -
10 L2	Shop Sockets Exit/Entry & Outside	3 P	T+E 2.5	B 1.5	60898 16	B 10	0.4	- -	- -	1.57 -	200 200	500 NA	2.18 1.72	- -	- -
10 L3	Shop Sockets LHS	2 P	T+E 2.5	B 1.5	60898 16	B 10	0.4	- -	- -	0.39 -	200 200	500 NA	2.18 0.54	- -	- -

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
11 L1	Track 5 Shop Lights	13 P	T+E 1.5	E 1	60898 10	B 10	0.4	-	-	0.35	L 0.01	250 NA	3.49 0.50	-	-
11 L2	Shop Entrance Auto Doors	2 P	T+E 2.5	E 1.5	60898 10	C 10	0.4	-	-	0.54	200 200	500 NA	1.74 0.69	-	-
11 L3	Unknown	L L	T+E 1.5	L 1	60898 6	C 10	0.4	-	-	L	L 200	250 NA	2.91 L	-	-
12 L1	Track 4 Shop Lights	4 P	T+E 1.5	E 1	60898 6	B 10	0.4	-	-	0.69	L 0.01	250 NA	5.82 0.84	-	-
12 L2	Marketing Office Sockets	8 P	T+E 2X2.5	A 2X1.5	60898 32	B 10	0.4	0.65	1.06	0.42	200 200	500 NA	1.68 0.57	-	-
12 L3	Marketing Lights Lift End	5 P	T+E 2.5	A 1.5	60898 6	C 10	0.4	-	-	0.74	L 0.01	250 NA	2.91 0.89	-	-
13 L1	Track 3 Shop & Wall Lights	13 P	T+E 1.5	E 1	60898 6	B 10	0.4	-	-	0.74	L 0.01	250 NA	5.82 0.89	-	-
13 L2	Marketing Radial Socket & Unknown	L P	T+E 2.5/1.5	B 1.5/1	60898 16	B 10	0.4	-	-	0.44	L 0.01	250 NA	2.18 0.59	-	-
13 L3	Marketing Lights Stairs End	4 P	T+E 1.5	A 1	60898 6	C 10	0.4	-	-	0.94	L 0.01	250 NA	2.91 1.09	-	-
14 L1	Track 2 Shop & CCTV Counter	8 P	T+E 1.5	E 1	60898 6	B 10	0.4	-	-	-	L 0.01	250 NA	5.82 0.69	-	-
14 L2	Video Workshop Ring & Socket Outside	5 P	T+E 2X2.5	A 2X1.5	60898 32	B 10	0.4	0.48	0.72	0.26	L 0.01	250 NA	1.08 0.41	-	-
14 L3	Lights Workshop & Store	5 P	L 1.5	L 1.5	60898 10	B 10	0.4	-	-	0.39	L 0.01	250 NA	3.49 0.52	-	-
15 L1	Track/Shop Lights	6 P	T+E 1.5	E 1	60898 6	B 10	0.4	-	-	L	L 0.01	250 NA	5.82 0.71	-	-
15 L2	Lift Lobby 2nd Floor Socket x2	2 P	T+E 2.5	A 1.5	60898 16	B 10	0.4	-	-	0.35	200 200	500 NA	2.18 0.50	-	-
15 L3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16 L1	Unknown	4 L	T+E 1.5	L 1	60898 6	B 10	0.4	-	-	L	L 200	250 NA	5.82 L	-	-
16 L2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16 L3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Ω	mA	x5	

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	24/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5 ms	
1	Socket Below Counter	1	T+E	B	61009	B	0.4	-	-	0.17	200	500	1.74	30	19
L2		P	2.5	1.5	20	6		-	-	-	200	NA	0.60	P	18.7
2	Socket L/H/S of DB	1	T+E	B	61009	B	0.4	-	-	0.09	200	500	2.18	30	18.2
L2		P	2.5	1.5	16	6		-	-	-	200	NA	0.52	P	18.1
2	Sockets L/H/S Cupboards	2	T+E	B	61009	B	0.4	-	-	0.18	200	500	2.18	30	18.2
L2		P	2.5	1.5	16	6		-	-	-	200	NA	0.61	P	18.1

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		24/02/2020	Multi-tester		493/21MLT			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Supply Cables
 Length Unknown
 SWA 185 mm²

Internal Rating
 Not IP2X

Earthing Arrangements
 PFC 2.88 kA
 Earth Loop 0.08 Ohms
 Cable Sheath

Supplied From Main Intake Panel 7L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms
								Ω	Ω	Ω	MΩ	AFDD Function	Test Button	
1	Control Contactor	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
2	Meter Chamber	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
7	DB B/4 T44660	1	SWA	C	88	2	5	-	-	0.14	200	500	0.31	-
L123		P	16	16	100	80	-	-	-	-	200	NA	0.22	-
8	DB B/3 T44661	1	PVC/PVC	B	88	2	5	-	-	0.12	200	500	0.31	-
L123		P	25	16	100	80	-	-	-	-	200	NA	0.20	-
9	Ammeter Chamber	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
10	DB B/1 S36816	1	SWA	C	88	2	5	-	-	0.14	200	500	-	-
L123		P	16	CS	63	80	-	-	-	-	200	NA	0.22	-
11	Spare	-	-	-	88	2	5	-	-	-	-	-	0.31	-
L123		-	-	-	100	80	-	-	-	-	-	-	-	-
12	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
13	DB B/2 T44662	1	S	B	88	2	5	-	-	0.04	200	500	0.31	-
L123		P	16	MF	100	80	-	-	-	-	200	NA	0.12	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No Ø	Designation	Points Served Polarity	Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Max Z _s Z _s Ω	Rating mA Test Button
14 L123	Ammeter Chamber	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -
15 L123	S36803 Sub C DB via 20L123 Contactor	1 P	SWA 91	C CS	88 200	2 80	5	- -	- -	0.01 -	200 200	500 NA	0.14 0.09	- -	- -
16 L123	A47207 BB T1 via 21L123 Contactor	1 P	SWA 95	C CS	88 100	2 80	5	- -	- -	0.05 -	200 200	500 NA	0.31 0.13	- -	- -
17 L123	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -
18 L123	Lighting Contactor Chamber	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- NA	- -	- -	- -
19 L123	DB B/2 Chamber	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- NA	- -	- -	- -
20 L123	Sub C DB Contactor Enclosure	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- NA	- -	- -	- -
21 L123	BB T1 Contactor Enclosure	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- NA	- -	- -	- -

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith Stu Smith	10/03/2020	Multi-tester	9ABC		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables
 Length Unknown
 SWA 16 mm²

Internal Rating
 IP2X

DB B/4
 Washing Up Area

Merlin Gerin Distribution Board
 RCD TP&N 12 ways (total)

RCD Details BS (EN) 61008 80 A 30 mA 4 pole
Test Results 1x 20 ms 5x 8 ms
Test Button Pass **Asset No.** T44660

Earthing Arrangements
 PFC 2.09 kA
 Earth Loop 0.22 Ohms
 Integral C.P.C., 16 mm²


Supplied From Sub B DB 7L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA					AFDD Function	Ω	Test Button	ms	
1	Lights This Area & Rear	9	T+E	B	60898	B	0.4	-	-	0.50	L	250	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	0.01	NA	0.72	-	-
1	CCTV Room 4 Flight Display	1	T+E	C	60898	B	0.4	-	-	0.33	L	L	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	L	NA	0.55	-	-
1	Socket Below	1	T+E	B	60898	B	0.4	-	-	0.02	200	500	2.18	-	-
L2		P	2.5	1.5	16	10		-	-	-	200	NA	0.24	-	-
1	Water Heater	1	T+E	B	60898	B	0.4	-	-	0.04	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.26	-	-
2	W/M Near	1	SWA	C	60898	B	0.4	-	-	0.22	200	500	2.18	-	-
L123		P	1.5	1.5	16	10		-	-	-	200	NA	0.44	-	-
3	Kitchen Oven	1	FLEX	C	60898	B	5	-	-	0.11	200	500	0.55	-	-
L123		P	10	10	63	10		-	-	-	200	NA	0.33	-	-
4	W/M Far	1	S	B	60898	B	0.4	-	-	0.13	200	500	1.74	-	-
L123		P	2.5	2.5	20	10		-	-	-	200	NA	0.35	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	18/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Ambirad Inverter Zone 2	1	S	B	60898	C	0.4	-	-	0.07	200	500	0.87	-	-
L1		P	4	4	20	10		-	-	-	200	NA	0.27	-	-
1	Ambirad Controls Zone 2	1	S	B	60898	C	0.4	-	-	0.07	200	500	2.91	-	-
L2		P	1.5	1.5	6	10		-	-	-	200	NA	0.27	-	-
1	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	Ambirad Inverter Zone 1	1	S	B	60898	C	0.4	-	-	0.08	200	500	0.87	-	-
L1		P	4	4	20	10		-	-	-	200	NA	0.28	-	-
2	Ambirad Controls Zone 1	1	S	B	60898	C	0.4	-	-	0.07	200	500	2.91	-	-
L2		P	1.5	1.5	6	10		-	-	-	200	NA	0.27	-	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Gas Valve Safety Circuit	1	S	B	60898	C	0.4	-	-	0.04	200	500	2.91	-	-
L1		P	1.5	1.5	6	10		-	-	-	200	NA	0.24	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith Stu Smith	10/03/2020	Multi-tester	9ABC		


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 16 mm²

Internal Rating

IP2X



Earthing Arrangements

PFC 2.08 kA
 Earth Loop 0.22 Ohms
 Cable Sheath

Supplied From Sub B DB 10L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
								Ω	Ω	Ω	MΩ	Ω	Test Button	ms	
1	Spare	-	-	-	60898	B	-	-	-	-	-	2.18	-	-	
L123		-	-	-	16	10	-	-	-	-	-	-	-	-	
2	Cold Room Supply	1	SWA	B	60898	B	0.4	-	-	0.13	200	500	1.08	-	
L1		P	4	CS	32	10	-	-	-	-	200	NA	0.35	-	
2	Ring Main	5	T+E	B	60898	B	0.4	0.30	0.50	0.21	200	500	1.08	-	
L2		P	2X2.5	2X1.5	32	10	-	0.32	-	-	200	NA	0.43	-	
2	Fused Outlets	1	T+E	B	3871	2	0.4	-	-	0.04	200	500	1.56	-	
L3		P	2.5	1.5	16	9	-	-	-	-	200	NA	0.26	-	
3	Lights	4	T+E	B	60898	B	0.4	-	-	0.66	L	250	5.82	-	
L1		P	1	1	6	6	-	-	-	-	0.01	NA	0.88	-	
3	S184 Case Lighting & Monitor	2	T+E	B	60898	B	0.4	-	-	0.24	200	500	2.18	-	
L2		P	2.5	1.5	16	10	-	-	-	-	200	NA	0.46	-	
3	Extract Fan	1	SWA	E	60898	B	0.4	-	-	0.11	200	500	2.18	-	
L3		P	4	4	16	10	-	-	-	-	200	NA	0.33	-	
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	
L12		-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Water Heater	1	T+E	B	60898	C	0.4	-	-	0.16	200	500	1.08	-	
L3		P	2.5	1.5	16	10	-	-	-	-	200	NA	0.38	-	
6	Blank	-	-	-	-	-	-	-	-	-	-	-	1.56	-	
L12		-	-	-	-	-	-	-	-	-	-	-	-	-	
6	Water Heater	1	T+E	B	60898	B	0.4	-	-	0.16	200	500	2.18	-	
L3		P	2.5	1.5	16	10	-	-	-	-	200	-	0.38	-	
2	Gas Valve Box Above Ceiling	1	T+E	E	3871	2	0.4	-	-	0.03	200	500	1.56	-	
L3		P	1.5	1	16	9	-	-	-	-	200	-	0.25	-	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Ω	mA	x5	

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		10/03/2020	Multi-tester		493/21MLT			


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length 1 metre
PVC Singles 16 mm²

Internal Rating

Unknown



Earthing Arrangements

PFC 3.80 kA
Earth Loop 0.12 Ohms
Trunking/Conduit

Supplied From Sub B DB 13L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
											AFDD Function	Ω	Test Button	ms	
1	Emergency Lights	L	L	L	3871	2	0.4	-	-	L	L	-	1.24	-	-
L1		L	L	L	20	9		-	-	-	L	NA	L	-	-
1	Flight Deck CCTV	L	L	L	3871	2	0.4	-	-	L	L	-	1.24	-	-
L2		L	L	L	20	9		-	-	-	L	NA	L	-	-
1	Emergency Lights	L	L	L	3871	2	0.4	-	-	L	L	-	1.24	-	-
L3		L	L	L	20	9		-	-	-	L	NA	L	-	-
2	Flight Deck CCTV	L	L	L	3871	2	0.4	-	-	L	L	-	1.24	-	-
L1		L	L	L	20	9		-	-	-	L	NA	L	-	-
2	Emergency Lights	L	L	L	3871	2	0.4	-	-	L	L	-	1.24	-	-
L2		L	L	L	20	9		-	-	-	L	NA	L	-	-
2	Emergency Lights	L	L	L	3871	2	0.4	-	-	L	L	-	1.24	-	-
L3		L	L	L	20	9		-	-	-	L	NA	L	-	-
3	Emergency Lights	L	L	L	3871	2	0.4	-	-	L	L	-	1.24	-	-
L1		L	L	L	20	9		-	-	-	L	NA	L	-	-
3	Emergency Lights	L	L	L	3871	2	0.4	-	-	L	L	-	1.24	-	-
L2		L	L	L	20	9		-	-	-	L	NA	L	-	-
3	Spare	-	-	-	3871	2	-	-	-	-	-	-	4.16	-	-
L3		-	-	-	6	9		-	-	-	-	-	-	-	-
4	Spare	-	-	-	3871	2	-	-	-	-	-	-	1.24	-	-
L1		-	-	-	20	9		-	-	-	-	-	-	-	-
4	Recirculation Fan F1	1	S	B	3871	2	0.4	-	-	L	L	-	2.49	-	-
L2		L	2.5	2.5	10	9		-	-	-	L	NA	L	-	-
4	Recirculation Fan F2	1	S	B	3871	2	0.4	-	-	L	L	-	2.49	-	-
L2		L	2.5	2.5	10	9		-	-	-	L	NA	L	-	-
4	Recirculation Fan F3	1	S	B	3871	2	0.4	-	-	L	L	-	2.49	-	-
L2		L	2.5	2.5	10	9		-	-	-	L	NA	L	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
4 L2	Recirculation Fan F4	1 L	S 2.5	B 2.5	3871 10	2 9	0.4	- -	- -	L -	L NA	- -	2.49 L	- -	- -
4 L2	Recirculation Fan F5	1 L	S 2.5	B 2.5	3871 10	2 9	0.4	- -	- -	L -	L NA	- -	2.49 L	- -	- -
4 L2	Recirculation Fan F6	1 L	S 2.5	B 2.5	3871 10	2 9	0.4	- -	- -	L -	L NA	- -	2.49 L	- -	- -
4 L3	Emergency Lights Carrier Exit	1 P	S 1.5	B 1.5	3871 10	2 9	0.4	- -	- -	0.99 -	L NA	- -	2.49 1.11	- -	- -
4 L3	Recirculation Fan F1	1 P	S 2.5	B 2.5	3871 10	2 9	0.4	- -	- -	1.24 -	L NA	- -	2.49 1.36	- -	- -
4 L3	Fire Alarm Beams Hall 2 & 3	L L	S 1.5	B 1.5	3871 10	2 9	0.4	- -	- -	L -	L NA	- -	2.49 L	- -	- -
5 L1	Security Lights Hall 3	6 L	S 1.5	B 1.5	3871 10	2 9	0.4	- -	- -	L -	L NA	- -	2.49 L	- -	- -
5 L2	Contactors Above	1 P	S 2.5	B MF	3871 6	2 9	0.4	- -	- -	0.01 -	L NA	- -	4.16 0.12	- -	- -
5 L2	Emergency Lights	1 P	FP200 1	B/C 1	3871 6	2 9	0.4	- -	- -	0.27 -	L NA	- -	4.16 0.39	- -	- -
5 L3	Spare	- -	- -	- -	3871 10	2 9	0.4	- -	- -	- -	- -	- -	2.49 -	- -	- -
6 L123	Library Intake Fan	1 P	S 1.5	B 1.5	3871 6	2 9	0.4	- -	- -	0.08 -	200 200	500 NA	4.16 0.20	- -	- -

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith Stu Smith	10/03/2020	Multi-tester	9ABC		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA					AFDD Function	Ω	Test Button	ms	
1	DB B/6 A47212	1	SWA	C	88	L	5	-	-	0.02	L	-	L	-	-
L123		P	16	CS	L	80		-	-	-	L	NA	0.15	-	-
2	DB B/9 B44033	1	SWA	C	88	L	5	-	-	0.05	L	-	L	-	-
L123		P	16	CS	L	80		-	-	-	L	NA	0.13	-	-
3	DB 5 S36792	1	SWA	C	88	L	5	-	-	0.01	L	-	L	-	-
L123		P	16	CS	L	80		-	-	-	L	NA	0.16	-	-
4	DB B/8 Phantom Store S36814	1	SWA	C	88	L	5	-	-	0.03	L	-	L	-	-
L123		P	16	CS	L	80		-	-	-	L	NA	0.17	-	-
5	DB B/7 S36813	1	SWA	C	88	L	5	-	-	0.04	L	-	L	-	-
L123		P	16	CS	L	80		-	-	-	L	NA	0.18	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith		11/03/2020	Multi-tester		9ABC			


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 3.06 kA
 Earth Loop 0.15 Ohms
 Cable Sheath

Supplied From BB T1 1L123
 Secondary Supply None

Circuit Schedule and Test Results


CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
1	Vibrating Motors (Tested to Isolator)	1	S	B	60898	C	0.4	-	-	0.01	200	500	1.74	-	-
L123		P	1.5	1.5	10	10		-	-	-	200	NA	0.16	-	-
2	Sockets This End	L	T+E	B	3871	3	0.4	0.47	0.12	0.39	L	-	0.54	-	-
L1		P	2X2.5	2X1.5	32	9		0.12	-	-	L	NA	0.54	-	-
2	Dimmer Control Below DB	2	T+E	B	3871	3	0.4	-	-	0.02	200	500	0.54	-	-
L2		P	4	2.5	32	9		-	-	-	200	NA	0.17	-	-
2	Lights Corridor	4	T+E/FLEX	B	60898	B	0.4	-	-	0.43	L	-	5.82	-	-
L3		P	3X1.5	2X1/1.5	6	10		-	-	-	L	NA	0.58	-	-
3	Unidentified	L	T+E	B	3871	2	0.4	-	-	L	L	-	2.49	-	-
L123		L	1.5	1	10	9		-	-	-	L	NA	L	-	-
4	Fan	1	S	B	3871	2	0.4	-	-	0.25	200	500	0.77	-	-
L123		P	2.5	2.5	32	9		-	-	-	200	NA	0.40	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith		11/03/2020	Multi-tester		9ABC			
Stu Smith								

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables
 Length Unknown
 SWA 16 mm²

Internal Rating
 Not IP2X



Earthing Arrangements
 PFC 2.60 kA
 Earth Loop 0.18 Ohms
 Cable Sheath

Supplied From BB T1 2L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop		R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage	Max Z s	Rating	x1	
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5		
												Ω	Test Button	ms		
1	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-	
1	Cyc Lights - Not in Use	1	S	B	60898	C	0.4	-	-	0.01	200	500	0.87	-	-	
L2		P	2.5	2.5	20	10		-	-	-	200	NA	0.19	-	-	
1	Sockets Floor, Helicopter Side	3	S	B	3871	3	0.4	-	-	0.37	200	500	0.87	-	-	
L3		P	4	4	20	9		-	-	-	200	NA	0.55	-	-	
2	Lights Landing, Buccaneer	1	FLEX	C	60898	B	0.4	-	-	0.01	L	250	3.49	-	-	
L1		P	1	1	10	10		-	-	-	0.01	NA	0.19	-	-	
2	Cyc Lights - Not in Use	1	S	B	3871	3	0.4	-	-	0.01	200	500	1.08	-	-	
L2		P	2.5	2.5	16	9		-	-	-	200	NA	0.19	-	-	
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-	
3	Socket This Corridor Helicopter Side	1	T+E	C	60898	B	0.4	-	-	0.33	200	500	3.40	-	-	
L1		P	2.5	1.5	10	10		-	-	-	200	NA	0.51	-	-	
3	Sockets Carrier Side, Small Pots	L	T+E	C	60898	B	0.4	-	-	L	L	250	3.49	-	-	
L2		L	2.5	1.5	10	10		-	-	-	0.01	NA	L	-	-	
3	Dimmer Box Below - Not in Use	1	S	B	60898	B	0.4	-	-	0.01	200	500	3.49	-	-	
L2		P	2.5	1.5	10	10		-	-	-	200	NA	0.19	-	-	
3	Sockets Floor, Carrier Side	4	S	B	3871	3	0.4	-	-	1.05	200	500	0.87	-	-	
L3		P	4	4	20	9		-	-	-	200	NA	1.23	-	-	
4	Spare	-	-	-	60898	B	-	-	-	-	-	-	3.49	-	-	
L1		-	-	-	10	10		-	-	-	-	-	-	-	-	
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-	
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results


CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Z _s Ω	mA	x5 ms	

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		18/03/2020	Multi-tester		493/21MLT			

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables
 Length Unknown
 SWA 16 mm²

Internal Rating
 Not IP2X



Earthing Arrangements
 PFC 3.42 kA
 Earth Loop 0.13 Ohms
 Cable Sheath

Supplied From BB T1 3L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA					AFDD Function	Ω	Test Button	ms	
1	Carrier Entrance Sign	2	T+E	B	60898	B	0.4	-	-	0.78	L	-	3.49	-	-
L1		P	1.5	1	10	10		-	-	-	L	NA	0.91	-	-
1	2 Bays From DB to Entrance	4	T+E	B	60898	B	0.4	-	-	0.37	L	-	3.49	-	-
L2		P	1.5	1	10	10		-	-	-	L	NA	0.50	-	-
1	This Bay & Ark Royal Model	4	T+E	B	60898	B	0.4	-	-	0.25	L	-	3.49	-	-
L3		P	1.5	1	10	10		-	-	-	L	NA	0.38	-	-
2	Recess Lights to Entrance	4	T+E	B	60898	B	0.4	-	-	L	L	-	3.49	-	-
L1		L	1.5	1	10	10		-	-	-	L	NA	L	-	-
2	Recess Lights to Exit	7	T+E	B	60898	B	0.4	-	-	0.79	L	-	3.49	-	-
L2		P	1.5	1	10	10		-	-	-	L	NA	0.92	-	-
2	Far 3 Bays	6	T+E	B	60898	B	0.4	-	-	0.58	L	-	3.49	-	-
L3		P	1.5	1	10	10		-	-	-	L	NA	0.71	-	-
3	Spare	-	-	-	60898	C	-	-	-	-	-	-	0.54	-	-
L1		-	-	-	32	10		-	-	-	-	-	-	-	-
3	4 Sockets on Tin Wall Outside	4	T+E	B	60898	C	0.4	0.56	0.52	0.30	200	500	0.54	-	-
L2		P	2X2.5	2X1.5	32	10		0.56	-	-	200	NA	0.43	-	-
3	Boards Lights in Entrance	6	T+E	B	60898	B	0.4	-	-	0.68	L	-	3.49	-	-
L3		P	2X1.5	2X1.5	10	10		-	-	-	L	NA	0.81	-	-
4	Ring Main this Area	4	T+E	B	60898	C	0.4	1.05	0.95	0.52	200	500	0.54	-	-
L1		P	2X2.5	2X1.5	32	10		1.05	-	-	200	NA	0.65	-	-
4	Main Carrier Sign	7	T+E	B	60898	3	0.4	-	-	L	L	-	5.82	-	-
L2		L	1.5	1	6	9		-	-	-	L	NA	L	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-		-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith	10/03/2020	Multi-tester	9ABC		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 2.84 kA
Earth Loop 0.16 Ohms
Cable Sheath

Supplied From BB T1 4L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Ceiling Fan	1	FLEX	B	60898	C	0.4	-	-	0.04	200	500	1.74	-	-
L123		P	1.5	1.5	10	10		-	-	-	200	NA	0.20	-	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	Interface Unit Left of DB	1	S	B	60898	B	0.4	-	-	0.03	200	500	5.82	-	-
L2		P	2.5	2.5	6	10		-	-	-	200	NA	0.19	-	-
2	Phantom DP Switch 1	1	T+E	B	60898	C	0.4	-	-	L	L	-	0.87	-	-
L3		L	2.5	1.5	20	10		-	-	-	L	NA	L	-	-
3	Phantom Exhaust Fans Iso	1	SWA	B	60898	B	0.4	-	-	L	L	-	1.08	-	-
L123		L	4	CS	32	10		-	-	-	L	NA	L	-	-
4	JBD Motors	1	S	B	60898	B	0.4	-	-	0.02	200	500	1.74	-	-
L123		P	2.5	2.5	20	10		-	-	-	200	NA	0.18	-	-
5	CYC Lights Forward	1	S	B	60898	C	0.4	-	-	0.02	200	500	0.87	-	-
L1		P	2.5	2.5	20	10		-	-	-	200	NA	0.18	-	-
5	Unidentified	L	S	L	60898	C	0.4	-	-	L	L	-	0.87	-	-
L2		L	2.5	2.5	20	10		-	-	-	L	NA	L	-	-
5	Smoke Machine Phantom	1	S	B	60898	B	0.4	-	-	0.03	200	500	05.8	-	-
L3		P	2.5	2.5	6	10		-	-	-	200	NA	0.19	-	-
6	Dimmer 2	1	S	B	60898	C	0.4	-	-	0.03	200	500	0.87	-	-
L1		P	2.5	2.5	20	10		-	-	-	200	NA	0.19	-	-
6	CYC Lights Port/AFT	1	S	B	60898	C	0.4	-	-	0.03	200	500	0.87	-	-
L2		P	2.5	2.5	20	10		-	-	-	200	NA	0.19	-	-
6	Phantom DP Switch 2	1	T+E	B	60898	C	0.4	-	-	0.44	L	-	0.87	-	-
L3		L	2.5	2.5	20	10		-	-	-	L	NA	L	-	-
7	Dimmer 1	1	S	B	60898	B	0.4	-	-	0.02	200	500	5.82	-	-
L1		P	2.5	2.5	6	10		-	-	-	200	NA	0.18	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
7	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-	-
L2		-	-	-	6	10		-	-	-	-	-	-	-	-
7	Phantom DP Switch 3	1	T+E	B	60898	C	0.4	-	-	L	L	-	0.87	-	-
L3		L	2.5	1.5	20	10		-	-	-	L	NA	L	-	-
8	Compressor	1	S	B	60898	D	5	-	-	0.02	200	500	0.17	-	-
L123		P	2.5	2.5	50	10		-	-	-	200	NA	0.19	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith Stu Smith	04/03/2020	Multi-tester	9ABC		


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 3.44 kA
 Earth Loop 0.17 Ohms
 Cable Sheath

Supplied From BB T1 5L123
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	AFDD Function	Z _s	mA	x5
			mm ²	mm ²	A	kA							Ω	Test Button	ms
1	Socket	1	T+E	B	60898	C	0.4	-	-	0.01	200	500	1.08	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.18	-	-
1	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
1	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	Air Conditioning	1	SWA	B	60898	C	0.4	-	-	0.17	200	500	0.87	-	-
L123		P	2.5	2.5	20	10		-	-	-	200	NA	0.34	-	-
3	Spare	-	-	-	60898	3	-	-	-	-	-	-	0.54	-	-
L1		-	-	-	32	9		-	-	-	-	-	-	-	-
3	Room Light	2	FLEX	B	60898	B	0.4	-	-	0.43	L	500	3.49	-	-
L2		P	2X1.5	2X1.5	10	10		-	-	-	200	NA	0.60	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Spare	-	-	-	60898	3	-	-	-	-	-	-	0.54	-	-
L1		-	-	-	32	9		-	-	-	-	-	-	-	-
4	Spare	-	-	-	60898	3	-	-	-	-	-	-	0.54	-	-
L2		-	-	-	32	9		-	-	-	-	-	-	-	-
4	External Socket via RCD	1	FLEX	B	60898	B	0.4	-	-	0.34	200	500	1.08	-	32
L3		P	4	4	32	10		-	-	-	200	NA	0.81	-	18

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith Stu Smith	04/03/2020	Multi-tester	9ABC		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 95 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 5.14 kA
Earth Loop 0.09 Ohms
Cable Sheath


Supplied From Sub B DB 15L123 via 20L123 Contactr
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA					AFDD Function	Ω	Test Button	ms	
1	DB C/1 A47205	1	SWA	B	947	2	5	-	-	0.11	200	500	L	-	-
L123		P	16	CS	80	25		-	-	-	200	NA	0.20	-	-
2	DB C/2 A47206	1	SWA	B	947	2	5	-	-	0.11	200	500	L	-	-
L123		P	16	CS	80	25		-	-	-	200	NA	0.20	-	-
3	DB C/16 ISO S36774 & DB C/15 S36772	2	SWA	B	947	2	5	-	-	0.03	20	20	L	-	-
L123		P	16	CS	80	25		-	-	-	20	NA	0.12	-	-
4	DB C/20 ISO S36777 & DB C/21 S36779	2	SWA	B	947	2	5	-	-	0.05	200	500	L	-	-
L123		P	16	CS	80	25		-	-	-	200	NA	0.14	-	-
5	DB C/5 A47202	1	SWA	B	947	2	5	-	-	0.14	200	500	L	-	-
L123		P	16	CS	80	25		-	-	-	200	NA	0.23	-	-
6	DB C/23 ISO S36781 & DC C/25 S36784 via Live Side	2	SWA	B	947	2	5	-	-	0.05	200	500	L	-	-
L123		P	16	CS	100	25		-	-	-	200	NA	0.14	-	-
7	Carrier Lift Supply	1	SWA	B	947	2	5	-	-	0.13	200	500	L	-	-
L123		P	16	CS	80	25		-	-	-	200	NA	0.22	-	-
8	DB C/8 S36868	1	SWA	B	947	2	5	-	-	0.09	200	500	L	-	-
L123		P	16	CS	80	25		-	-	-	200	NA	0.18	-	-
9	DB C/9 S36798	1	SWA	B	947	2	5	-	-	0.13	200	500	L	-	-
L123		P	10	10	100	25		-	-	-	200	NA	0.22	-	-
10	DB C/10 S36786	1	SWA	B	947	2	5	-	-	0.08	200	500	L	-	-
L123		P	25	CS	100	25		-	-	-	200	NA	0.15	-	-
11	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
12	DB C/12 ISO S36788	1	SWA	B	947	2	5	-	-	0.08	200	500	L	-	-
L123		P	25	CS	100	25		-	-	-	200	NA	0.17	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith Stu Smith	10/03/2020	Multi-tester	9ABC		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Z _s	mA	x5	
			mm ²	mm ²	A	kA					AFDD Function	Ω	Test Button	ms	
1	Lights Workshop	12	T+E	B/C	61009	B	0.4	-	-	0.41	L	-	1667	30	20
L1		P	2.5	1.5	10	10		-	-	-	L	NA	0.61	P	10
1	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
1	Sockets Ring Below	2	S	B	60898	B	0.4	L	L	0.02	200	500	1.08	-	-
L3		P	2X2.5	2X2.5	32	10		L	-	-	200	NA	0.22	-	-
2	3 Phase Socket Below	1	SY FLEX	C	3871	2	0.4	-	-	0.01	200	500	2.49	-	-
L123		P	1.5	1.5	10	9		-	-	-	200	NA	0.20	-	-
3	3 Phase Socket Below	1	SY FLEX	C	60898	B	5	-	-	0.04	200	500	0.87	-	-
L123		P	2.5	2.5	40	10		-	-	-	200	NA	0.24	-	-
4	DB C/1/6L1 A47210	1	PVC/PVC	C	60898	C	5	-	-	0.01	200	500	0.54	-	-
L1		P	16	16	32	10		-	-	-	200	NA	0.21	-	-
4	2 Phase Socket Below	1	PVC/PVC	C	60898	C	5	-	-	0.01	200	500	0.27	-	-
L23		P	25	16	63	10		-	-	-	200	NA	0.20	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith		09/03/2020	Multi-tester		9ABC			
Stu Smith								

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

<p>Supply Cables Length 1 metre PVC/PVC Tails 10 mm²</p> <p>Internal Rating Not IP2X</p>	<p>DB C/1/6L1 Workshop Hangar</p> <hr/> <p>Merlin Gerin Distribution Board RCD SP&N L1 phase 1 way</p> <p>RCD Details BS (EN) 61008 40 A 30 mA 2 pole Test Results 1x 19 ms 5x 16 ms Test Button Pass Asset No. A47210</p>	<p>Earthing Arrangements PFC 1.1 kA Earth Loop 0.21 Ohms Trunking/Conduit</p>
<p>Supplied From DB C/1 6L1 Secondary Supply None</p>		

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L L/E		Test Voltage AFDD Function	Max Z s	Rating mA
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	Test Button	ms	
1	Sockets Workshop	6	SWA	C	60898	B	0.4	0.61	0.61	0.57	200	500	1.08	-	-
L1		P	2.5	2.5/CS	32	10		0.61		-	200	NA	0.78	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Stu Smith Sean Smith		12/03/2020	Multi-tester		9ABC			


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 2.24 kA
 Earth Loop 0.20 Ohms
 Cable Sheath

Supplied From Sub C DB 2L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
1 L1	Switch Fuse Fire Alarm	1 P	T+E 2.5	B/C 1.5	60898 16	B 10	0.4	-	-	0.06	200 200	500 NA	2.18 0.26	-	-
1 L2	Dimmer Rack R	1 P	S 4	B 4	60898 32	B 10	0.4	-	-	0.04	200 200	500 NA	1.08 0.24	-	-
1 L3	Experience Chamber Smoke Machine	L L	T+E 2.5	B/C 1.5	60898 16	B 10	0.4	-	-	L -	L NA	- L	2.18 L	-	-
2 L1	Lights This Room	3 P	T+E 2X1	B/C 2X1	60898 6	B 10	0.4	-	-	0.46	L L	- NA	5.82 0.66	-	-
2 L2	Dimmer Rack S	1 P	S 4	B 4	60898 32	B 10	0.4	-	-	0.04	200 200	500 NA	1.08 0.24	-	-
2 L3	R/H/S Contactor	1 P	T+E 1	B/C 1	60898 6	B 10	0.4	-	-	0.02	200 200	500 NA	5.82 0.22	-	-
3 L1	Experience Chamber Safety Beams & Maps	1 P	T+E 1	B/C 1	60898 6	B 10	0.4	-	-	0.03	200 200	500 NA	5.82 0.23	-	-
3 L2	Experience Chamber Ring Main	L P	T+E 2X2.5	B/C 2X1.5	60898 32	B 10	0.4	-	-	0.60	L L	- NA	1.08 0.80	-	-
3 L3	Experience Chamber Emergency Light	1 P	T+E 1	B/C 1	60898 6	B 10	0.4	-	-	1.09	200 200	500 NA	5.82 1.29	-	-
4 L123	Fans Control Room L/H/S	1 P	3 CORE 1	C 1	60898 6	B 10	0.4	-	-	0.09	200 200	500 NA	5.82 0.29	-	-
5 L1	Sockets Control Room	4 P	T+E 2X2.5	B/C 2X1.5	60898 32	B 10	0.4	0.89	1.12	0.34	200 200	500 NA	1.08 0.54	-	-
5 L2	F/A Repeater Panel	1 P	T+E 4	B/C 2.5	60898 6	B 10	0.4	-	-	0.17	200 200	500 NA	5.82 0.37	-	-
5 L3	Redundant	L L	T+E 2.5	B/C 1.5	60898 16	B 10	0.4	-	-	L	L L	- NA	2.18 L	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs Ω	mA Test Button	x5 ms
6	Racks A, B, C, D, E	5	T+E	B/C	60898	B	0.4	-	-	0.24	200	500	1.74	-	-
L1		P	1.5	1	20	10		-	-	-	200	NA	0.44	-	-
6	Racks G, H, J, K	4	SWA	C	60898	B	0.4	-	-	0.07	200	500	1.74	-	-
L2		P	2X2.5	CS	20	10		-	-	-	200	NA	0.27	-	-
6	Hall 3, Buccaneer Projector	L	FLEX	C	60898	C	0.4	-	-	L	L	-	0.87	-	-
L3		L	2X2.5	2X2.5	20	10		-	-	-	L	NA	L	-	-
7	Fan Control	1	SWA	B/C	60898	B	0.4	-	-	0.04	200	500	0.27	-	-
L123		P	2.5	1.5	32	10		-	-	-	200	NA	0.24	-	-
8	Sockets Projector Experience Chamber	2	T+E	B/C	60898	B	0.4	-	-	L	L	-	1.74	-	-
L1		L	2.5	1.5	20	10		-	-	-	L	NA	L	-	-
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith		09/03/2020	Multi-tester		9ABC			
Stu Smith								

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5	
			mm ²	mm ²	A	kA	s					Ω	Test Button	ms	
1	DB C/16 S36775	1	S	B	5419	-	5	-	-	0.01	200	500	L	-	-
L123		P	16	16	125	L		-	-	-	200	NA	0.12	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith		04/03/2020	Multi-tester		9ABC			
Stu Smith								


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length 2 metres
 PVC Singles 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 3.92 kA
 Earth Loop 0.12 Ohms
 PVC Singles, 16 mm²

Supplied From DB C/16 ISO 1L123 via Contactor
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Zs
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5
												Ω	Test Button	ms
1	Fan in Island Wall Low Level	1	S	B	60898	B	0.4	-	-	L	L	3.49	-	-
L123		L	1.5	1.5	10	10		-	-	-	L	L	-	-
2	Socket in Conference & Exhibition Area	6	T+E	A	60898	B	0.4	1.15	1.91	0.83	200	500	1.08	-
L1		P	2X2.5	2X1.5	32	10		1.15	-	-	200	NA	0.95	-
2	Unknown	L	T+E	A	60898	B	0.4	-	-	L	L	2.18	-	-
L2		L	2.5	1.5	16	10		-	-	-	L	NA	L	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-
3	Lights Area 1	1	T+E	A	60898	B	0.4	-	-	0.60	200	500	5.82	-
L2		P	1.5	1.5	6	10		-	-	-	200	NA	0.72	-
3	Lights Area 2	6	T+E	A	60898	B	0.4	-	-	1.36	L	500	5.82	-
L3		P	1.5	1.5	6	10		-	-	-	200	NA	1.48	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-
4	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-
L2		-	-	-	6	10		-	-	-	-	-	-	-
4	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-
L3		-	-	-	6	10		-	-	-	-	-	-	-
5	Lights Area 3	3	T+E	A	60898	B	0.4	-	-	1.15	L	-	5.82	-
L1		P	1.5	1	6	10		-	-	-	L	NA	1.27	-
5	Modern Navy Sockets	1	T+E	A	60898	B	0.4	-	-	0.28	200	500	2.18	-
L2		P	2.5/1.5	1.5/1	16	10		-	-	-	200	NA	0.41	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms
6	Spare	-	-	-	60898	B	-	-	-	-	-	1.08	-	-
L123		-	-	-	32	10	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith	04/03/2020	Multi-tester	9ABC		
Stu Smith					


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length 2 metres
PVC Singles 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 3.62 kA
Earth Loop 0.12 Ohms
PVC Singles, 16 mm²

Supplied From LiveSide DB C/20 ISO LiveSide
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Ring Main Outside Toilet Area	3	T+E	B	60898	B	0.4	0.98	1.69	0.44	200	500	1.08	-	-
L1		P	3X2.5	3X1.5	32	10		0.89		-	200	NA	0.50	-	-
1	DB C/17 A47204	1	S	B	60898	B	5	-	-	0.03	200	500	1.08	-	-
L2		P	4	4	32	10		-	-	-	200	NA	0.15	-	-
1	Lights this Room	2	T+E	B	60898	B	0.4	-	-	0.04	L	-	5.82	-	-
L3		P	2X1.5	2X1	6	10		-	-	-	L	NA	0.16	-	-
2	Water Heater	1	T+E	B	60898	B	0.4	-	-	0.54	200	500	2.18	-	-
L1		P	2.5	1.5	20	10		-	-	-	200	NA	0.66	-	-
2	Spare	-	-	-	60898	B	-	-	-	-	-	-	2.18	-	-
L2		-	-	-	16	10		-	-	-	-	-	-	-	-
2	Hand Dryer Ladies WC	1	T+E	B	60898	B	0.4	-	-	0.51	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.63	-	-
3	Hand Dryer Ladies WC	1	T+E	B	60898	B	0.4	-	-	0.59	200	500	2.18	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.71	-	-
3	Hand Dryer Gents WC	1	T+E	B	60898	B	0.4	-	-	0.49	200	500	2.18	-	-
L2		P	2.5	1.5	16	10		-	-	-	200	NA	0.61	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Emergency Lights Stairs	5	T+E	B	60898	B	0.4	-	-	1.02	L	-	5.82	-	-
L1		P	4X1.5	4X1	6	10		-	-	-	L	NA	1.14	-	-
4	Lights in Service Cupboard	2	T+E/FP	B	60898	B	0.4	-	-	0.89	L	-	5.82	-	-
L2		P	3X1.5	3X1	6	10		-	-	-	L	NA	1.01	-	-
4	Sockets for Computer & Projection Rm	2	T+E	B	60898	B	0.4	-	-	0.11	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.23	-	-
5	Emergency Lights	2	T+E	B	60898	B	0.4	-	-	0.68	L	-	5.82	-	-
L1		P	2X1.5	2X1	6	10		-	-	-	L	NA	0.80	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
5	Island Wall Lights	15	FP200	B	60898	B	0.4	-	-	0.30	L	-	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	L	NA	2.51	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
6	Lights WC	11	T+E	B	60898	B	0.4	-	-	1.01	L	-	5.82	-	-
L1		P	2X1.5	2X1	6	10		-	-	-	L	NA	1.13	-	-
6	Control Circuit	1	S	B	60898	B	0.4	-	-	0.08	L	-	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	L	NA	0.20	-	-
6	DB C/19 B44034 via Contactor Supply	1	PVC PVC	B	60898	C	5	-	-	0.01	200	500	0.27	-	-
L3		P	16	10	63	10		-	-	-	200	NA	0.13	-	-
6	DB S36806 via Contactor	1	SWA	C	60898	C	5	-	-	0.08	200	500	0.27	-	-
L3		P	16	16/CS	63	10		-	-	-	200	NA	0.20	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith	02/03/2020	Multi-tester	9ABC		
Stu Smith					

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Conduit Box Under DB	1	S	B	3871	2	0.4	-	-	0.05	200	500	1.56	-	-
L2		P	2.5	2.5	16	3		-	-	-	200	NA	0.20	-	-
2	Sockets Lift Room & FA Interface	2	S	B	3871	2	0.4	-	-	0.19	200	500	1.56	-	-
L2		P	1.5	1.5	16	3		-	-	-	200	NA	0.34	-	-
3	Lights in Lift	5	S	B	3871	2	0.4	-	-	0.40	L	-	1.56	-	-
L2		P	1.5	1.5	16	3		-	-	-	L	NA	0.55	-	-
4	Lights Lift Room	3	S/FP200	B	3871	2	0.4	-	-	0.20	L	-	2.49	-	-
L2		P	3X1.5	3X1.5	10	3		-	-	-	L	NA	0.35	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith		04/03/2020	Multi-tester		9ABC			
Stu Smith								


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 16 mm²

Internal Rating

IP2X



Earthing Arrangements

PFC 2.30 kA
 Earth Loop 0.20 Ohms
 Integral C.P.C., 16 mm²

Supplied From DB C/15 6L3 via Contactor Below
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Lights Displays	1	T+E	B	60898	B	0.4	-	-	0.24	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.44	-	-
2	Lights Displays	1	T+E	B	60898	B	0.4	-	-	0.13	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.33	-	-
3	Lights Displays via Socket	1	T+E	B	60898	B	0.4	-	-	0.17	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.37	-	-
4	Lights Displays via Socket	1	T+E	B	60898	B	0.4	-	-	0.23	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.43	-	-
5	Lights Boat Display Cabinet	1	T+E	B	60898	B	0.4	-	-	0.09	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.29	-	-
5	Downlights via Dimmer	1	FLEX	B	60898	B	0.4	-	-	0.14	200	500	2.18	-	-
L3		P	1	1	16	10		-	-	-	200	NA	0.34	-	-
5	LED Wall Lights Far End	1	T+E	B	60898	B	0.4	-	-	L	L	250	2.18	-	-
L3		L	2.5	1.5	16	10		-	-	-	0.01	NA	L	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	18/03/2020	Multi-tester	493/21MLT		


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 1.17 kA
 Earth Loop 0.20 Ohms
 Integral C.P.C., 16 mm²
 Cable Sheath


Supplied From DB C/15 6L3 via Contactor
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
1 L3	Socket Back Wall	1 P	T+E 2.5	C 1.5	60898 16	B 10	0.4	- -	- -	0.34 -	200 200	500 NA	2.18 0.54	- -	- -
2 L3	Lights Above Control Display	2 P	T+E 2.5	C 1.5	60898 16	B 10	0.4	- -	- -	0.19 -	L L	- NA	2.18 0.39	- -	- -
3 L3	Lights Fan, Store	1 P	T+E 2.5	C 1.5	60898 16	B 10	0.4	- -	- -	0.10 -	200 200	500 NA	2.18 0.30	- -	- -
4 L3	Lights Ring Ceiling & Spot Lights	2 P	T+E 2.5	C 1.5	60898 16	B 10	0.4	- -	- -	0.22 -	L L	- NA	2.18 0.42	- -	- -
5 L3	Spot Lights Fire Exit	1 P	T+E 2.5	C 1.5	60898 16	B 10	0.4	- -	- -	0.34 -	L L	- NA	2.18 0.54	- -	- -
6 L3	Corridor Spot Lights	1 P	T+E 2.5	B 1.5	60898 16	B 10	0.4	- -	- -	0.46 -	L L	- NA	2.18 0.66	- -	- -
7 L3	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -
8 L3	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith Stu Smith	04/03/2020	Multi-tester	9ABC		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5	
			mm ²	mm ²	A	kA	s					Ω	Test Button	ms	
1	DB C/20 S36778	2	S	B	5419	-	0.4	-	-	0.01	200	500	L	-	-
L123		P	16/10	16/16	125	L		-	-	-	200	NA	0.14	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith		04/03/2020	Multi-tester		9ABC			
Stu Smith								


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length 1 metre
SWA 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 3.26 kA
Earth Loop 0.14 Ohms
PVC Singles, 16 mm²

Supplied From DB C/20 ISO 1L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1 L123	Silence Maint. Hangar	L	T+E	B	60898	B	0.4	-	-	L	L	-	3.49	-	-
		L	1.5	1	10	10		-	-	-	L	NA	L	-	-
2 L123	Fan Desk 2 Leander	L	T+E	A	60898	B	0.4	-	-	0.67	200	500	5.82	-	-
		P	1.5	1	6	10		-	-	-	200	NA	0.81	-	-
3 L1	Dimmer Box D Tarr & Comms	1	T+E	A	60898	B	0.4	-	-	0.15	L	-	1.08	-	-
		P	4	4	32	10		-	-	-	L	NA	0.29	-	-
3 L2	Dimmer Box E Comms Spots	1	T+E	A	60898	B	0.4	-	-	0.13	L	-	1.08	-	-
		P	4	4	32	10		-	-	-	L	NA	0.27	-	-
3 L3	Spare	-	-	-	60898	B	-	-	-	-	-	5.82	-	-	
		-	-	-	6	10		-	-	-	-	-	-	-	-
4 L1	Sockets Low Level Ring Comms Room	7	T+E	A	60898	B	0.4	-	-	L	L	-	3.49	-	-
		L	1.5	1	10	10		-	-	-	L	NA	L	-	-
4 L2	CCTV Ward Room	2	T+E	A	60898	B	0.4	-	-	0.68	200	500	3.49	-	-
		P	1.5	1	10	10		-	-	-	200	NA	0.82	-	-
4 L3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
		-	-	-	-	-	-	-	-	-	-	-	-	-	-
5 L1	Lights Ward Room	5	T+E	A	60898	B	0.4	-	-	1.02	L	-	5.82	-	-
		P	1.5	1	6	10		-	-	-	L	NA	1.16	-	-
5 L2	Lights Lift Lobby & Comms Lobby	7	T+E	A	60898	B	0.4	-	-	0.50	L	-	5.82	-	-
		P	1.5	1	6	10		-	-	-	L	NA	0.64	-	-
5 L3	Dimmer Box 2	1	T+E	A	60898	B	0.4	-	-	0.14	L	-	2.18	-	-
		P	4	4	16	10		-	-	-	L	NA	0.28	-	-
6 L123	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
		-	-	-	-	-	-	-	-	-	-	-	-	-	-
7 L123	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
		-	-	-	-	-	-	-	-	-	-	-	-	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Ω	mA	x5 ms
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
9	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
10	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
11	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
12	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith	03/03/2020	Multi-tester	9ABC		
Stu Smith					

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable



Supply Cables
 Length 1 metre
 PVC Singles 16 mm²

Internal Rating
 Not IP2X

Earthing Arrangements
 PFC 3.26 kA
 Earth Loop 0.14 Ohms
 PVC Singles, 16 mm²

Supplied From Carrier Panel Board Sub C DB 4L123 via S36777 LiveSide
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
1 L1	Ring Main 1st Floor & Em Light Hangar Control Pt	14 P	T+E 3X2.5	B 2X1.5	60898 32	B 10	0.4	0.60 0.61	0.82	0.40 -	L L	- NA	1.08 0.54	- -	- -
1 L2	Lights This Room	2 P	T+E 2X1	B 2X1	60898 6	B 10	0.4	- -	-	0.08 -	L L	- NA	5.82 0.22	- -	- -
1 L3	Supply to F/A Interface	1 P	FP200 1	B 1	60898 4	B 10	0.4	- -	-	0.02 -	200 200	500 NA	8.73 0.16	- -	- -
2 L1	Emergency Lights	5 P	T+E 2X1	B 2X1	60898 6	B 10	0.4	- -	-	0.96 -	L L	- NA	5.82 0.10	- -	- -
2 L2	Unidentified	L L	T+E 2.5	B 1.5	60898 16	D 10	0.4	- -	-	L -	L L	- NA	0.54 L	- -	- -
2 L3	Leander Air Con	1 P	SY FLEX 2.5	B 2.5	60898 32	C 10	0.4	- -	-	0.22 -	L L	- NA	0.54 0.36	- -	- -
3 L123	Blank	- -	- -	- -	- -	- -	- -	- -	-	- -	- -	- -	- -	- -	- -
4 L123	Blank	- -	- -	- -	- -	- -	- -	- -	-	- -	- -	- -	- -	- -	- -

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith Stu Smith	04/03/2020	Multi-tester	9ABC		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 2.04 kA
Earth Loop 0.23 Ohms
Cable Sheath

Supplied From Sub C DB 5L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
			mm ²	mm ²	A	kA							Ω	Test Button	ms
1	Lights G/F Lift Room & Adjacent	3	T+E	C	60898	B	0.4	-	-	0.76	L	-	5.82	-	-
L1		P	2X1.5	2X1	6	10		-	-	-	L	NA	0.99	-	-
1	Socket G/F Lift Room	1	T+E	C	60898	B	0.4	-	-	0.41	L	-	1.74	-	-
L2		P	2X2.5	2X1.5	20	10		-	-	-	L	NA	0.64	-	-
1	External Garage/Shed	2	T+E	C	60898	B	0.4	-	-	0.52	200	500	1.08	-	-
L3		P	6	2.5	32	10		-	-	-	200	NA	0.75	-	-
2	S36780, S33776, S36785 via	3	SWA	E	60898	B	5	-	-	0.43	200	500	0.87	-	-
L123	Contactour	P	2.5	CS	40	10		-	-	-	200	NA	0.66	-	-
3	Compressor Below DB	1	S	B	60898	C	0.4	-	-	0.01	200	500	0.54	-	-
L123		P	2.5	4	32	10		-	-	-	200	NA	0.24	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Spare	-	-	-	3871	2	0.4	-	-	-	-	-	2.49	-	-
L2		-	-	-	10	6		-	-	-	-	-	-	-	-
4	DB C/14 A47203	1	SWA	C	60898	C	5	-	-	0.02	200	500	0.27	-	-
L3		P	10	CS	63	10		-	-	-	200	NA	0.25	-	-
5	Experience Chamber Fan	1	SWA	C	60898	B	0.4	-	-	0.24	200	500	3.49	-	-
L123		P	2.5	CS	10	10		-	-	-	200	NA	0.47	-	-
6	Spare	-	-	-	60898	B	0.4	-	-	-	-	-	3.49	-	-
L123		-	-	-	10	10		-	-	-	-	-	-	-	-
7	JBD Contactour	1	SWA	C	60898	D	0.4	-	-	0.22	200	500	0.87	-	-
L123		P	1.5	CS	10	10		-	-	-	200	NA	0.45	-	-
8	Decbridge Lift Experience Chamber	1	SWA	C	60898	B	5	-	-	0.03	200	500	0.55	-	-
L123		P	10	CS	63	10		-	-	-	200	NA	0.26	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith Stu Smith	02/03/2020	Multi-tester	9ABC		


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length 9 metres
 SWA 4 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 0.39 kA
 Earth Loop 0.59 Ohms
 Integral C.P.C., 4 mm²

Supplied From DB C/5 2L123 via Contactor
 Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating	x1
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Z _s	mA	x5 ms	
1	Lights Power Room LHS	3 P	FP200 1.5	B 1.5	60898 6	B 6	0.4	-	-	0.25	L L	- NA	5.82 0.84	- -	- -
2	Lights Power Room RHS	2 P	FP200 1.5	B 1.5	60898 6	B 6	0.4	-	-	0.32	L L	- NA	5.82 0.91	- -	- -
3	Lights Lift Room	3 P	FP200 1.5	B 1.5	60898 6	B 6	0.4	-	-	0.18	L L	- NA	5.82 0.77	- -	- -
4	Lights Toilet Area	7 P	FP200 1.5	B 1.5	60898 6	B 6	0.4	-	-	0.49	L L	- NA	5.82 1.09	- -	- -
5	Blank	- -	- -	- -	- -	- -	-	-	-	-	- -	- -	- -	- -	- -
6	Blank	- -	- -	- -	- -	- -	-	-	-	-	- -	- -	- -	- -	- -
7	Blank	- -	- -	- -	- -	- -	-	-	-	-	- -	- -	- -	- -	- -

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Stu Smith	03/03/2020	Multi-tester	9ABC		


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 4 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 0.37 kA
 Earth Loop 0.62 Ohms
 Integral C.P.C., 4 mm²


Supplied From DB C/5 2L123 via Contactor
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Ω	mA	ms
1	Wall Lights	6 P	FP200 1.5	B 1.5	60898 6	B 10	0.4	-	-	0.33	L	-	5.82	-	-
								-	-	-	L	NA	0.95	-	-
2	Wall Lights	4 P	FP200 1.5	B 1.5	60898 6	B 10	0.4	-	-	1.04	L	-	5.82	-	-
								-	-	-	L	NA	1.66	-	-
3	Wall Lights	3 P	FP200 1.5	B 1.5	60898 6	B 10	0.4	-	-	0.28	L	-	5.82	-	-
								-	-	-	L	NA	0.90	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
								-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
								-	-	-	-	-	-	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
								-	-	-	-	-	-	-	-
7	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
								-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Stu Smith Sean Smith	04/03/2020	Multi-tester	9ABC		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
1	Stair Wall Lights	3 P	FP200 1.5	B 1	60898 6	B 6	0.4	- -	- -	0.48 -	L L	- NA	5.82 1.14	- -	- -
2	Gallery Wall Lights	7 P	FP00 1.5	B 1	60898 6	B 6	0.4	- -	- -	1.49 -	L L	- NA	5.82 2.15	- -	- -
3	Wall Lights Island Tour	8 P	FP200 1.5	B 1	60898 6	B 6	0.4	- -	- -	1.30 -	L L	- NA	5.82 1.96	- -	- -
4	Wall Lights Island Tour	6 P	FP200 1.5	B 1	60898 6	B 6	0.4	- -	- -	0.90 -	L L	- NA	5.82 1.58	- -	- -
5	Blank	- -	- -	- -	- -	- -	-	- -	- -	- -	- -	- -	- -	- -	- -
6	Blank	- -	- -	- -	- -	- -	-	- -	- -	- -	- -	- -	- -	- -	- -
7	Blank	- -	- -	- -	- -	- -	-	- -	- -	- -	- -	- -	- -	- -	- -

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith Stu Smith		09/03/2020	Multi-tester		9ABC			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length 10.15 metres
 SWA 10 mm²

Internal Rating

Not IP2X

DB C/14	
Old Soft Frame Room	
Hager Distribution Board RCD SP&N L3 phase 4 ways	
RCD Details	BS (EN) 4293 63 A 30 mA 2 pole
Test Results	1x 37 ms 5x 17 ms
Test Button	Pass
Asset No.	A47203

Earthing Arrangements

PFC 0.92 kA
 Earth Loop 0.25 Ohms
 Cable Sheath


Supplied From DB C/5 4L3
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Sockets This Room	2	T+E	B/C	60898	B	0.4	0.40	0.55	0.59	200	500	1.08	-	-
L3		P	2X2.5	2X1.5	32	6		0.43		-	200	NA	0.84	-	-
2	Sockets Next Door	2	T+E	B/C	60898	B	0.4	-	-	0.61	200	500	1.08	-	-
L3		P	2.5	1.5	32	6		-	-	-	200	NA	0.86	-	-
3	Lights This Room	3	T+E	B/C	60898	B	0.4	-	-	0.17	L	-	5.82	-	-
L3		P	1.5	1	6	6		-	-	-	L	NA	1.02	-	-
4	Lights Next Room	1	T+E	B/C	60898	B	0.4	-	-	0.68	L	-	5.82	-	-
L3		P	1.5	1	6	6		-	-	-	L	NA	0.93	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith		02/03/2020	Multi-tester		9ABC			
Stu Smith								

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	DB C/23 S36782	1	S	B	5419	-	0.4	-	-	0.01	200	500	L	-	-
L123		P	16	16	125	L		-	-	-	200	NA	0.14	-	-
1	DB C/24 S36783	1	S	B	5419	-	0.4	-	-	0.02	200	500	L	-	-
L123		P	16	16	125	L		-	-	-	200	NA	0.16	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Stu Smith		04/03/2020	Multi-tester		9ABC			
Sean Smith								


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length 1 metre
PVC Singles 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 3.29 kA
Earth Loop 0.14 Ohms
PVC Singles, 16 mm²

Supplied From DB C/20 ISO 1L123 via Contactor
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Ω	mA	x5 ms
1	Fan Maintenance Hangar	1	T+E	A	60898	B	0.4	-	-	L	L	-	3.49	-	-
L123		L	1.5	1	10	10		-	-	-	L	NA	L	-	-
2	Fan High Level Above ACR	1	T+E	A	60898	B	0.4	-	-	L	L	-	5.82	-	-
L123		L	1.5	1	6	10		-	-	-	L	NA	L	-	-
3	Fan in Sleeping Quarters 1	1	T+E	A	60898	B	0.4	-	-	0.76	200	500	5.82	-	-
L123		P	1.5	1	6	10		-	-	-	200	NA	0.90	-	-
4	Fan Above Water Effect	1	T+E	A	60898	B	0.4	-	-	0.62	200	500	5.82	-	-
L123		P	1.5	1	6	10		-	-	-	200	NA	0.76	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-		-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-		-	-	-	-	-	-	-	-
5	Pump for Water Effect	1	T+E	A	60898	C	0.4	-	-	0.64	200	500	1.08	-	-
L3		P	1.5	1	16	10		-	-	-	200	NA	0.78	-	-
6	Unidentified	L	T+E	A	3871	4	0.4	-	-	L	L	-	0.79	-	-
L123		L	1.5	1	16	9		-	-	-	L	NA	L	-	-
7	Unidentified	L	T+E	A	60898	B	0.4	-	-	L	L	-	2.18	-	-
L123		L	1.5	1	16	10		-	-	-	L	NA	L	-	-
8	Gallery Fan	1	T+E	A	60898	B	0.4	-	-	0.69	200	500	5.82	-	-
L123		P	1.5	1	6	10		-	-	-	200	NA	0.83	-	-
9	Fan in Opps Room	1	T+E	A	60898	B	0.4	-	-	0.20	200	500	5.82	-	-
L123		P	1.5	1	6	10		-	-	-	200	NA	0.34	-	-
10	Unidentified	L	T+E	A	3871	4	0.4	-	-	L	L	-	0.79	-	-
L123		L	1.5	1	16	9		-	-	-	L	NA	L	-	-
11	Unidentified	L	SWA	A	60898	B	0.4	-	-	L	L	-	1.08	-	-
L1		L	6	6	32	10		-	-	-	L	NA	L	-	-


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
11	Funnel Lights & Traffic Lights	8	T+E	A	60898	B	0.4	-	-	6.16	L	-	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	L	NA	6.20	-	-
11	Power 7-18, 7-19, 7-20 Flight Deck	6	T+E	A	60898	B	0.4	0.98	1.45	0.62	L	-	2.18	-	-
L3		P	3X1.5	3X1	16	10		0.99	-	-	L	NA	0.76	-	-
12	1st Area Main Exhibition	6	T+E	A	60898	B	0.4	1.63	2.10	0.40	L	-	2.18	-	-
L1		P	2X1.5	2X1	16	10		1.63	-	-	L	NA	0.54	-	-
12	Lab Card Readings	13	T+E	A	60898	B	0.4	0.44	0.92	0.76	L	-	2.18	-	-
L2		P	2X1.5	2X1	16	10		0.44	-	-	L	NA	0.90	-	-
12	Power 7-10, 7-11	2	T+E	A	60898	B	0.4	0.92	1.27	0.57	L	-	2.18	-	-
L3		P	2X1.5	2X1	16	10		0.99	-	-	L	NA	0.71	-	-
13	Flyco Ring 1st	10	T+E	A	60898	B	0.4	1.66	1.32	0.66	L	-	2.18	-	-
L1		P	2X1.5	2X1	16	10		1.63	-	-	L	NA	0.80	-	-
13	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
13	Unidentified	L	T+E	A	60898	B	0.4	-	-	L	L	-	2.18	-	-
L3		L	2.5	1.5	16	10		-	-	-	L	NA	L	-	-
14	Lights in Pre-Experience	10	T+E	A	60898	B	0.4	-	-	0.65	L	-	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	L	NA	0.79	-	-
14	Lights on Concorde Stairs	L	T+E	A	60898	B	0.4	-	-	L	L	-	5.82	-	-
L2		L	1.5	1	6	10		-	-	-	L	NA	L	-	-
14	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
15	Lights in Disabled Lobby	9	T+E	A	60898	B	0.4	-	-	1.16	L	-	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	L	NA	1.30	-	-
15	Island Wall Lights Front	L	T+E	A	60898	B	0.4	-	-	L	L	-	5.82	-	-
L2		L	1.5	1	6	10		-	-	-	L	NA	L	-	-
15	Red/Green Interface	1	T+E	A	60898	B	0.4	-	-	0.04	L	-	1.74	-	-
L3		P	1.5	1	20	10		-	-	-	L	NA	0.20	-	-
16	Unidentified	L	T+E	A	60898	B	0.4	-	-	L	L	-	5.82	-	-
L1		L	1.5	1	6	10		-	-	-	L	NA	L	-	-
16	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
16	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Stu Smith Sean Smith	04/03/2020	Multi-tester	9ABC		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable



Supply Cables
 Length Unknown
 PVC Singles 16 mm²

Earthing Arrangements
 PFC 2.8 kA
 Earth Loop 0.16 Ohms
 PVC Singles, 16 mm²

Internal Rating
 Not IP2X

Supplied From DB C/20 ISO 1L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	Ω	Ω	Ω	L/E	AFDD Function	Zs	mA	x5	
			mm ²	mm ²	A	kA	s			MΩ		Ω	Test Button	ms	
1	Supply to Dimmer F	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L1		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
1	Supply to Dimmer G	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L2		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
1	Supply to Dimmer H	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L3		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
2	Supply to Dimmer I	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L1		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
2	Supply to Dimmer J	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L2		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
2	Supply to Dimmer K	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L3		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
3	Supply to Dimmer L	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L1		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
3	Supply to Dimmer M	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L2		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Supply to Dimmer M3	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L2		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
5	Supply to Dimmer M2	1	S	B	60898	B	0.4	-	-	0.01	L	-	0.39	-	-
L2		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
5	Cannons 4 Dimmer M	1	FLEX	B	60898	B	0.4	-	-	L	L	-	3.49	-	-
L3		L	1.5	1	10	10		-	-	-	L	NA	L	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
6	Supply to DimmerM1	1	S	B	60898	B	0.4	-	-	0.01	L	-	1.08	-	-
L2		P	6	6	32	10		-	-	-	L	NA	0.17	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
7	Unidentified	L	T+E	B	60898	B	0.4	-	-	L	L	-	3.49	-	-
L1		L	1.5	1	10	10		-	-	-	L	NA	L	-	-
7	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-	-
L2		-	-	-	6	10		-	-	-	-	-	-	-	-
7	Pre-Experience Stair Lights	3	T+E	A	60898	B	0.4	-	-	0.64	L	-	5.82	-	-
L3		P	1.5	1	6	10		-	-	-	L	NA	0.80	-	-
8	Unidentified	L	T+E	A	60898	B	0.4	-	-	L	L	-	5.82	-	-
L1		L	1.5	1	6	10		-	-	-	L	NA	L	-	-
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
9	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
10	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
11	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
12	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Stu Smith Sean Smith	03/03/2020	Multi-tester	9ABC		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
PVC/PVC Tails 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 3.29 kA
Earth Loop 0.14 Ohms
PVC Singles, 16 mm²

Supplied From Sub C DB 6L123 via Liveside S36781
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Zs
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5
1	Ring Main Sockets	L	T+E	B	60898	B	0.4	0.81	1.42	0.37	L -	1.08	-	-
L1		P	2X2.5	2X1.5	32	10		0.81	-	-	L NA	0.51	-	-
1	Emergency Lights Concorde Stairs	2	T+E	B	60898	B	0.4	-	-	0.97	L -	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	L NA	1.11	-	-
1	DB Contactor Supply All Floors	1	S	B	60898	B	0.4	-	-	1.07	L -	5.82	-	-
L3		P	1.5	1	6	10		-	-	-	L NA	1.21	-	-
2	Lights & Emergency Lights Switch Room	4	T+E	B	60898	B	0.4	-	-	0.35	L -	5.82	-	-
L1		P	3X1.5	3X1	6	10		-	-	-	L NA	0.49	-	-
2	Ethernet Socket & Unidentified	1	T+E	B	60898	B	0.4	-	-	0.14	L -	5.82	-	-
L2		P	1.5/2.5	1/1.5	6	10		-	-	-	L NA	0.30	-	-
2	Emergency Lights this Floor	7	T+E	B	60898	B	0.4	-	-	0.62	L -	5.82	-	-
L3		P	1.5	1	6	6		-	-	-	L NA	0.76	-	-
3	Dimmer Supply A	1	S	B	60898	B	0.4	-	-	0.02	L -	1.08	-	-
L1		P	6	6	32	10		-	-	-	L NA	0.16	-	-
3	Dimmer Supply B	1	S	B	60898	B	0.4	-	-	0.02	L -	1.08	-	-
L2		P	6	6	32	10		-	-	-	L NA	0.16	-	-
3	Dimmer Supply C	1	S	B	60898	B	0.4	-	-	0.02	L -	1.08	-	-
L3		P	6	6	32	10		-	-	-	L NA	1.16	-	-
4	Unidentified	L	S	B	60898	B	0.4	-	-	L	L -	8.43	-	-
L1		L	1.5	1	4	10		-	-	-	L NA	L	-	-
4	Switched Off by Others	1	SWA	B	60898	B	0.4	-	-	L	L -	2.18	-	-
L2		L	6	6	16	10		-	-	-	L NA	L	-	-
4	Switched Off by Others	1	SWA	B	60898	B	0.4	-	-	L	L -	2.18	-	-
L3		L	6	6	16	10		-	-	-	L NA	L	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith	05/03/2020	Multi-tester	9ABC		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 16 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 2.5 kA
Earth Loop 0.18 Ohms
Cable Sheath

Supplied From Sub C DB 8L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Z _s	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Pelmet Lights	8	T+E	B	60898	B	0.4	-	-	1.21	L	-	3.49	-	-
L1		P	1.5	1	10	10		-	-	-	L	NA	1.39	-	-
1	Chiller Unit	1	T+E	B	60898	B	0.4	-	-	0.21	200	500	1.74	-	-
L2		P	2.5	1.5	20	10		-	-	-	200	NA	0.39	-	-
1	Socket Servery LHS	1	T+E	B	60898	B	0.4	-	-	0.20	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.38	-	-
2	Exit Pelmet & Servery Lights	10	T+E	B	60898	B	0.4	-	-	0.64	L	-	3.49	-	-
L1		P	1.5	1	10	10		-	-	-	L	NA	0.82	-	-
2	Coffee Machine	1	T+E	B	60898	B	0.4	-	-	0.39	200	500	1.74	-	-
L2		P	2.5	1.5	20	10		-	-	-	200	NA	0.55	-	-
2	Cleaners Socket Mains Cupboard Wall	1	T+E	B	60898	B	0.4	-	-	0.02	200	500	2.18	-	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.20	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Sockets	10	T+E	B	60898	B	0.4	0.40	0.48	0.17	200	500	1.08	-	-
L2		P	2X2.5	2X1.5	32	10		0.41	-	-	200	NA	0.35	-	-
3	Emergency Lights	4	T+E	B	60898	B	0.4	-	-	0.74	L	-	5.82	-	-
L3		P	3X1.5	3X1	6	10		-	-	-	L	NA	0.92	-	-
4	Socket Vending Machine	1	T+E	B	60898	B	0.4	-	-	0.19	200	500	1.74	-	-
L1		P	2.5	1.5	20	10		-	-	-	200	NA	0.37	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Stu Smith	05/03/2020	Multi-tester	9ABC		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 10 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 2.08 kA
Earth Loop 0.22 Ohms
PVC Singles, 10 mm²

Supplied From Carrier Panel Board Sub C DB 9L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Blank L123	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	Lights & A/C Office Opposite 111 L1	5	T+E	A	60898	B	0.4	-	-	0.42	L	250	5.82	-	-
		P	1.5	1	6	10		-	-	-	0.01	NA	0.64	-	-
2	Blank L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	Blank L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Lights Wall Passage L1	6	T+E	A	60898	B	0.4	-	-	0.76	L	250	5.82	-	-
		P	1.5	1	6	10		-	-	-	0.01	NA	0.98	-	-
3	Blank L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Blank L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Lights O/S WN R/H/S L1	4	T+E	A	60898	B	0.4	-	-	1.06	L	250	5.82	-	-
		P	1.5	1	6	10		-	-	-	0.01	NA	1.28	-	-
4	Lights Survey & Air Con Ed L2	4	T+E	A	60898	B	0.4	-	-	0.36	L	250	5.82	-	-
		P	1.5	1	6	10		-	-	-	0.01	NA	1.58	-	-
4	Blank L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Sockets Meeting & Ed Room Opposite 111, Radial L1	2	T+E	A	60898	B	0.4	-	-	0.22	200	500	2.18	-	-
		P	2.5	1.5	16	10		-	-	-	200	NA	0.44	-	-
5	Blank L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Blank L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	V	Zs	mA	x5
6	Lobby Lights & Emergency No 5	11	T+E	A	3871	2	0.4	-	-	0.25	L	250	4.99	-	-
L1		P	1.5	1	5	6		-	-	-	0.01	NA	0.47	-	-
6	Ed Office Ring Opposite 111	5	T+E	B	60898	B	0.4	0.20	0.35	0.15	200	500	0.54	-	-
L2		P	2X2.5	2X1.5	32	10		0.20	-	-	200	NA	0.37	-	-
6	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-	-
L3		-	-	-	6	10		-	-	-	-	-	-	-	-
7	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-		-	-	-	-	-	-	-	-
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-		-	-	-	-	-	-	-	-
9	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-		-	-	-	-	-	-	-	-
10	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-		-	-	-	-	-	-	-	-
10	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-		-	-	-	-	-	-	-	-
10	Sockets Opposite Office R/H/S & Server	2	T+E	A	3871	2	0.4	0.32	0.48	0.11	200	500	0.99	-	-
L3		P	2X2.5	2X1.5	25	9		0.32	-	-	200	NA	0.33	-	-
11	Heater	1	T+E	A	60898	C	0.4	-	-	0.29	200	500	0.54	-	-
L1		P	4	2.5	32	10		-	-	-	200	NA	0.51	-	-
11	Office Ring 119 & 112	8	T+E	A	60898	B	0.4	0.54	0.75	0.35	200	500	1.08	-	-
L2		P	2X2.5	2X1.5	32	10		0.52	-	-	200	NA	0.57	-	-
11	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-	-
L3		-	-	-	6	10		-	-	-	-	-	-	-	-
12	Office Lights	10	T+E	A	60898	B	0.4	-	-	0.69	L	250	5.82	-	-
L1		P	1.5	1	6	10		-	-	-	0.01	NA	0.91	-	-
12	Ring Office & Opposite	4	T+E	B	60898	B	0.4	0.20	0.27	0.17	200	500	1.08	-	-
L2		P	2X2.5	2X1.5	32	10		0.18	-	-	200	NA	0.39	-	-
12	DB C/13 S36821	1	T+E	A	60898	B	5	-	-	0.05	200	-	0.87	-	-
L3		P	10	6	40	10		-	-	-	200	NA	0.27	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	27/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Sockets	9	T+E	B	61009	C	0.4	0.26	0.98	0.22	200	500	0.54	30	28.3
L3		P	2X2.5	2X1.5	32	16		0.29		-	200	NA	0.48	P	18.4
2	Heating	1	T+E	B	61009	C	0.4	-	-	0.37	200	500	1.08	30	28.2
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.64	P	18.3
3	Pillar Sockets	1	T+E	B	61009	C	0.4	-	-	0.32	200	500	1.08	30	28.3
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.59	P	18.3
4	Lights & Air Con	5	T+E	B	60898	B	0.4	-	-	0.58	L	250	3.49	-	-
L3		P	1.5	1.5	10	10		-	-	-	0.01	NA	0.85	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	18/02/2020	Multi-tester	493/21MLT		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable



Supply Cables
 Length Unknown
 SWA 25 mm²

Internal Rating
 Not IP2X

Earthing Arrangements
 PFC 1.41 kA
 Earth Loop 0.15 Ohms
 Cable Sheath

Supplied From Sub C DB 10L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms
								Ω	Ω	Ω	MΩ	Ω	Test Button	
1	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
7	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
8	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-
9	Roof Fan 1	L	FLEX	E	60898	C	0.4	-	-	L	L	-	1.08	-
L123		L	1.5	1.5	16	10		-	-	-	L	NA	L	-
10	Roof Fan 2	L	FLEX	E	60898	C	0.4	-	-	L	L	-	1.08	-
L123		L	1.5	1.5	16	10		-	-	-	L	NA	L	-
11	Roof Fan 3	L	FLEX	E	60898	C	0.4	-	-	L	L	-	1.08	-
L123		L	1.5	1.5	16	10		-	-	-	L	NA	L	-
12	Spare	-	-	-	60898	C	-	-	-	-	-	-	0.54	-
L123		-	-	-	32	10		-	-	-	-	-	-	-
13	HCP Roof Fan 1	L	SWA	E	60898	C	0.4	-	-	L	L	-	1.08	-
L123		L	1.5	1.5/CS	16	10		-	-	-	L	NA	L	-

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	AFDD Function	Z _s	mA	x5
			mm ²	mm ²	A	kA							Ω	Test Button	ms
14	HCP Roof Fan 2	L	SWA	E	60898	C	0.4	-	-	L	L	-	1.08	-	-
L123		L	1.5	1.5/CS	16	10		-	-	-	L	NA	L	-	-
15	Spare	-	-	-	60898	C	-	-	-	-	-	-	1.08	-	-
L123		-	-	-	16	10		-	-	-	-	-	-	-	-
16	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-		-	-	-	-	-	-	-	-
16	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-		-	-	-	-	-	-	-	-
16	DB C/28 A47208	1	SWA	E	60898	B	5	-	-	0.21	200	500	0.55	-	-
L3		P	4	4/CS	63	10		-	-	-	200	NA	0.36	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Sean Smith	03/03/2020	Multi-tester	9ABC		
Stu Smith					

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 4 mm²

Internal Rating

Not IP2X

DB C/28
 Carrier Experience Office

Eaton Distribution Board
 RCD SP&N L3 phase 7 ways

RCD Details BS (EN) 61008 100 A 30 mA 2 pole
Test Results 1x 43 ms 5x 8 ms
Test Button Pass **Asset No.** A47208

Earthing Arrangements

PFC 0.63 kA
 Earth Loop 0.36 Ohms
 Cable Sheath
 Integral C.P.C., 4 mm²


Supplied From DB C/10 16L3
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Sockets This Room	6	T+E	B	60898	B	0.4	0.12	0.12	0.09	200	500	1.08	-	-
L3		P	2X2.5	2X1.5	32	10		0.12		-	200	NA	0.45	-	-
2	Heater Below	1	T+E	B	60898	B	0.4	-	-	0.12	200	500	1.74	-	-
L3		P	2.5	1.5	20	10		-	-	-	200	NA	0.48	-	-
3	Sockets Pillar & Store Cupboard	3	T+E	B	60898	B	0.4	-	-	0.27	200	500	1.74	-	-
L3		P	2X2.5	2X1.5	20	10		-	-	-	200	NA	0.63	-	-
4	Socket by Window	1	T+E	B	60898	B	0.4	-	-	0.34	200	500	1.74	-	-
L3		P	2.5	1.5	20	10		-	-	-	200	NA	0.70	-	-
5	Winch	1	T+E	B	60898	B	0.4	-	-	L	L	-	2.18	-	-
L3		L	2.5	1.5	16	10		-	-	-	L	NA	L	-	-
6	Spare	-	-	-	60898	C	-	-	-	-	-	-	2.91	-	-
L3		-	-	-	6	10		-	-	-	-	-	-	-	-
7	Lights This Room	5	T+E	B	60898	B	0.4	-	-	0.43	L	-	3.49	-	-
L3		P	3X1.5	3X1	10	10		-	-	-	L	NA	0.17	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Stu Smith	13/03/2020	Multi-tester	9ABC		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5	
			mm ²	mm ²	A	kA	s					Ω	Test Button	ms	
1	DB C/12 S36787	1	S	B	60947	3	5	-	-	0.01	200	500	L	-	-
L123		P	25	25	125	L		-	-	-	200	NA	0.17	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
Sean Smith		03/03/2020	Multi-tester		9ABC			
Stu Smith								


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length 1 metre
 PVC Singles 25 mm²

Internal Rating

Not IP2X



Earthing Arrangements

PFC 2.74 kA
 Earth Loop 0.17 Ohms
 PVC Singles, 25 mm²

Supplied From DB C/12 ISO 1L123 via Contactor
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA					AFDD Function	Ω	Test Button	ms	
1	Dimmer 1	1	S	B	60898	B	0.4	-	-	0.03	L	-	1.08	-	-
L1		P	6	6	32	10		-	-	-	L	NA	0.20	-	-
1	Dimmer 2	1	S	B	60898	B	0.4	-	-	0.03	L	-	1.08	-	-
L2		P	6	6	32	10		-	-	-	L	NA	0.20	-	-
1	Dimmer 3	1	S	B	60898	B	0.4	-	-	0.05	L	-	1.08	-	-
L3		P	6	6	32	10		-	-	-	L	NA	0.22	-	-
2	Dimmer 4	1	S	B	60898	B	0.4	-	-	0.03	L	-	1.08	-	-
L1		P	6	6	32	10		-	-	-	L	NA	0.20	-	-
2	Dimmer 5	1	S	B	60898	B	0.4	-	-	0.04	L	-	1.08	-	-
L2		P	6	6	32	10		-	-	-	L	NA	0.21	-	-
2	Dimmer 6	1	S	B	60898	B	0.4	-	-	0.03	L	-	1.08	-	-
L3		P	6	6	32	10		-	-	-	L	NA	0.20	-	-
3	Dimmer 7	1	S	B	60898	B	0.4	-	-	0.06	L	-	1.08	-	-
L1		P	6	6	32	10		-	-	-	L	NA	0.23	-	-
3	Dimmer 8	1	S	B	60898	B	0.4	-	-	0.03	L	-	1.08	-	-
L2		P	6	6	32	10		-	-	-	L	NA	0.20	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Dimmer Head 4	1	FLEX	B	60898	B	0.4	-	-	0.07	L	-	5.82	-	-
L1		P	1.5	1.5	6	10		-	-	-	L	NA	0.24	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L2		-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
Stu Smith Sean Smith	03/03/2020	Multi-tester	9ABC		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable



Supply Cables
 Length Unknown
 SWA 70 mm²

Earthing Arrangements
 PFC 2.48 kA
 Earth Loop 0.18 Ohms
 Cable Sheath

Internal Rating
 IP2X

Supplied From Main Intake Panel 8L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Points Served Polarity	Cable		Overcurrent Device		Dis Time s	Continuity Test			Insulation Test		Earth Loop Max Z _s Z _s Ω	R.C.D. Test	
No Ø	Designation		Wiring Phase mm ²	Method CPC mm ²	BS No Rating A	Type Rating kA		r1 Ω	r2 Ω	R1+R2 R2 Ω	L/L L/E MΩ	Test Voltage AFDD Function		Rating mA Test Button	x1 x5 ms
1 L123	ACU No 1 Roof	1 P	SWA 2.5	B CS	60898 20	C 10	0.4	- -	- -	0.17 -	200 200	500 NA	0.87 0.35	- -	- -
2 L123	ACU No 2 Roof	1 P	SWA 2.5	B CS	60898 20	C 10	0.4	- -	- -	0.12 -	200 200	500 NA	0.87 0.30	- -	- -
3 L123	ACU No 3 Roof	1 P	SWA 2.5	B CS	60898 20	C 10	0.4	- -	- -	0.15 -	200 200	500 NA	0.87 0.33	- -	- -
4 L123	ACU No 4 Roof	1 P	SWA 2.5	B CS	60898 20	C 10	0.4	- -	- -	0.13 -	200 200	500 NA	0.87 0.31	- -	- -
5 L1	Lift Room DB 11 S36870	1 P	SWA 10	B 1	60898 40	C 10	5	- -	- -	0.01 -	200 200	500 NA	0.43 0.18	- -	- -
5 L2	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -
5 L3	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -
6 L123	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -
7 L1	Warm Air Damper - Not Located	L L	T+E 1.5	B 1	60898 6	C 10	0.4	- -	- -	L -	200 200	250 NA	2.91 L	- -	- -
7 L2	ACU Retail Offices - Door	1 P	SWA 4	B 4	60898 32	C 10	0.4	- -	- -	0.08 -	200 200	500 NA	0.54 0.26	- -	- -
7 L3	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -
8 L123	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -
9 L123	Blank	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L L/E	Test Voltage AFDD Function		Max Z s Zs	Rating mA
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Ω	Test Button	x5 ms	
10	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
11	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-
12	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	26/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
													Test Button		
1	SW below Labelled Shaft Lights	1	S	B	60898	C	0.4	-	-	0.1	200	250	1.08	-	-
L1		L	2.5	2.5	16	10		-	-	-	200	NA	0.19	-	-
2	Speech Synth, REC & Car Lights	2	S	B	60898	C	0.4	-	-	0.05	L	250	1.74	-	-
L1		L	2.5	2.5	10	10		-	-	-	0.01	NA	0.23	-	-
3	Lights	L	S	B	60898	C	0.4	-	-	L	200	250	1.74	-	-
L1		L	2.5	2.5	10	10		-	-	-	200	NA	L	-	-
3	Unknown via Socket Below	L	S	B	60898	C	0.4	-	-	0.01	L	L	1.74	-	-
L1		L	1.5	1.5	10	10		-	-	-	L	NA	0.19	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L1		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	26/02/2020	Multi-tester	493/21MLT		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable




Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Spare	-	-	-	3871	2	-	-	-	-	-	L	-	-	
L1		-	-	-	L	9	-	-	-	-	-	-	-	-	
1	RCD Unit for 1L1	-	-	-	4293	-	-	-	-	-	-	1667	30	19	
L23		-	-	-	L	-	-	-	-	-	NA	-	P	15	
2	Display Sockets L/HS	4	SWA	C	3871	2	0.4	0.18	-	0.27	200	500	-	-	
L1		P	2X2.5	CS	L	9	-	0.18	-	-	200	NA	0.43	-	
2	RCD Unit for 2L1	-	-	-	4293	-	-	-	-	-	-	1667	30	18.5	
L23		-	-	-	-	-	-	-	-	-	NA	-	P	15.4	
3	High Level Sockets Above Ceilings	1	SWA	E	3871	2	0.4	-	-	L	7.5	500	-	-	
L1		L	6	6	L	9	-	-	-	-	7.5	NA	L	-	
3	RCD Unit for 3L1	-	-	-	4293	-	-	-	-	-	-	1667	30	29	
L23		-	-	-	-	-	-	-	-	-	NA	-	P	16	
4	DB G/2 T44636	1	SWA	A	3871	D	5	-	-	0.01	999	500	-	-	
L123		P	6	10/CS	40	10	-	-	-	-	999	NA	0.43	-	
5	Spare	-	-	-	3871	C	-	-	-	-	-	-	-	-	
L1		-	-	-	63	10	-	-	-	-	-	-	-	-	
5	Spare	-	-	-	3871	B	-	-	-	-	-	-	-	-	
L2		-	-	-	16	10	-	-	-	-	-	-	-	-	
5	DB G/A S36793	1	T+E	C	3871	B	5	-	-	0.01	999	500	1.08	-	
L3		P	10	4	32	10	-	-	-	-	999	NA	0.17	-	
6	DB G/3 T44637	1	SWA	A	3871	D	5	-	-	0.12	999	500	0.43	-	
L123		P	10	25/CS	40	10	-	-	-	-	999	NA	0.19	-	
7	Unused MCB Below DB Fed From	1	FLEX/S	B	-	-	5	-	-	0.01	999	500	-	-	
L123	Live Side of M/S	P	25	35	-	-	-	-	-	-	999	NA	0.17	-	

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	04/11/2019	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms
1	Plant Room 3 Chiller	1	SWA	E	60898	D	0.4	-	-	0.13	200	500	0.27	-
L123		P	6	CS	32	10		-	-	-	200	NA	0.30	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-		-	-	-	-	-	-	-
3	Plant Room 3 Boiler Supply	1	SWA	E	60898	D	0.4	-	-	0.20	200	500	0.27	-
L123		P	4	CS	32	10		-	-	-	200	NA	0.37	-
4	Lights Plant Room 3	2	S	B	3871	2	0.4	-	-	0.13	200	500	4.16	-
L1		P	1.5	1.5	6	9		-	-	-	200	NA	0.30	-
4	RCD Socket by DB	1	S	B	3871	2	0.4	-	-	0.01	200	500	1.24	-
L2		P	2.5	2.5	20	9		-	-	-	200	NA	0.18	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-		-	-	-	-	-	-	-

Tested By		Test Date		Instrument Type		Serial No	
P Anderson		05/11/2019		Multi-tester		493/21MLT	

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length 2 metres
 VIR 4 mm²

Internal Rating

Not IP2X

DB G/4
 Hall 1 Sea King Exhibition

Hager Distribution Board
 RCD SP&N L3 phase 6 ways

RCD Details BS (EN) 4293 63 A 30 mA 2 pole
Test Results 1x 33 ms 5x 11 ms
Test Button Pass **Asset No.** S36793

Earthing Arrangements

PFC 1.33 kA
 Earth Loop 0.17 Ohms
 Integral C.P.C., 4 mm²


Supplied From DB G/1 5L3
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	Ω	Ω	Ω	L/E	AFDD Function	Zs	mA	x5	
			mm ²	mm ²	A	kA	s			MΩ		Ω	Test Button	ms	
1	Power Plinth	7	T+E	B	60898	B	0.4	0.12	0.15	0.37	200	500	1.08	30	-
L3		P	2X2.5	2X1.5	32	6		0.10		-	200	NA	0.57	-	-
2	Sockets Here & Far Wall	3	T+E	B	60898	B	0.4	0.24	0.39	0.38	200	500	1.08	30	-
L3		P	2X2.5	2X1.5	32	6		0.23		-	200	NA	0.87	-	-
3	Sockets Below & Camera	2	T+E	B	60898	C	0.4	-	-	0.02	200	500	1.08	30	-
L3		P	2.5	1.5	16	10		-	-	-	200	NA	0.52	-	-
4	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-
6	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		04/11/2019	Multi-tester		493/21MLT			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms
1	RCD Socket by DB	1	S	B	3871	2	0.4	-	-	0.01	200	500	1.24	-
L1		P	2.5	2.5	20	9		-	-	-	200	NA	0.20	-
1	Lights Plant Room 2	2	S	B	3871	2	0.4	-	-	0.20	200	500	4.16	-
L2		P	1.5	1.5	6	9		-	-	-	200	NA	0.39	-
1	FCU CCTV Camera	1	SWA	E	60898	B	0.4	-	-	0.29	200	500	5.82	-
L3		P	2.5	CS	6	10		-	-	-	200	NA	0.48	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L123		-	-	-	-	-		-	-	-	-	-	-	-
3	Plant Room 2 Boiler	1	SWA	E	60898	D	0.4	-	-	0.09	200	500	0.27	-
L123		P	6	CS	32	10		-	-	-	200	NA	0.28	-
4	Plant Room 2 Chiller Unit	1	SWA	E	60898	D	0.4	-	-	0.09	200	500	0.27	-
L123		P	6	CS	32	10		-	-	-	200	NA	0.28	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	05/11/2019	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	S36825, Sub E/BB L123	1	SWA	E	3036	-	5	-	-	0.06	200	500	0.40	-	-
		P	35	CS	100	4		-	-	-	200	NA	0.38	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		27/02/2020	Multi-tester		493/21MLT			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating	x1
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	Isolator S36828	1	S	B	-	-	5	-	-	0.01	999	500	0.40	-	-
L123		P	25	25	-	-	-	-	-	-	999	NA	0.39	-	-
2	Isolator S36827	1	S	B	-	-	5	-	-	0.01	999	500	0.40	-	-
L123		P	25	25	-	-	-	-	-	-	999	NA	0.39	-	-
3	Supply to Isolators S36826	1	S	B	-	-	5	-	-	0.01	999	500	0.40	-	-
L123		P	10	16	-	-	-	-	-	-	999	NA	0.39	-	-
4	Isolator S36829	1	S	B	-	-	5	-	-	0.01	999	500	0.40	-	-
L123		P	25	16	-	-	-	-	-	-	999	NA	0.39	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	27/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	Supply to DB E/1 S36831 L123	1	S	B	88	2	5	-	-	0.01	200	500	0.31	-	-
		P	25	25	100	80		-	-	-	200	NA	0.40	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		12/02/2020	Multi-tester		493/21MLT			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Guillotine	1	SWA	C	3871	B	0.4	-	-	0.05	200	500	1.08	-	-
L123		P	6	6	32	9		-	-	-	200	NA	0.45	-	-
2	Grinder	1	S	B	3871	B	0.4	-	-	0.32	200	500	3.49	-	-
L123		P	2.5	2.5	10	9		-	-	-	200	NA	0.72	-	-
3	Meter L1	1	S	B	3871	2	0.4	-	-	0.01	200	500	4.99	-	-
L1		P	2.5	MF	5	9		-	-	-	200	NA	0.41	-	-
3	Meter L2	1	S	B	3871	2	0.4	-	-	0.01	200	500	4.99	-	-
L2		P	2.5	MF	5	9		-	-	-	200	NA	0.41	-	-
3	Meter L3	1	S	B	3871	2	0.4	-	-	0.01	200	500	4.99	-	-
L3		P	2.5	MF	5	L		-	-	-	200	NA	0.41	-	-
4	Pillar Drill	1	S	B	3871	B	0.4	-	-	0.10	200	500	1.24	-	-
L123		P	4	4	20	9		-	-	-	200	NA	0.50	-	-
5	Welder	1	S	B	3871	C	0.4	-	-	0.16	200	500	0.87	-	-
L123		P	2.5	2.5	20	9		-	-	-	200	NA	0.56	-	-
6	Spare	-	-	-	3871	3	-	-	-	-	-	-	0.87	-	-
L1		-	-	-	20	9		-	-	-	-	-	-	-	-
6	Spare	-	-	-	3871	3	-	-	-	-	-	-	0.87	-	-
L2		-	-	-	20	9		-	-	-	-	-	-	-	-
6	Spare	-	-	-	3871	2	-	-	-	-	-	-	0.77	-	-
L3		-	-	-	32	6		-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	12/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2	L/L		Test Voltage	Max Zs	Rating
Ø		Polarity	mm²	mm²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	DB E/2 S36830	1	S	B	88	2	5	-	-	L	0.13	250	0.62	-	-
L123		L	16	MF	63	30		-	-	0.01	0.01	NA	L	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	06/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
0	Unable to Access Due to Asbestos	-	-	-	-	-	-	-	-	-	-	-	-	-	-
		-	-	-	-	-	-	-	-	-	NA	-	-	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		06/02/2020	Multi-tester		493/21MLT			

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**




Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating		Type Rating	r1	r2	R1+R2 R2	L/L L/E		Test Voltage AFDD Function	Max Z s Zs	Rating mA Test Button
1	DB E/4 S33834 L123	2	SWA 10	B CS/10	88 100	2 80	5	-	-	0.11	200 200	500 NA	0.31 0.50	-	-
1	DB E/3 T444668 L1	1	SWA 10	C 10	88 100	2 80	5	-	-	0.01	200 200	500 NA	0.31 0.40	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	06/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating	x1
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Z _s Ω	mA	x5 ms	
1	16A Socket	1 P	S 6	B 6	60898 32	B 6	0.4	-	-	0.02	200 200	500 NA	1.08 0.46	- -	- -
2	Gas Heater	1 P	FLEX 1.5	B 1.5	60898 16	B 6	0.4	-	-	0.13	200 200	500 NA	2.18 0.57	- -	- -
3	Fire Alarm	1 P	FP200 1.5	B 1.5	60898 10	C 6	0.4	-	-	0.93	200 200	500 NA	1.74 1.37	- -	- -
4	Blank	- -	- -	- -	- -	- -	-	-	-	-	- -	- -	- -	- -	- -
0	RCD for Circuits 5-7	- -	- -	- -	- -	- -	-	-	-	-	- NA	-	-	30 P	156 27.4
5	Weld Bench Sockets	5 P	S 2X2.5	B 2X2.5	60898 32	B 6	0.4	0.21 0.18	0.15	0.05	200 200	500 NA	1.08 0.79	- -	- -
6	220 Work Bench Sockets	5 P	T+E 2X2.5	B 2X2.5	60898 32	B 6	0.4	0.36 0.41	0.64	0.10	200 200	500 NA	1.08 0.65	- -	- -
7	Cooker R/H/S	1 P	T+E 2.5	B 1.5	60898 16	B 6	0.4	-	-	0.11	200 200	500 NA	2.18 0.82	- -	- -

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	06/02/2020	Multi-tester	493/21MLT		

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length 30 metres
SWA 10 mm²

Internal Rating

IP2X

DB E/4 Central Workshop
Merlin Gerin Distribution Board RCD TP&N 18 ways (total)
RCD Details BS (EN) 4293 63 A 30 mA 2 pole
Test Results 1x 20 ms 5x 7 ms
Test Button Pass Asset No. S36834

Earthing Arrangements

PFC 0.82 kA
Earth Loop 0.50 Ohms
PVC Singles, 10 mm²
Cable Sheath

Supplied From DB C/20 ISO 1L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
											AFDD Function	Ω	Test Button	ms	
1	DB Above S36835 Redundant	1	S	B	60898	B	5	-	-	0.01	200	500	0.55	-	-
L1		L	16	16	63	10		-	-	-	200	NA	0.61	-	-
1	Socket for Pillar Drill	1	S	B	60898	2	0.4	-	-	0.28	200	500	1.54	-	-
L2		P	2.5	2.5	16	9		-	-	-	200	NA	0.78	-	-
1	Lights Far	4	S	B	60898	B	0.4	-	-	0.82	L	250	5.82	-	-
L3		P	1.5	1.5	6	10		-	-	-	0.25	NA	1.31	-	-
2	Sockets Laundry Far End	2	S	B	60898	B	0.4	0.48	0.47	0.31	200	500	1.08	-	-
L1		P	2X2.5	2X2.5	32	10		0.45	-	-	200	NA	0.81	-	-
2	Generator DB E/4/2B T44692	2	S	B	60898	B	5	-	-	0.12	200	500	1.08	-	-
L2		P	6	6	32	10		-	-	-	200	NA	0.62	-	-
2	Supply to Emergency Generator	1	SWA	B	3871	2	0.4	-	-	0.01	200	500	1.66	-	-
L3		P	2.5	2.5	15	6		-	-	-	200	NA	0.50	-	-
3	Water Heater	1	S	B	3871	2	0.4	-	-	0.40	200	500	1.66	-	-
L1		P	4	4	15	6		-	-	-	200	NA	0.90	-	-
3	Workshop Sockets Far	2	S	B	60898	B	0.4	-	-	0.17	200	500	1.08	-	-
L2		P	6	6	32	10		-	-	-	200	NA	0.67	-	-
3	Central Sockets	2	FLEX	B	60898	B	0.4	-	-	0.46	200	500	2.18	-	-
L3		P	1.5	1.5	16	10		-	-	-	200	NA	0.98	-	-
4	Table Saw	1	SY FLEX	B	60898	C	0.4	-	-	0.53	200	500	1.08	-	-
L1		P	1.5	1.5	16	10		-	-	-	200	NA	1.03	-	-
4	Workshop Sockets Near L/H/S	4	S	B	3871	2	0.4	0.45	0.21	0.23	200	500	0.77	-	-
L2		P	2X2.5	2X2.5	32	6		0.45	-	-	200	NA	0.73	-	-
4	Lights Near & Behind DB	4	S	B	60898	B	0.4	-	-	0.58	L	250	5.82	-	-
L3		P	1.5	1.5	6	10		-	-	-	0.30	NA	1.08	-	-
5	Dust Extractor	1	SWA	B	60898	C	0.4	-	-	0.93	200	500	1.74	-	-
L123		P	1.5	1.5	10	10		-	-	-	200	NA	1.43	-	-

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs Ω	mA Test Button	x5 ms
6	3 Phase Socket on Side of this DB	1	S	B	60898	D	0.4	-	-	0.01	200	500	0.43	-	-
L123		P	4	4	20	10		-	-	-	200	NA	0.51	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	06/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Supply Cables

Length Unknown
 SWA 2.5 mm²

Internal Rating

Not IP2X

DB E/4/2B
 Generator Outside Workshop

Square D Distribution Board
 RCD SP&N L3 phase 6 ways

RCD Details BS (EN) 4293 80 A 100 mA 2 pole
Test Results
Test Button **Asset No.** T44692

Earthing Arrangements

PFC 0.82 kA
 Earth Loop 0.50 Ohms
 Integral C.P.C., 2.5 mm²


Supplied From DB E/4 2L3
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating
Ø		Polarity	Phase mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Z _s Ω	mA	x5 ms
1	Lighting in Generator Room	6	S	B	3871	3	0.4	-	-	0.79	L	250	2.91	100
L3		P	1.5	1.5	6	9		-	-	-	0.32	NA	1.29	-
2	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-
3	Blank	-	-	-	-	-	-	-	-	-	-	-	-	-
L3		-	-	-	-	-	-	-	-	-	-	-	-	-
4	Unidentified	L	S	B	3871	2	0.4	-	-	L	L	250	4.16	100
L3		L	1.5	1.5	6	9		-	-	-	999	NA	L	-
5	Power Socket Below DB	1	S	B	3871	3	0.4	-	-	0.13	999	500	1.16	100
L3		P	2.5	2.5	15	9		-	-	-	999	NA	0.63	-
6	Battery Charger & Heater	2	S	B	3871	2	0.4	-	-	0.58	999	500	0.55	100
L3		P	6	6	45	9		-	-	-	999	NA	1.08	-

Tested By		Test Date		Instrument Type		Serial No	
P Anderson		06/02/2020		Multi-tester		493/21MLT	

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable




Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L L/E	Test Voltage AFDD Function		Max Z s	Rating mA
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	Test Button	x5	
1	Spare L1	-	-	-	60898 32	C 10	-	-	-	-	-	-	-	-	-
2	Spare L1	-	-	-	60898 16	C 10	-	-	-	-	-	-	-	-	-
3	Spare L1	-	-	-	60898 6	B 6	-	-	-	-	-	-	-	-	-
4	Spare L1	-	-	-	60898 6	B 6	-	-	-	-	-	-	-	-	-
5	Spare L1	-	-	-	60898 16	B 6	-	-	-	-	-	-	-	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	06/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring Phase	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Zs	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Zs Ω	mA	x5 ms	
1	DB E/6 S36836	1	SWA	B	88	2	5	-	-	0.04	200	500	0.34	-	-
L123		P	25	16	100	80		-	-	-	200	NA	0.43	-	-

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		11/02/2020	Multi-tester		493/21MLT			


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length Unknown
SWA 25 mm²

Internal Rating

Unknown



Earthing Arrangements

PFC 1.58 kA
Earth Loop 0.43 Ohms
PVC Singles, 16 mm²
Cable Sheath

Supplied From IS DB/E/6 1L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
			mm ²	mm ²	A	kA							Ω	Test Button	ms
1	Supply to DB E/8 S36839	1	PVC/PVC	B	60898	B	5	-	-	0.01	200	500	0.09	-	-
L1		P	16	16	63	10		-	-	-	200	NA	0.45	-	-
1	Kitchen Ring	6	T+E	A	60898	B	0.4	F	F	0.83	200	250	1.08	-	-
L2		P	2X2.5	2X1.5	32	10		F	-	-	200	NA	1.26	-	-
1	Door Magnets	1	T+E	A	60898	B	0.4	-	-	0.86	200	500	1.08	-	-
L2		P	2.5	1.5	32	10		-	-	-	200	NA	0.49	-	-
1	Bar Ring	4	T+E	B	60898	B	0.4	0.21	0.36	0.14	200	500	1.08	-	-
L3		P	2X2.5	2X1.5	32	10		0.21	-	-	200	NA	0.57	-	-
2	Dishwasher	1	SWA	B	60898	C	0.4	-	-	0.22	200	500	0.87	-	-
L123		P	2.5	2.5	20	10		-	-	-	200	NA	0.65	-	-
3	Spare	-	-	-	60898	B	-	-	-	-	-	-	2.18	-	-
L123		-	-	-	16	10		-	-	-	-	-	-	-	-
4	3 Phase Socket Below	1	S	B	60898	B	0.4	-	-	0.01	200	500	0.69	-	-
L123		P	16	16	63	10		-	-	-	200	NA	0.44	-	-
5	DB E/7 S36837	1	S	B	5419	-	5	-	-	0.01	200	500	0.11	-	-
L123		P	25	25	125	-		-	-	-	200	NA	0.44	-	-
6	Socket by Bar Door	1	T+E	B	60898	C	0.4	-	-	0.22	200	500	1.08	-	-
L1		P	2.5	1.5	16	10		-	-	-	200	NA	0.65	-	-
6	Floor Socket Middle	8	T+E	B	60898	B	0.4	F	F	0.48	200	500	1.08	-	-
L2		P	2X2.5	2X1.5	32	10		F	-	-	200	NA	0.92	-	-
6	Spare	-	-	-	60898	B	-	-	-	-	-	-	1.08	-	-
L3		-	-	-	32	10		-	-	-	-	-	-	-	-
7	Wall Sockets L/H/S	6	T+E	B	60898	B	0.4	0.74	1.19	0.47	200	500	1.08	-	-
L1		P	2X2.5	2X1.5	32	10		0.74	-	-	200	NA	0.91	-	-
7	Wall Sockets R/H/S	6	T+E	B	60898	B	0.4	0.67	1.06	0.42	200	500	1.08	-	-
L2		P	2X2.5	2X1.5	32	10		0.69	-	-	200	NA	0.86	-	-

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Zs	mA	x5
7	Bar Ring	4	T+E	B	60898	B	0.4	0.18	0.33	0.31	200	500	1.08	-	-
L3		P	2X2.5	2X1.5	32	10		0.20		-	200	NA	0.75	-	-
8	Ceiling Sockets CCTV	L	SWA	B	60898	B	0.4	-	-	L	L	-	1.08	-	-
L1		L	4	4	32	10		-	-	-	L	NA	L	-	-
8	Lights Prep Room	6	T+E	B	60898	B	0.4	-	-	0.83	L	250	5.82	-	-
L2		P	1.5	1	6	10		-	-	-	0.01	NA	1.31	-	-
8	Socket this Room	1	T+E	B	3871	2	0.4	-	-	0.01	200	500	0.99	-	-
L3		P	2.5	1.5	25	9		-	-	-	200	NA	0.44	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	13/02/2020	Multi-tester	493/21MLT		


Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Supply Cables

Length 3 metres
PVC/PVC Tails 25 mm²

Internal Rating

IP2X



Earthing Arrangements

PFC 0.51 kA
Earth Loop 0.45 Ohms
PVC Singles, 16 mm²

Supplied From DB F/1 1L1
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test		
No	Designation	Points Served	Wiring	Method	BS No		Type	r1	r2	R1+R2	L/L		Test Voltage	Max Z _s	Rating
Ø		Polarity	Phase	CPC	Rating	Rating	s	Ω	Ω	Ω	MΩ	Z _s	mA	x5	
			mm ²	mm ²	A	kA						Ω	Test Button	ms	
1	Lobby/Foyer Lights	14	T+E	B	60898	B	0.4	-	-	0.35	L	250	5.82	-	-
L1		P	1.5	1	6	6		-	-	-	0.01	NA	0.80	-	-
2	WCs Lights	14	T+E	B	60898	B	0.4	-	-	1.20	L	250	5.82	-	-
L1		P	1	1	6	6		-	-	-	0.01	NA	1.65	-	-
0	RCD for Circuits 3-12	-	-	-	-	-	-	-	-	-	-	-	-	30	43.5
		-	-	-	-	-	-	-	-	-	-	NA	-	P	11.2
3	Ladies Hand Dryer	1	T+E	B	60898	B	0.4	L	L	0.60	200	500	1.74	-	-
L1		P	2X2.5	2X1.5	20	6		L		-	200	NA	1.05	-	-
4	Unidentified	1	T+E	B	60898	B	0.4	-	-	L	L	250	2.18	-	-
L1		L	2.5	1.5	16	6		-	-	-	200	NA	L	-	-
5	Ladies Water Heater	1	T+E	B	60898	B	0.4	-	-	0.10	200	500	2.18	-	-
L1		P	2.5	1.5	16	6		-	-	-	200	NA	0.55	-	-
6	Gents Water Heater	1	T+E	B	60898	B	0.4	-	-	0.73	200	500	2.18	-	-
L1		P	2.5	1.5	16	6		-	-	-	200	NA	1.15	-	-
7	Ladies/Gents Sensors	5	T+E	B	60898	B	0.4	-	-	0.80	200	500	5.82	-	-
L1		P	2X1.5	2X1	6	6		-	-	-	200	NA	1.25	-	-
8	Gents Hand Dryer	1	T+E	B	60898	B	0.4	-	-	0.20	200	500	2.18	-	-
L1		P	2.5	1.5	16	6		-	-	-	200	NA	0.65	-	-
9	Foyer Socket	1	T+E	B	60898	B	0.4	-	-	0.47	200	500	2.18	-	-
L1		P	2.5	1.5	16	6		-	-	-	200	NA	0.92	-	-
10	Disabled Hand Dryer	1	T+E	B	60898	B	0.4	-	-	0.73	200	500	3.49	-	-
L1		P	2.5	1.5	10	6		-	-	-	200	NA	1.18	-	-
11	Extractor Fans	1	T+E	B	60898	B	0.4	-	-	2.46	200	500	5.82	-	-
L1		P	1.5	1	6	6		-	-	-	200	NA	2.91	-	-
12	Gents Heaters	1	T+E	B	60898	B	0.4	-	-	L	L	250	2.18	-	-
L1		L	2.5	1.5	16	6		-	-	-	200	NA	L	-	-


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method	BS No	Type		r1	r2	R1+R2	L/L	Test Voltage		Max Z s	Rating
Ø		Polarity	mm ²	CPC mm ²	Rating A	Rating kA	s	Ω	Ω	Ω	MΩ	Ω	mA	x5	

Tested By		Test Date	Instrument Type		Serial No	Instrument Type		Serial No
P Anderson		13/02/2020	Multi-tester		493/21MLT			

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable



Supply Cables

Length 1 metre
PVC Singles 25 mm²

Internal Rating

Unknown

Earthing Arrangements

PFC 1.04 kA
Earth Loop 0.44 Ohms
PVC Singles, 16 mm²

Supplied From DB F/1 5L123
Secondary Supply None

Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L L/E	Test Voltage AFDD Function		Max Zs	Rating mA
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	Test Button	x5	
1	Spare	-	-	-	60898	D	-	-	-	-	-	0.54	-	-	
L1		-	-	-	16	10	-	-	-	-	-	-	-	-	
1	Kitchen Wash Up Heater	1	T+E	B	60898	C	0.4	-	-	0.27	200	500	1.74	-	
L2		P	2.5	1.5	10	10	-	-	-	-	200	NA	0.71	-	
1	Spare	-	-	-	60898	B	-	-	-	-	-	1.08	-	-	
L3		-	-	-	32	10	-	-	-	-	-	-	-	-	
2	Stage Winch	L	T+E	B	60898	C	0.4	-	-	L	L	250	1.74	-	
L1		L	6	2.5	10	10	-	-	-	-	160	NA	L	-	
2	Steam Extract in Wash Area	1	T+E	B	60898	D	0.4	-	-	0.52	200	500	0.54	-	
L2		P	2.5	1.5	16	10	-	-	-	-	200	NA	0.93	-	
2	Room 221 DB E/9 T44691	1	SWA	B	60898	C	5	-	-	0.23	200	500	0.35	-	
L3		P	16	16	63	10	-	-	-	-	200	NA	0.67	-	
3	Above Stage Fan	1	FLEX	E	60898	B	0.4	-	-	1.64	200	500	5.82	-	
L123		P	1.5	1.5	6	10	-	-	-	-	200	NA	2.18	-	
4	Heater Above Ceiling	L	FLEX	B	60898	B	0.4	-	-	0.33	200	500	5.82	-	
L123		P	1.5	1.5	6	10	-	-	-	-	200	NA	0.77	-	
5	Overhead Lights No 1	10	T+E	B	60898	B	0.4	-	-	1.77	L	250	2.18	-	
L1		P	1.5	1	16	6	-	-	-	-	0.01	NA	2.21	-	
5	Overhead Lights No 2	10	T+E	B	60898	B	0.4	-	-	1.61	L	250	2.18	-	
L2		P	1.5	1	16	6	-	-	-	-	0.01	NA	2.15	-	
5	Overhead Lights No 3	10	T+E	B	60898	B	0.4	-	-	1.50	L	250	2.18	-	
L3		P	1.5	1	16	6	-	-	-	-	0.01	NA	1.94	-	
6	L/H/S Wall Lights	4	T+E	B	60898	B	0.4	-	-	1.24	L	250	5.82	-	
L1		P	1.5	1	6	10	-	-	-	-	0.01	NA	1.68	-	
6	R/H/S Wall Lights	4	T+E	B	60898	B	0.4	-	-	1.67	L	250	5.82	-	
L2		P	1.5	1	6	10	-	-	-	-	0.01	NA	1.71	-	


Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**

Circuit Schedule and Test Results

CIRCUIT			Cable		Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Z _s	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	AFDD Function	Z _s Ω	mA Test Button	x5 ms
6	Centre Downlights	14	T+E	B	60898	B	0.4	-	-	1.10	L	250	5.82	-	-
L3		P	1.5	1	6	10		-	-	-	0.01	NA	1.54	-	-
7	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-	-
L1		-	-	-	6	10		-	-	-	-	-	-	-	-
7	Spare	-	-	-	60898	B	-	-	-	-	-	-	5.82	-	-
L2		-	-	-	6	10		-	-	-	-	-	-	-	-
7	R/H/S Stage Lecturn Light	L	T+E	B	60898	B	0.4	-	-	0.63	L	250	5.82	-	-
L3		P	2.5	1.5	6	10		-	-	-	0.01	NA	1.07	-	-
8	L/H/S Stage Lecturn Light	L	T+E	B	60898	B	0.4	-	-	0.83	L	250	5.82	-	-
L1		P	2.5	1.5	6	10		-	-	-	0.01	NA	1.27	-	-
8	Bar Front Lights	10	T+E	B	60898	C	0.4	-	-	0.33	L	250	1.74	-	-
L2		P	1.5	1	10	10		-	-	-	0.01	NA	0.77	-	-
8	RCD Unit Above	L	T+E	B	60898	C	0.4	-	-	0.01	200	500	0.54	-	-
L3		P	6	2.5	32	10		-	-	-	200	NA	0.45	-	-

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	13/02/2020	Multi-tester	493/21MLT		

Occupier **Fleet Air Arm Museum**
 Installation Address **Main Museum, RNAS Yeovilton**
 Specific Location **Not Applicable**



Circuit Schedule and Test Results

CIRCUIT		Cable			Overcurrent Device		Dis Time	Continuity Test			Insulation Test		Earth Loop	R.C.D. Test	
No	Designation	Points Served	Wiring Phase	Method CPC	BS No Rating	Type Rating		r1	r2	R1+R2	L/L	Test Voltage		Max Zs	Rating
Ø		Polarity	mm ²	mm ²	A	kA	s	Ω	Ω	Ω	MΩ	Zs	mA	x5	
												Ω	Test Button	ms	
1	Spare	-	-	-	3036	-	-	-	-	-	-	1.93	-	-	
L3		-	-	-	15	4	-	-	-	-	-	-	-	-	
2	Spare	-	-	-	3036	-	-	-	-	-	-	1.93	-	-	
L3		-	-	-	15	4	-	-	-	-	-	-	-	-	
3	Spare	-	-	-	3036	-	-	-	-	-	-	0.83	-	-	
L3		-	-	-	30	4	-	-	-	-	-	-	-	-	
4	Sockets Ring	3	S	B	3036	-	0.4	0.36	0.52	0.23	200	250	0.83	-	
L3		P	2X2.5	2X1.5	30	4	-	0.36	-	-	200	NA	0.90	-	
5	Spare	-	-	-	3036	-	-	-	-	-	-	7.28	-	-	
L3		-	-	-	5	4	-	-	-	-	-	-	-	-	
6	Spare	-	-	-	3036	-	-	-	-	-	-	7.28	-	-	
L3		-	-	-	4	4	-	-	-	-	-	-	-	-	
7	Lights This End	5	S	B	3036	-	0.4	-	-	0.38	L	250	7.28	-	
L3		P	1.5	1.5	5	4	-	-	-	-	45	NA	1.05	-	
8	Lights This End	4	S	B	3036	-	0.4	-	-	0.72	L	250	4.28	-	
L3		P	1.5	1.5	4	4	-	-	-	-	45	NA	1.39	-	

Tested By	Test Date	Instrument Type	Serial No	Instrument Type	Serial No
P Anderson	16/03/2020	Multi-tester	493/21MLT		

Report Abbreviations

Occupier Fleet Air Arm Museum
Installation Address Main Museum, RNAS Yeovilton
Specific Location Not Applicable

Abbreviation	Meaning	Abbreviation	Meaning
-	The item has been considered but is not applicable	ADS	Automatic Disconnection of Supply
AFDD	Arc Fault Detection Device	BBC	Busbar Chamber
BS3036	Rewirable Fusible Link	BS3871	Miniature Circuit Breaker
BS88/BS1361	General Purpose Cartridge Fuses	BSEN60898	Miniature Circuit Breaker
BSEN60947-2	Moulded Case Circuit Breaker	BSEN61009	Combined MCB/RCD
C	Continuity Confirmed by Earth Loop Impedance Tester	C/W	Copper Wire
CON	Concentric	CPC	Circuit Protective Conductor
CS	Cable Sheath	DB	Distribution Board
EEBADS	Earthed Equipotential Bonding and Automatic Disconnection of Supply	F	Fail
FELV	Functional extra low voltage	FP200	Fire Retardant Cable
INA	Information Not Available	IP2X	Protection against approach by fingers
ISO	Isolator Switch	L or LIM	Limitation of Test
LS	Lead Sheathed Cable	MCB	Miniature Circuit Breaker BS3871, BSEN60898
MCCB	Moulded Case Circuit Breaker	Method	Refer to BS7671 Appendix 4 Table 4A2 for full list of Reference Methods
MF	Metal Conduit/Trunking System Provides main C.P.C.	MI/MICC	Mineral Insulated Copper Conductor Cables
NA	Not Applicable	P	Pass
PELV	Protective extra low voltage	PFC	Prospective Fault Current
PILSWA	Paper Insulated Lead Steel Wire Armour	PVC/PVC	PVC Insulated PVC Sheathed Singles (tails)
RCBO	Residual Current Breaker with Overcurrent Protection	RCCB	Residual Current Circuit Breaker
RCD	Residual Current Device	S	PVC Insulated Single Cable
SELV	Separated extra low voltage	SL	Solid Link
SP+N	Single Pole and Neutral	SPD	Surge Protection Device
SWA	Steel Wire Armoured Cable	SWF	Switched Fuse
T	PVC Insulated Twin Cable	T+E	PVC Insulated Twin and Earth Cable
TP+N	Triple Pole and Neutral	TRS	Tough Rubber Sheathed Cable
U	Unknown	V/IR	Vulcanised Indian Rubber Insulated Cable (singles)
VOCB	Voltage Operated Circuit Breaker		

Guidance for Recipients

Occupier **Fleet Air Arm Museum**
Installation Address **Main Museum, RNAS Yeovilton**
Specific Location **Not Applicable**

1. This Condition Report is based on BS7671:2018 and Guidance Note 3, Inspection and Testing. The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service as identified in the Report Summary. The Report identifies any damage, deterioration, defects and/or conditions which may give rise to danger in Section 4, "Observations and Recommendations for Action to be taken".
2. The person ordering the Report will receive the "original" Report and SSE Contracting will retain a duplicate.
3. The Original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
4. Where the installation incorporates a Residual Current Device (RCD) there should be a notice at or near the origin stating the frequency at which it should be tested. For safety reasons it is important that this instruction is followed.
5. The "Extent and Limitations" in Section 1 identify the extent of the installation covered by this Report and any Limitations on the inspection and testing. The "Extent and Limitations" have been agreed with the person ordering the Report and/or with the interested parties such as licencing authority, insurance company, mortgage provider and the like before the inspection was carried out and identified within the Quotation and/or Specification provided to cover the work.
6. Some operational limitations such as inability to gain access to parts of the installation, or an item of equipment, may have been encountered during the inspection. The inspector will have noted these in Section 4.
7. For items classified in Section 4 as C1 "Danger present", the safety of those using the installation is at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in Section 4 as C2 "Potentially dangerous", the safety of those using the installation may be at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section 4 that an observation requires "Further Investigation" the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary without delay, to determine the nature and extent of the apparent deficiency.
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in the "Report Summary" and on a label at or near to the electrical intake position.

Note: Where inadequacies in the distributor's equipment are identified in Section 4, it is your responsibility to inform the appropriate supply authority to rectify the defects.