



Written Clarification Questions and Answers
CPD/004/119/231; MHCLG; Fire safety testing of HPL cladding

Ref	Clarification Question	Response
1	What is the actual type of HPL that needs to be tested, do you have more of a description so that we quote for and source exactly the right material for the test?	We're looking for the supplier to produce a representative test of a commonly used HPL cladding system (with non-combustible insulation). We have not specified the manufacturers of the materials to be tested.
2	Is it a Part 1 or a Part 2 8414 Test that is required?	Part 1 (one).