

**THE HORNIMAN MUSEUM AND GARDENS**  
**CONDITION SURVEY & 10-YEAR MAINTENANCE PLAN**  
**BUILDINGS AND EXTERNAL AREAS**

**TENDER QUERIES**

<b><u>REF</u></b>	<b><u>DATE</u></b>	<b><u>QUESTION</u></b>	<b><u>ANSWER</u></b>
1	26/06/2017	Re Drainage surveys for this, what is the client expecting here?	Please refer to item 2.4 - The survey is to be limited to the visual elements only (i.e. connections to above ground drainage, rainwater gullies, manhole covers etc.) and a CCTV survey of the below ground systems is not required.