


Site/Floor Plan

(17) //



- ACM Locations
- Sample Reference
- No Access
- Room Reference

Client: KATE ZEEBACH

Job no: A-03890

Date: 27-4-16

Building: TUE OLD
MURKIN FARM
TRACESTRUB

Floor: 2nd

Surveyor: M. ROBERT
MURKIN

Total No. of
samples taken
NST (circle)

Lab Used: SSL REC A&P
(Circle)

Plan no: 1 of 1



2107

A&P

Falmouth Docks & Engineering Company
 The Docks
 Falmouth, Cornwall
 TR11 4NR
 United Kingdom
 Tel: +44 (0)1326 212100
 Fax: +44 (0)1326 319433
 Email: mike.pereira@ap-group.co.uk

Shield Environmental Service Ltd
 Shield House
 Caxton Business Park
 Crown Way
 Warmley
 Bristol BS30 8XJ

LABORATORY REPORT

Report No.: 16/11612

Page 1 of 2

30 June 2016

SAMPLES

Location	The Old Mushroom Farm, Halestown	N° of samples	17
Collected by	P Perkins	Date	30/06/2016
Sampled by	M Roberts	Date	30/06/2016
Tested by	P Perkins	Date	30/06/2016
Your Order N°	10312		

Analysis of the samples was carried out in accordance with standard laboratory procedure FDE/T02 and HSG 248.

RESULTS

Lab Ref.	Client Identification	Description	Asbestos content
45529	A-03590/MR/001- external	profiled sheet	nad
45530	A-03590/MR/002- external	ridge sheets	nad
45531	A-03590/MR/003- external	ridge sheets	nad
45532	A-03590/MR/004- external	gutter	nad
45533	A-03590/MR/005- external	profiled sheet	chrysotile
45534	A-03590/MR/006- external	edging	chrysotile
45535	A-03590/MR/007- external	ridge sheets	nad
45536	A-03590/MR/008- external	profiled sheet	chrysotile
45537	A-03590/MR/009- external	edging	chrysotile
45538	A-03590/MR/010- external	ridge sheets	nad
45539	A-03590/MR/011- external	profiled sheet	nad
45540	A-03590/MR/012- external	edging	nad
45541	A-03590/MR/013- external	profiled sheet	chrysotile
45542	A-03590/MR/014- external	ridge sheets	chrysotile
45543	A-03590/MR/015- external	profiled sheet	nad
45544	A-03590/MR/016- external	ridge sheets	nad
45545	A-03590/MR/017- external	profiled sheet	nad

Notes:

1. nad means no asbestos detected
2. Appendix 2 of HSE document HSG264 is a table showing typical asbestos percentages in standard products.
3. Common asbestos minerals are also known by trivial names;
 - Crocidolite = blue asbestos
 - Amosite = brown asbestos
 - Chrysotile = white asbestos
4. Opinions and interpretations expressed herein including the sample description are outside the scope of our UKAS accreditation.

The Falmouth Docks & Engineering Company
 Company Registered by Statute
 VAT registration group number 780 7751 02

A member of the A&P Group