



THIS DRAWING IS INDICATIVE AND REPRESENTS ONLY THE DESIGN INTENT. THE CONTRACTOR MUST PRODUCE FULLY CO-ORDINATED WORKING / INSTALLATION DRAWINGS AS REFERRED TO IN THE CONTRACT DOCUMENTATION

NOTES

- DO NOT SCALE FROM THIS DRAWING.
- DRAWING TO BE READ IN CONJUNCTION WITH SPECIFICATION, DOCUMENTATION, DRAWINGS & ALL RELEVANT BRITISH STANDARD DOCUMENTS.
- THE ENTIRE DRAINAGE INSTALLATION SHALL COMPLY IN ALL RESPECTS WITH THE REQUIREMENTS OF THE CURRENT EDITION OF THE BUILDING REGULATIONS 2010 (AMENDED 2016), THE REQUIREMENTS OF THE LOCAL DRAINAGE INSPECTOR AND BS EN 12056:2000.
- ALL FITTINGS, PLANT & EQUIPMENT TO BE INSTALLED, REGULATED & TESTED IN ACCORDANCE WITH THE MANUFACTURERS PRINTED INSTRUCTIONS.
- ALL SOIL & WASTE PIPE CONNECTIONS TO DRAIN MUST BE MADE WITH PIPE MANUFACTURERS PATENTED REDUCERS, ADAPTERS & CONNECTORS.
- ALL PIPEWORK TO BE ADEQUATELY SUPPORTED THROUGHOUT ITS LENGTH.
- RODDING POINTS TO BE PROVIDED ON H/L PIPEWORK AT ALL CHANGES OF DIRECTION.
- INTUMESCENT FIRE SLEEVE/COLLAR TO BE INSERTED ON 500 & OVER PIPEWORK PASSING THROUGH FIRE RATED WALLS & FLOORS.
- AAVS TO BE MOUNTED ABOVE THE OVERFLOW LINE OF THE APPLIANCES SERVED & BE SUITABLY VENTILATED AND POSITIONED TO ALLOW FUTURE MAINTENANCE.
- WHERE SVP'S PENETRATE THE ROOF STRUCTURE THE SVP SHALL BE FULLY WEATHERED TO SUIT THE ROOFING MATERIAL AND TO THE ARCHITECTS REQUIREMENTS
- 110mmØ CONNECT TO WC WITH MULTIKWICK CONNECTOR
- 32mmØ WP WITH BRANCH + DEEP SEAL ANTI-SIPHON BOTTLE TRAP TO SERVE WHB & 32mmØ WP TERMINATE WITH ACCESS CAP
- 40mmØ WP WITH BRANCH + DEEP SEAL TUBULAR TRAP TO SINK, 40mmØ WP TERMINATE WITH ACCESS CAP

LEGEND

	SOIL VENT PIPE
	PIPEWORK AT LOW LEVEL
	PIPEWORK WITHIN FLOOR VOID/BELOW SLAB
	PIPEWORK AT HIGH LEVEL
	PIPEWORK WITHIN CEILING VOID
AAV	AIR ADMITTANCE VALVE
AP	ACCESS POINT
D/W	DISHWASHER
G/W	GLASSWASHER
RE	RODDING EYE
RWP	RAIN WATER PIPE
S/S	STUB STACK
SVP	SOIL VENT PIPE
VP	VENT PIPE
W/B	WATER BOILER
WHB	WASH HAND BASIN
WP	WASTE PIPE
CV	CEILING VOID
H/L	HIGH LEVEL
L/L	LOW LEVEL
DFA	DROP FROM ABOVE
DTB	DROP TO BELOW
RFB	RISE FROM BELOW
RTA	RISE TO ABOVE

P03	UPDATED TENDER ISSUE	SM	RL	RL	22.10.21
P02	TENDER ISSUE	SM	RL	RL	15.10.21
P01	STAGE 3	SM	RL	RL	01.10.21

REV	DESCRIPTION	BY	CHK	APP	DATE
-----	-------------	----	-----	-----	------

Project Status:					
TENDER					

The Multi-disciplinary Engineering Consultancy
Ground Floor, 45 Great Guildford Street
London, SE1 0ES
T 44 (0) 203 755 5950
E london@harleyhaddow.com
Edinburgh | London | Glasgow
harleyhaddow.com
Association for Consultancy and Engineering Member Firm

Project: 307685			
HORNIMAN MUSEUM STAFF RECEPTION & REST AREA REFURBISHMENT			
Drawing Title: DRAINAGE LAYOUT			
Scale @ A1 1:25	Date OCT 2021	Engineer RL	Revision P03