



L.V. MAINS RECORD
 Grid Ref: SU74418443
 Scale: 1:1250
 Date: 17/08/2018
 MSS331361

**Scottish & Southern
 Electricity Networks**
 If you are unsure & need to seek advice before commencing excavations please contact
 READING
 01169-126500

BASED UPON THE ORDINANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF T.M. STATIONERY OFFICE. CROWN COPYRIGHT RESERVED.
 This copy has been made by e with the authority of Southern Electricity Power Distribution plc pursuant to a licence granted by the Copyright Licensing Agency Ltd. All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage or retrieval system, without the prior written permission of the Controller of the Copyright Licensing Agency.
 Registered office: No. 1 Forebury Place, London SE1 7NU
 Registered in England No. 09242490
 UNCONTROLLED COPY
 Subject to Revision Master held at

WARNING
 There may have been subsequent alterations to the surface levels. Trial holes must be taken to determine positions and depth of cables. HIS (C) 47 Booklet from the Health and Safety Executive - Avoiding Danger from Buried Cables - should be consulted before commencing excavation work. (available from the HSE)
 WHEN WORKING IN THE VICINITY OF OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTE GS6 SHOULD BE CONSULTED. (AVAILABLE FROM THE HSE)

NORMAL DEPTH TO THE TOP OF THE CABLE WHEN LAID	services		
	l.v.	h.v.	e.h.v.
FOOTPATH/UNMADE	0.45m	0.60m	0.80m
ROAD CROSSING	0.60m	0.60m	0.90m
AGRICULTURAL	1.00m	1.00m	1.10m
l.v./services	- up to 1000V.		
h.v.	- over 1000V. to 11,000V.		
e.h.v.	- 22,000V. to 132,000V.		