

ITT SCHEDULE 3-Costings

Rossendale Borough Council

Tender for Christmas Lighting Annual Installations and Switch On (s)

Works to be included within tender price additional to schedule -:

- Replacement of any faulty lamps.
- Repairs to all equipment and cabling note: any equipment that is deemed not cost effective to be repaired must be reported to client for consideration to renew .
 - Annually - allow for 12 x 2 meter new lighting columns displays must be purchased to replace old stock.
 - Annually- allow for the replacement of lighting on one illumined large tree. Approximately 1800 mini LED
 - Annually allow for the replacement of lighting for one illuminated medium tree approximately 1200 mini LED
 - Annually –allow for 2 x cut Christmas trees, approximately 2 meters high with coloured lighting to be fitted into Futures Park in the One Stop Shop Reception and The Business Centre Reception by the 1st week in December .

- Within the contract period include for one refurbishment of each cross the street sign.
- Within the contract period - one electrical test and inspection must be carried out on of each feeder pillar (numbers indicated on schedule) to comply with 17th edition IEE wiring regulations with certification supplied
- Within the contract period – one pull test must be carried out on each wall bracket (numbers indicated on schedule) for the cross the street lighting and signs to comply with BS 5289 / BS5649 with certification issued

Equipment / Plant

- The contractor must allow for all necessary vehicles ,highway platform access (minimum 12.5 meter) vehicles, plant , equipment ,tools and sundries