

## Additional Information Supplied in Response to Procurement Questions – Old Priory Boiler Replacement

### **Gas Metre**

- Gas metres on site will be upgraded to support additional boiler provision, as required.

### **Zoning Requirements**

- The new system will require 3 zones – Zone 1: top floor (self-contained accommodation units), Zone 2: first floor (office units), Zone 3: ground floor (meeting rooms and community use).

### **Pump Requirements**

- Twin head pumps will be required for each zone.

### **Lagging Requirements**

- Commercial standard lagging is required.

### **Control Panel Requirements**

- A single control panel, where boiler zones and timing can be controlled from one unit.

### **Piping Requirements**

- Copper pipes are required inside the boiler plant room, with steel used inside the main buildings on the site.

### **Gas Isolation Valve**

- The existing drop weight gas isolation valve will need to be replaced and linked to the fire alarm system on site.