

Notes:

This drawing is not to be scaled. All dimensions to be checked on site and any discrepancies to be reported to Tyse Design and Consultancy Ltd. All material is produced on behalf of Tyse Design and Consultancy Ltd. All drawings to be read in conjunction with specification where applicable.  
© Tyse Design & Consultancy Limited


DRAWING SPECIFIC NOTES:

- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE ELECTRICAL ENGINEERING SERVICES SPECIFICATION
- EXISTING EXTERNAL SPEAKER TO BE REWIRED TO NEW PA SYSTEM EQUIPMENT POSITION.
- EXISTING CCTV CAMERA TO BE RETAINED, REWIRED TO SUIT NEW LAYOUT AND MAINTAINED AS OPERATIONAL.
- EXISTING INTRUDER ALARM DEVICE TO BE RETAINED AND REWIRED TO SUIT NEW LAYOUT.
- EXISTING INTRUDER ALARM DEVICE TO BE REPLACED WITH NEW.
- EXISTING INTRUDER ALARM DEVICE TO BE RETAINED AND MAINTAINED AS OPERATIONAL.
- ALLOW FOR EXTENDING THE EXISTING 6A CIRCUIT CABLING FEEDING THE EXISTING COLUMN MOUNTED EXTERNAL LIGHTING (CIRCUIT REFERENCE DB1/8) TO NEW DISTRIBUTION BOARD DB1 USING 1.5mm<sup>2</sup> 3c XLPE/SWLSZH CABLE - REFER TO DISTRIBUTION BOARD SCHEDULES.
- THE EXISTING FIRE ALARM AND DETECTION SYSTEM SHALL BE MAINTAINED AS OPERATIONAL DURING THE WORKS. FINAL PHASING PLAN TO BE CONFIRMED BY THE CONTRACTOR.
- REFER TO DRAWING E10 FOR ROOF FIRE ALARM SYSTEM DEVICES.

T01	TENDER ISSUE	LT	15/10/24
P01	PRELIMINARY ISSUE	LT	14/10/24
REV:	DESCRIPTION:	BY:	DATE:
STATUS: TENDER ISSUE			



**Tyse Design & Consultancy Limited**  
2 Osier Link,  
Amphill,  
Bedfordshire MK45 2TW  
☎ 07954 450970  
✉ lee@tyse设计.co.uk



**WARE TOWN COUNCIL**

PROJECT:  
**WARE PRIORY LIDO,  
PROPOSED EXTENSION & REFURBISHMENT  
PRIORY STREET,  
WARE SG12 0DE**

TITLE:  
**EXISTING ELECTRICAL SERVICES**

SCALE AT A1: As Noted	DATE: October 2024	DRAWN: RT	CHECKED: LT
PROJECT NO: 240804	DRAWING NO: 240804/E/01	REVISION:	T01