

Tenant Services, Wokingham BC

STP, Septic tank and pumping stations

| | | | |
|---|---|----------------------------|---|
| Type | Sewage Treatment Plant | | |
| | | | |
| Site No | 3 | Approx grid ref. | SU 800 810 |
| Address | 5 The Crescent Crazies Hill Reading RG10 8LW | No of properties connected | 1 |
| | | | |
| Consent | | Plant | P6 Titan/ ENTEC Biotec package sewage treatment plant with an Et60 air pump |
| EA Ref No | CASM.1491 | | |
| Bio Oxygen Demand (BOD) | Not specified | | |
| Suspended Solids (SS) | Not specified | | |
| Nitrogen (N) | Not specified | | |
| Other | Copper & zinc limited | | |
| Volume | 1M ³ per day | Site description | |
| Plant details | | | |
| Make | | | |
| Model | | | |
| | | | |
| | | | |
| Other comments: Situated under patio with limited access. Desludging: 2Nr visits per annum with 6800 litres total pa | | | |
| | | | |