

## Appendix 5 CPPM and PPM Specification

Service / Asset Type	SFG20	Assets	In-house Tasks	Outsourced Tasks	Notes
HV Ring Main	70-08	1	-	1-3	
PF Correction	44-03	2	-	2	
Transformer	70-06	17	1-2	3-18	
Battery Charging Unit	44-14	7	-	1-3	
Distribution Board	44-07	55	-	1-12	
Low Voltage Circuit Breaker	44-07	55	-		
HV Distribution Board	44-07	1		1-12	
HV Protection Relay	70-04	28	-	1-2, 27-41	
HV Vacuum Circuit Breaker	70-04	28	-		

In addition, partial discharge testing must be carried out annually on all relevant HV assets and cable terminations