



1. DO NOT SCALE FROM THIS DRAWING. 2. ALL MEASUREMENTS ARE IN MILLIMETRES UNLESS STATED OTHERWISE. 3. THIS DRAWING IT TO BE READ IN CONJUNCTION WITH THE SPECIFICATION AND ALL RELEVANT ARCHITECTURAL, ELECTRICAL, MECHANICAL AND STRUCTURAL DRAWINGS. KEY: KEY: THIS DRAWING SHOULD BE PRINTED IN COLOUR 30 MINUTE FIRE RESISTING WALL 60 MINUTE FIRE COMPARTMENT WALL 60 MINUTE FIRE RATED DOOR 30 MINUTE FIRE RATED DOOR 60 MINUTE FIRE RESISTING WINDOW ALL STRUCTURAL COLUMNS AND BEAMS AT WITHIN THIS ZONE TO RECEIVE 60 MINS FIRE RATED INTUMESCENT PAINT (GROUND FLOOR ONLY) AS M61:110 FIRE ESCAPE SAFETY HEALTH AND ENVIRONMENTAL INFORMATION For details of site-wide and general risks, to be read in conjunction with these notes, see Design Risk Register ref: In addition to the risks normally associated with the types of work detailed on this drawing, note the following risks and information:

Status	CONTRACT ISS			Jina	/
Rev	Revision Description	Date	Ву	Chkd	Auth
C2 C1	FIRE RATED PARTITION BETWEEN MEZZANINE AND MAIN HALL OMITTED AS CLIENT REQUIREMENTS CONTRACT ISSUE	17.09.14 17.09.14	GHA RH	HL GP	GN HL
СЗ	MEZZANINE WALL RE-INSTATED	24.07.15	GР	GHA	HL
It is	assumed that all works will be carried out I working, where appropriate, to an approve				

Revision Description		Date	Ву	Chkd
CONTRACT	ISS	UE		
KINS		Atkins I Chilbrod Eynshar Oxon OX29 4/ England	ok, Oasis n AH	Busines

Telephone: +44 (0)1865 882828 Fax: +44 (0)1865 883 060 www.atkinsglobal.com Copyright © Atkins Limited (2011) CCFE

CULHAM CENTRE FOR FUSION ENERGY

MATERIALS RESEARCH FACILITY

FIRE STRATEGY DRAWING

Original Scale	Original Size	Designed GA	Drawn GA	Checked GP	Authorised HL
1 : 200	Office OXF	Date 19/12/13	Date 13.01.14	Date 13.01.14	Date 13.01.14
Project Number	Rev				
51250	C3				