

### Site Name and Site Address

The Harlington Centre  
Fleet Road, , Fleet, , GU51 4BY

### Summary of Work Performed

PREVENTATIVE MAINTENANCE VISIT  
Full service and test if all grd floor, stage, back of house and all basement areas tested - All ok.  
Key found for show mode operation. Log book updated.

### Work Order Details

<b>Contract No:</b>	1232902-Standard	<b>Work Done Description:</b>	Detection & Alarm Routine Serv
<b>Off Site Time:</b>	31/07/2018 15:36	<b>Technician:</b>	Colin Alexander
<b>Service PO #:</b>	.	<b>Sales PO #:</b>	

### Job Summary - Detection & Alarm

Equipment Type	Quantity		
Call Points	16	Quantity Tested	11
		Quantity Passed	11
		Quantity Failed	0
		MAC's are of a similar operation?	Yes
Control Panel	1	Minor fire control panel fault?	No
		Is the panel obsolete?	No
		Is the panel located in accordance with the British Standard?	Yes
		Is the panel in good condition?	Yes
		Is the panel config available?	Yes
		How many circuits have been tested?	1
		Fire control panel failure or large area of detection non functioning?	No
		Detection / manual callpoint / sounder device failure?	No
		Are there any faults indicated?	No
Heat Detector	2	Are spare glasses available?	Yes
		Are any devices isolated? (Log details in Job Summary)	No
		Quantity Tested	2
		Quantity Passed	2
Point Detection	57	Quantity Failed	0
		Quantity Tested	32
		Quantity Passed	32
Power Supply	1	Quantity Failed	0
		Visual inspection of Power Supply?	Yes
		Quiescent Load	.
		Connections Checked?	Yes
		Charger Voltage	28.3
		Charger Size OK?	Yes
		Charger OK?	Yes
		Battery Voltage with Mains Disconnected	26.6
		Battery Size OK?	Yes
		Battery Size	7.0
		Battery Failed?	No
		Battery Condition OK?	Yes
		Alarm Current	.



## Inspection Certificate

**Work Order #** 28231935

### Customer Signature

In the event of any sales at the time of servicing all sales will be supplied subject to Chubb Fire standard terms and conditions of sale. A copy of which I acknowledge has been supplied to me at the time of this service.

**Customer Name:** THE HARLINGTON CENTRE

**Title:** Kai

**Customer Signature:**

A handwritten signature in blue ink, consisting of a stylized 'K' followed by a horizontal line.

**Date:** 31/07/2018 15:36

Thank you for your business! Satisfied customers are our highest priority. If you have any questions or comments please call us on 0344 879 1666.

**Chubb Fire & Security Limited Registered Office:**

Littleton Road, Ashford, Middlesex TW15 1TZ. Registered in England and Wales under company number 524469

**Email:** info@chubb.co.uk

**Website:** www.chubb.co.uk