

WOKINGHAM BOROUGH COUNCIL

Invitation to Tender for Sewage Treatment Plant, Septic Tanks, Cess Pits and Stand Alone Pumping Stations Maintenance Services

CLARIFICATION NOTE 8

The following requests for clarification have been received, alongside each of these is the clarification:

Clarification request	Details of clarification
As per Clarification note 7 there should be a new BoQ for Site 3 (it is not present) Required: tbc <ul style="list-style-type: none">BoQ site 3	Please find attached the updated BoQ for Site 3 ('CN8 BoQ Site3 5 The Crescent UPDATED.doc').
We have only rcvd BoQ for Site 8 (should there also be an updated datasheet for site 8?) – Appreciate what you can advise. Required: tbc <ul style="list-style-type: none">Datasheet(s) site 8	Please find attached a further updated BoQ for Site 8 ('CN8 BoQ Site 8 2 Forest Road UPDATED 2.0.doc'), along with an updated datasheet ('CN8 Site 8 2 Forest Road datasheet UPDATED 2.0.pdf'). Please take note that the frequency of emptying at this site has reduced from four times pa to 2 times pa and the annual total volume has therefore reduced.
To follow up on clarification note 7. 5 The Crescent, does it still only require only service visit per annum?	There is no concept of a 'Service visit' in the specification; the plant is to be maintained in the manner and frequency in the bill of quantities (the BoQ documents). The sites are to be visited as required to undertake the works scheduled in the bills of quantities.
Also, bench testing, is this to be carried out at six monthly and quarterly visits?	Bench testing, or the alternative of drop testing in the first instance, is to be undertaken as detailed in the Bills of Quantities (as described for bench testing) at frequencies as contained within the original documentation and as amended in the revised documents issued in previous Clarifications.

Associated files:

CN8 BoQ Site 3 5 The Crescent UPDATED.doc

CN8 BoQ Site 8 2 Forest Road UPDATED 2.0.doc

CN8 Site 8 2 Forest Road datasheet UPDATED 2.0.doc

3/4/2018 Clarification Note Ends. Issued to all parties having expressed an interest and also placed on the Contract Finder web page for the tender.