

Item	Relevant Clause	Subject	Description
1	Clarification	Submission of tender documents	Tender submission (priced Section 4 'Schedule of Works', signed Form of Tender and completed tender quality questions) should be returned in hard copy (1 no.) to Michelle Reynolds of Baily Garner LLP at 146-148 Eltham Hill, Eltham, London SE9 5DY, by 2pm on Thursday, 4 October 2018.
2	Clarification	Tender return date	Tender return date has been revised to Thursday 11th October 2018, by 12pm.
3	Clarification	Pre-Construction Information	Pre-Construction Information issued via Contracts Finder.
4	Clarification	Clarification on new and existing doors, and requirements to each doors	Tenderers are to review the Door Schedule in conjunction with Door Location Plans to identify installations required. For clarity, the works are to replace the existing door access control system, undertake making good works and all existing doors are to be retained.
5	Clarification	Fire stopping of all openings	Tenderers are to allow for provisions of fire stopping to all penetrations made and made redundant associated with the tendered works.
6	Clarification	Manufacturer and product choice for new system	No specific manufacturer and system have been selected by the employer. Tenderers are to make recommendation on the best suitable system and provide reasoning, relevant information such as system data, guarantee and warranty information, etc. Tender submission to be based on their recommended system.
7	Clarification	Provision of information	Any tender clarifications and additional information to be listed on this tender clarification schedule and uploaded on Contracts Finder for review by tenderers.