



FIRE ALARM SYSTEM SCHEDULE OF SYMBOLS			
SYMBOL	DESCRIPTION	MANUFACTURER / REFERENCE	NOTES
	FIRE DETECTION SYSTEM ANALOGUE ADDRESSABLE CONTROL AND INDICATING EQUIPMENT - TWO LOOP	ADVANCED MxPio 5'	SURFACE MOUNTED
	INTERFACE UNIT c/w INTERFACE ENCLOSURE	APOLLO FIRE 'INTELLIGENT SERIES'	X DENOTES EQUIPMENT SERVED
	SMOKE DETECTOR	APOLLO FIRE 'XP95'	CEILING MOUNTED
	SMOKE DETECTOR c/w SOUNDER BASE	APOLLO FIRE 'XP95'	CEILING MOUNTED
	COMBINED SMOKE / HEAT DETECTOR c/w SOUNDER BASE	APOLLO FIRE 'XP95'	CEILING MOUNTED
	IP66 RATED ELECTRONIC SOUNDER	APOLLO FIRE 'XP95'	WALL MOUNTED AT 2.2m
	COMBINED ELECTRONIC SOUNDER / VISUAL ALERT DEVICE	APOLLO FIRE 'XP95'	WALL MOUNTED AT 2.2m
	IP66 RATED COMBINED ELECTRONIC SOUNDER / VISUAL ALERT DEVICE	APOLLO FIRE 'XP95'	WALL MOUNTED AT 2.2m
	IP66 RATED COMBINED OPEN AREA ELECTRONIC SOUNDER / VISUAL ALERT DEVICE	APOLLO FIRE 'XP95'	CEILING MOUNTED
	MANUALLY OPERATED CALL POINT c/w HINGED PROTECTIVE COVER	APOLLO FIRE 'XP95'	WALL MOUNTED AT 1.4m
	IP67 RATED MANUALLY OPERATED CALL POINT c/w HINGED PROTECTIVE COVER	APOLLO FIRE 'XP95'	WALL MOUNTED AT 1.4m
	COMBINED SMOKE / HEAT DETECTOR	APOLLO FIRE 'XP95'	CEILING MOUNTED
	COMBINED SMOKE / HEAT DETECTOR c/w SOUNDER / VISUAL ALERT BASE	APOLLO FIRE 'XP95'	CEILING MOUNTED
	SMOKE DETECTOR c/w COMBINED SOUNDER / VISUAL ALERT BASE	APOLLO FIRE 'XP95'	CEILING MOUNTED

Notes:

This drawing is not to be scaled. All dimensions to be checked on site and any discrepancies to be reported to Tyse Design and Consultancy Ltd. All material is produced on behalf of Tyse Design and Consultancy Ltd. All drawings to be read in conjunction with specification where applicable.

© Tyse Design & Consultancy Limited

DRAWING SPECIFIC NOTES:

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE ELECTRICAL ENGINEERING SERVICES SPECIFICATION

2. REFER TO DRAWING E10 FOR ROOF FIRE ALARM SYSTEM DEVICES.

FINAL POSITIONS OF ALL ELECTRICAL ACCESSORIES TO BE CONFIRMED

T01	TENDER ISSUE	LT	15/10/24
P01	PRELIMINARY ISSUE	LT	14/10/24
REV:	DESCRIPTION:	BY:	DATE:

STATUS: TENDER ISSUE

Tyse Design & Consultancy Limited

2 Osier Link, Amphill, Bedfordshire MK45 2TW

07954 450970

lee@tyse设计.co.uk

PROJECT: WARE PRIORY LIDO, PROPOSED EXTENSION & REFURBISHMENT, PRIORY STREET, WARE SG12 0DE

TITLE: ELECTRICAL SERVICES PROPOSED FIRE ALARM SYSTEM LAYOUT

SCALE AT A1: 1:100	DATE: October 2024	DRAWN: RT	CHECKED: LT
PROJECT NO: 240804	DRAWING NO: 240804/E/07	REVISION: T01	