

ELECTRICAL INSTALLATION CONDITION REPORT

120872 - Duplicate



A. Details of the Client/Person Ordering the Report		B. Reason for Producing this Report	
Client:	ROYAL CORNWALL MUSEUM	Purpose of this report:	HEALTH AND SAFETY/INSURANCE
Address:	ROYAL CORNWALL MUSEUM 25 RIVER STREETRURO CORNWALL TRURO TR1 2SJHE	Date(s) on which Inspection: and testing was carried out	09/12/2016
C. Details of the Installation which is the Subject of this Report			
Installation:	ROYAL CORNWALL MUSEUM	Description of premises:	Domestic: N/A Commercial: <input checked="" type="checkbox"/> Industrial: N/A
Occupier:	Occupier	Other:	N/A
Address:	ROYAL CORNWALL MUSEUM 25 RIVER STREETRURO CORNWALL TRURO TR1 2SJHE	Estimated age of wiring system:	35 yrs
Record of Installation available:	N/A	Evidence of alterations or additions:	<input checked="" type="checkbox"/> If yes estimated Age: 0.1 yrs
Records held By:	N/A	Date of previous inspection:	Not Known
D. Extent and Limitations Inspection and Testing			
Extent of Electrical Installation covered by this report: VISUAL INSPECTION OF WHOLE SYSTEM FOLLOWING --See Additional Page--		Agreed limitations including the reasons (See regulation 634.2) FULL INSPECTION AND TEST TO BE CARRIED OUT IN --See Additional Page--	
Operational Limitations including the reasons (See page No N/A)		Agreed with name N/A	
None			
This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS7671:2008 (IET Wiring Regulations) as amended to July 2015 It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.			
E. Summary of the Condition of the Installation		General condition of the installations (In terms of electrical safety)	
SAFE AND SATISFACTORY			
Overall assessment of the installation	Satisfactory	*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.	
F. Recommendations			
Where the overall assessment of the suitability of the installation for continued use above is stated as SATISFACTORY, I recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (code FI). Observation classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken I recommend that the installation is further inspected and tested by 09/06/2017			
G. Declaration			
I, , being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by My signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.			
Trading Title and address	Technical Electrical Engineering Ltd, Wheal Kitty Studios, Wheal Kitty, St. Agnes, Cornwall, TR5 0RD	NICEIC Enrolment Number	019875
		Branch No. (If Applicable)	000
Inspected and tested by:			
Name	ALAN DENHAM	Position	ELECTRICIAN
Signature		Date	
Report authorised for issue by:			
Name	ALAN DENHAM	Position	ELECTRICIAN
Signature		Date	
H. Schedule(s) The attached schedule(s) are part of this document and this report is valid only when they are attached to it.			
1	Schedule(s) of inspection and	1	Schedule(s) of test results are attached

I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements	Number and Type of Live Conductors				Nature of Supply Parameters		Supply protective device	
TN-S <input type="text" value="N/A"/>	a.c. <input checked="" type="checkbox"/>		d.c. <input type="text" value="N/A"/>		Nominal Voltage $U^{(1)}$ <input type="text" value="400"/> V		BS(EN)	
TN-C-S <input checked="" type="checkbox"/>	1-Phase (2 wire) <input type="text" value="N/A"/>	1-Phase (3 wire) <input type="text" value="N/A"/>	2 Wire <input type="text" value="N/A"/>		Nominal Voltage $U_0^{(1)}$ <input type="text" value="230"/> V		88-3 Fuse	
TN-C <input type="text" value="N/A"/>	2-Phase (3 wire) <input type="text" value="N/A"/>		3 Wire <input type="text" value="N/A"/>		Nominal frequency $f^{(1)}$ <input type="text" value="50"/> Hz		Type	
TT <input type="text" value="N/A"/>	3-Phase (3 wire) <input type="text" value="N/A"/>	3-Phase (4 wire) <input checked="" type="checkbox"/>	Other <input type="text" value="N/A"/>		Prospective fault current $I_{pf}^{(2)}$ <input type="text" value="4.84"/> kA		N/A	
IT <input type="text" value="N/A"/>	Other <input type="text" value="N/A"/>				External loop impedance $Z_e^{(2)}$ <input type="text" value="0.1"/> Ω		Nominal current rating <input type="text" value="100"/> A	
Confirmation of supply polarity <input checked="" type="checkbox"/>					Number of supplies <input type="text" value="1"/>		Short circuit capacity <input type="text" value="80"/> kA	
				(Note: (1) by enquiry, (2) by enquiry or by measurement)				

J. Particulars of Installation Referred to in the Report

Means of earthing	Details of installation Earth Electrode (where applicable)	
Distributor's facility <input checked="" type="checkbox"/>	Type (e.g. rod(s), tape etc.) <input type="text" value="N/A"/>	Location <input type="text" value="N/A"/>
Installation earth electrode <input type="text" value="N/A"/>	Resistance to Earth <input type="text" value="N/A"/> Ω	Method of measurement <input type="text" value="N/A"/>

Main Protective Conductors

Tick boxes and enter details as applicable

Earthing Conductor	Material <input type="text" value="Copper"/>	csa <input type="text" value="35"/> mm ²	Connection and Continuity Verified <input checked="" type="checkbox"/>
Main protective bonding conductors	Material <input type="text" value="Copper"/>	csa <input type="text" value="16"/> mm ²	Connection and Continuity Verified <input checked="" type="checkbox"/>

Bonding of Incoming Service

Water installation pipes <input checked="" type="checkbox"/>	Gas installation pipes <input checked="" type="checkbox"/>	Structural Steel <input checked="" type="checkbox"/>	Lightning protection <input type="text" value="N/A"/>	Maximum Demand (Load) <input type="text" value="100"/> Amps
Oil installation pipes <input type="text" value="N/A"/>	Please State			Protective measure(s) against electric shock
Other incoming service(s) <input type="text" value="N/A"/>	<input type="text" value="N/A"/>			ADS <input type="text" value="ADS"/>

Main Switch / Switch-Fuse / Circuit-Breaker / RCD

Location <input type="text" value="N/A"/>	Current rating <input type="text" value="N/A"/> A	if RCD main switch Rated residual operation current, $I_{\Delta n}$ <input type="text" value="N/A"/> mA Rated time delay <input type="text" value="N/A"/> ms RCD Operating time at, $I_{\Delta n}$ <input type="text" value="N/A"/> ms
Type BS(EN) <input type="text" value="N/A"/>	Fuse/Device rating or setting <input type="text" value="N/A"/> A	
No of poles <input type="text" value="N/A"/>	Voltage rating <input type="text" value="N/A"/> V	
Supply Conductors material <input type="text" value="N/A"/>	Supply Conductors csa <input type="text" value="N/A"/> mm ²	

K. Observations

Referring to the attached schedule(s) of Inspection and Test Results, and subject to the limitations specified at the Extent and Limitations of the Inspection and testing section.

No remedial action is required. The following observations are made ☒

Item No	Observations	Code
1	VARIOUS C3 DEVIATIONS AS DETAILED ON SEPARATE REPORT HAVE NOT BEEN CARRIED OUT TO DATE	C3
2	FULL INSPECTION AND TEST BOOKED TO BE CARRIED OUT IN JANUARY 2017	N/A
3	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.1 Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)	C3
	--Observations continue on continuation sheet(s)--	

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1 - Danger present. Risk of injury. Immediate remedial action required	<input type="text" value="0"/>
C2 - Potentially dangerous - urgent remedial action required	<input type="text" value="0"/>
C3 - Improvement recommended	<input type="text" value="18"/>
FI - Further investigation required without delay	<input type="text" value="0"/>

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

120872 - Duplicate

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome		Comments	
1.0	DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT													
1.1	Condition of service cable										✓		No	
1.2	Condition of Service head										✓		No	
1.3	Condition of distributor's earthing arrangement										✓		No	
1.4	Condition of meter tails - Distributor/Consumer										✓		No	
1.5	Condition of metering equipment										✓		No	
1.6	Condition of Isolator (where present)										✓		No	
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES										N/A		No	
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)													
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)										✓		No	
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)										✓		No	
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13.1)										✓		No	
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)										✓		No	
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)										✓		No	
3.6	Confirmation of main protective bonding conductor sizes (544.1)										✓		No	
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)										✓		No	
3.8	Accessibility and condition of other protective bonding connections (543.3.2)										✓		No	
4.0	CONSUMER UNIT (S) / DISTRIBUTION BOARD(S)													
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)										C3 (see section K)		No	
4.2	Security of fixing (134.1.1)										✓		No	
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)										✓		No	
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)										✓		No	
4.5	Enclosure not damaged/deteriorated so as to impair safety (Regulation 621.2 (iii))										✓		No	
4.6	Presence of linked main switch (as required by 537.1.4)										✓		No	
4.7	Operation of main switch (functional check) (612.13.2)										✓		No	
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (612.13.2)										✓		No	
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)										C3 (see section K)		No	
4.10	Presence of RCD quarterly test notice at or near consumer unit / distribution board (514.12.2)										C3 (see section K)		No	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit / distribution board (514.14)										C3 (see section K)		No	
4.12	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)										N/A		No	
4.13	Presence of other required labelling (please specify)(Section 514)										C3 (see section K)		No	
4.14	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)(421.1.3)										C3 (see section K)		No	
4.15	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.2)										✓		No	
4.16	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.11)										✓		No	
4.17	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5.1))										✓		No	
4.18	RCD(s) provided for fault protection – includes RCBOs(411.4.9; 411.5.2; 531.2)										✓		No	
4.19	RCD(s) provided for additional protection - includes RCBOs (411.3.3; 415.1)										✓		No	
4.20	Confirmation of indication that SPD is functional (534.2.8)										N/A		No	
4.21	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure (526.1)										✓		No	
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)										N/A		No	
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)										N/A		No	
5.0	FINAL CIRCUITS													
5.1	Identification of conductors (514.3.1)										C3 (see section K)		No	
5.2	Cables correctly supported throughout their run (522.8.5)										N/V		No	
5.3	Condition of insulation of live parts (416.1)										✓		No	

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY CONTINUED

120872 - Duplicate

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome			Comments
5.0	FINAL CIRCUITS (Continued)													
5.4.0	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)										✓			No
5.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)										✓			No
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)										C3 (see section K)			No
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)										C3 (see section K)			No
5.7	Adequacy of protective devices; type and rated current for fault protection (411.3)										C3 (see section K)			No
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)										✓			No
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)										✓			No
5.10	Concealed cables installed in prescribed zones (see section D. Extent and limitations) (522.6.202)										N/V			No
5.11	Cables concealed under floors, above ceilings or in walls / partitions, adequately protected against damage (see Section D. Extent and limitations) (522.6.204)										N/V			No
5.12.0	Provision of additional protection by RCD not exceeding 30mA													
5.12.1	For all socket-outlets of rating 20 A or less, unless an exception is permitted (411.3.3)										C3 (see section K)			No
5.12.2	For supply to mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)										✓			No
5.12.3	For cables concealed in walls at a depth of less than 50mm (522.6.202; 522.6.203)										C3 (see section K)			No
5.12.4	For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)										C3 (see section K)			No
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)										C3 (see section K)			No
5.14	Band II Cables segregated / separated from Band I cables (528.1)										N/V			No
5.15	Cables segregated / separated from communications cabling (528.2)										N/V			No
5.16	Cables segregated / separated from non-electrical services (528.3)										N/V			No
5.17.0	Termination of cables at enclosures – indicate extent of sampling in Section D of the report (Section 526)													
5.17.1	Connections soundly made and under no undue strain (526.6)										C3 (see section K)			No
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)										✓			No
5.17.3	Connections of live conductors adequately enclosed (526.5)										✓			No
5.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc...) (522.8.5)										✓			No
5.18	Condition of accessories including socket-outlets, switches and joint boxes (621.2 (iii))										C3 (see section K)			No
5.19	Suitability of accessories for external influences (512.2)										✓			No
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)										C3 (see section K)			No
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.2)										✓			No
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER													
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30mA (701.411.3.3)										N/A			No
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)										N/A			No
6.3	Shaver sockets comply with BS EN 61558-2-5 formally BS 3535 (701.512.3)										N/A			No
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671: 2008 (701.415.2)										N/A			No
6.5	Low Voltage (e.g.230 volts) socket outlets at least 3m from Zone 1 (701.512.3)										N/A			No
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)										N/A			No
6.7	Suitability of accessories and control gear etc. for a particular zone (701.512.3)										N/A			No
6.8	Suitability of current-using equipment for particular position within the location (701.55)										N/A			No
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS													
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied).									Number of locations	0			No

Inspected By

Name: ALAN DENHAM

Date: N/A

Signature:

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION	
Location of Distribution Board	VISUAL INSPECTION CARRIED OUT ONLY	Supply to distribution board is from	N/A
Distribution board designation	ALL CIRCUITS	No of phases	N/A
		Nominal Voltage	N/A V
		Overcurrent protective device for the distribution circuit	
		Type BS(EN)	N/A
		Rating	N/A A
		Associated RCD (if any)	
		BS(EN)	N/A
		RCD No of Poles	N/A
		RCD Rating	N/A mA

Circuit Details

[illegible]

Wiring Code

A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED
DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Earth fault loop impedance	AD-6111-754-080508/6	RCD	AD-6111-754-080508
Insulation resistance	AD-6111-754-080508/6	Other	N/A
Continuity	AD-6111-754-080508/6	Other	N/A

Zs	N/A	Ω	Operating times of associated RCD (if any)	At I Δ_n	N/A	ms
Ip	N/A	kA		At 5I Δ_n	N/A	ms
Correct supply polarity confirmed	N/A		Phase sequence confirmed (where appropriate)		N/A	

N/A

[illegible]

Signature _____

Name **ALAN DENHAM**

Position	ELECTRICIAN
Date of testing	09/12/2016

Extent of Electrical Installation covered by this report, Continued. from page 1

RECENT C2 WORKS BEING CARRIED OUT

Agreed limitations including the reasons, Continued. from page 1

JANUARY 2017.

Observations Continued from Page 2

Item No	Description	Code
4	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.9 Correct identification of circuit details and protective devices (514.8.1;514.9.1)	C3
5	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.10 Presence of RCD quarterly test notice at or near consumer unit / distribution board (514.12.2)	C3
6	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.11 Presence of non-standard (mixed) cable colour warning notice at or near consumer unit / distribution board (514.14)	C3
7	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.13 Presence of other required labelling (please specify)(Section 514)	C3
8	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.14 Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)(421.1.3)	C3
9	5 FINAL CIRCUITS 5.1 Identification of conductors (514.3.1)	C3
10	5 FINAL CIRCUITS 5.5 Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	C3
11	5 FINAL CIRCUITS 5.6 Coordination between conductors and overload protective devices (433.1; 533.2.1)	C3
12	5 FINAL CIRCUITS 5.7 Adequacy of protective devices; type and rated current for fault protection (411.3)	C3
13	5 FINAL CIRCUITS 5.12.1 For all socket-outlets of rating 20 A or less, unless an exception is permitted (411.3.3)	C3
14	5 FINAL CIRCUITS 5.12.3 For cables concealed in walls at a depth of less than 50mm (522.6.202; 522.6.203)	C3
15	5 FINAL CIRCUITS 5.12.4 For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)	C3
16	5 FINAL CIRCUITS 5.13 Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	C3
17	5 FINAL CIRCUITS 5.18 Condition of accessories including socket-outlets, switches and joint boxes (621.2 (iii))	C3
18	5 FINAL CIRCUITS 5.20 Adequacy of working space / accessibility to equipment (132.12; 513.1)	C3
19	5 FINAL CIRCUITS 5.17.1 Connections soundly made and under no undue strain (526.6)	C3

Code Key

C1 - Danger present. Risk of injury. Immediate remedial action required

C2 - Potentially dangerous - urgent remedial action required

C3 - Improvement recommended

FI - Further investigation required without delay

CONDITION REPORT GUIDANCE NOTES FOR RECIPIENTS

This report is an important and valuable document which should be retained for future reference.

1. The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. The person ordering the Report should have received the "original" Report and the inspector should have retained a duplicate.
3. The "original" Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner /occupier with details of the condition of the electrical installation at the time the Report was issued.
4. Where the installation incorporates residual current devices (RCD) there should be a notice at or near the device stating that it should be tested quarterly. **For safety reasons it is important that this instruction is followed.**
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as C1 ("Danger Present"), **the safety of those using the installation is at risk**, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in Section K as C2 ("Potentially Dangerous"), the safety of those using the installation may be at risk and it is recommended that a competent person undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation (code F1) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit / distribution board.