



Notes:

1. 12mm to fines (buff colour wearing course) crushed sandstone path surfacing, dampened and rolled at least twice with deadweight roller max 1.5 tonnes - 50mm finished depth
2. Terram 1000 Geotextile.
3. 150x38mm Timber edging boards and 50x50x450mm pegs, driven into the ground at max. 1200mm centres. Top of pegs to finish short of tops of boards and buried under finished levels to give neat edge finish. Edging boards to be butt jointed and fixed with fishplate / joining board. Timber to be treated softwood with minimum 25yr life span. Pegs to be fixed to boards with min 2No 65mm 10g galvanised nails.
4. Sub-base - Compacted MOT Type 1 granular hardcore - 150mm depth.
5. Existing ground level.
6. Reinstatement and consolidate suitable clean topsoil to path edges and grass seed following completion. Ensure no trip is formed at edges.

Path to be Breedon Golden Amber gravel or similar laid to manufacturers instructions to the approved camber and construction to use the recommended weight and use of water during consolidation and to achieve a firm consolidated surface with semi-bound fines material at the surface.

© Crown copyright and database rights 2011 Ordnance Survey

Notes:

- 1) Figured dimensions to be taken. Do not scale dimensions. Contractors must verify all dimensions on site before preparing shop drawings or commencing any work.
- 2) Copyright ©. This drawing must not be reproduced without the permission of North East and West Yorkshire Groundwork Trust

Rev	Revision Notes:	Dwn	Ckd	Date

GROUNDWORK NEWBY

Groundwork Landscape Architecture GWRK Design
 Environment and Business Centre,
 Morley, Leeds, LS27 8SL
 Telephone: 0113 238 0601
 Fax: 0113 232 8607
 Web: www.groundwork.org.uk/lia/newby



Project	Centre Vale Wheelspark	Title	Compacted Sandstone Path
Client	Todmorden Town Council	Drawing No.	0002
Site code	-	Drawn	JL
		Checked	11.20
		Scale	1:1250 @ A4