



This copy has been made by or with the authority of Scottish and Southern Energy plc pursuant to section 47 of the Copyright, Design and Patents Act 1988 (the Act). Unless the Act provides a relevant exception to copyright, the copy must not be copied without prior permission from the copyright owner.

BASED UPON THE ORDNANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF H.M. STATIONERY OFFICE. COPYRIGHT RESERVED. SSSI DATA (c) Scottish Natural Heritage

Scottish and Southern Energy plc. Registered in Scotland No. 117119. Registered Office: Inveralmond House 200 Dunkeld Road Perth PH1 3AQ

NORTH EAST DISTRICT

Tel: 01224 667200

All Voltages

Scale : 1:1250

19/06/2012

NJ71596424

UNCONTROLLED COPY
Subject to revision without notice.

NORMAL DEPTH TO THE TOP OF THE CABLE WHEN LAID.

	services	lv	hv	ehv
FOOTPATH	0.40m	0.45m	0.60m	0.75m
ROAD CROSSING	0.65m	0.60m	0.75m	0.90m

l.v./services - upto 1000V
h.v. - over 1000V to 11,000V
e.h.v. - 22,000V and 132,000V

WARNING

There may have been subsequent alterations to the surface levels. Trial holes must be taken to determine positions and depths of cables. HS (G) 47 Booklet from the Health and Safety Executive - Avoiding Danger from Buried Cables - should be consulted before commencing excavation work. (available from HMSO)

WHEN WORKING IN THE VICINITY OF OR OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTE G56 SHOULD BE CONSULTED. (AVAILABLE FROM HMSO)

For plots at 1:10000 scale there maybe more information visible at 1:500 scale. Responsibility is with the user of this map to check no further information exists at 1:500 scale.