

Clarification Questions Log - Tender- Fire Alarm and Associated Systems Maintenance

Q. No.	Question	Response
1	We note that required insurance levels are not stated within any of the tender documents and the SQ asks us to state our level of coverage. However, Appendix B provides scoring for Insurance requirements and full marks are given for 'Exceeds minimum levels'. Please can you clarify what Pirbright considers to be the minimum levels required?	Employers - £5m; Public £5m, Professional Identify £1m; Cyber £500K
2	Qty of gas suppression cylinders for the 2 energy centres	4 x IG100 80 Litre 300 Bar and 8 x Water 80 Litre
3	Confirmation maintenance work can be completed in normal working hours	All maintenance service works carried out during normal hours Preferably 08:00 am to 05:00 pm
4	Type of gas/agent in the energy centres	IG100 (Nitrogen) - Fire Suppression Agent
5	Appendix C - Pricing Schedule', we noticed that the 'Costs (£)/year' tabs on the right of the table all say year 1. Should this be year 1, 2 and 3?	Yes, this should be year 1, 2 and 3. Please amend for your submission.