



Section

Notes

- 1 All dimensions are in millimetres.
- 2 For dimensions of soakaways refer to schedules on contract specific drawings.
- 3 Suitable fill shall be free from fine material (5mm down) and have a total void ratio of no less than 35%. proposals shall be submitted to the engineer for approval.
- 4 HR400 B125 covers are suitable for the following locations :
 - A) Verges
 - B) Footways / Pedestrian Areas
 - C) Car Parks
- 5 All details shall otherwise be in accordance with The Department of Transports Specification For Highway Works, 7th Edition.

C	NOTE No. 3 REVISED.	VC-13-07-04
B	NOTES 3 & 5 REVISED.	VC-16-11-95
A	ADDITIONAL NOTES ADDED TO DRAWING.	PF-16-10-95

REV	DESCRIPTION	DATE
-----	-------------	------

Archibald Shaw 

Consulting Civil & Structural Engineers
 One Little London Chichester West Sussex PO19 1PP
 Telephone: 01243 786471 Facsimile: 01243 779346
 mail@archibaldshaw.co.uk www.archibaldshaw.co.uk

PROJECT Standard Details Rubble Filled Soakaway		
DRAWN BY PEF	CHECKED BY VC	DESIGNED BY VC
SCALE N.T.S.	DATE AUG.95	REVISION
STD NO. STD.01.65		C