## Display energy certificate (DEC)



Congleton Town Hall High Street Congleton CW12 1BN	Operational rating	Certificate number:	1124-2051-7813-8301-2463
		Valid until:	29 June 2025
		Total useful floor area:	1,340.85 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO2) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	Α		
26-50	В		
51-75	С	70 C	
76-100	D		400
			100
101-125	E		
126-150	F		
150+	G		
This bui	lding's energy use		

Energy use	Electricity	Other fuels
Annual energy use (kWh/m2/year)	86.79	240.19
Typical energy use (kWh/m2/year)	128.60	329.53
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
June 2024	70 C
June 2023	69 C
June 2022	68 C

## Total carbon dioxide (CO2) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO2.

Date	Electricity	Heating	Renewables
June 2024	64	62	0
June 2023	61	64	0
June 2022	53	72	0

## Assessment details

Assessor's name	Mr Stephen Gater
Employer/Trading name	SMG Consultancy Partnership
Employer/Trading address	Heathlands Cottage, Street Lane, Rode Heath, S-o-T, ST7 3SN
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	28 May 2024
Nominated date	30 June 2024

5/29/24, 5:59 PM