

**Rooftop Housing Group**  
**RHA\_Shrews\_Gas\_Maintenance\_2024 Tender Clarification Log**

Clarification Question	Question	Response	Date Received
1	Good afternoon I have been looking at the tender for the gas maintenance contract at your Shrewsbury site and just wanted to know if it's domestic gas appliances or commercial.	All domestic appliances	13/06/2024
2	Could you confirm what a AD-Hoc service is????	A one-off, unplanned gas safety service - not included in the servicing schedule	26/06/2024
3	Will there be tightness testing as well? It does not state but is a Gas safety / Landlords' requirement.	Tightness testing is a standard part of the service so yes this is a requirement. Specification has been updated to reflect this.	26/06/2024