



- NOTES:
1. READ IN CONJUNCTION WITH ALL OTHER MAX FORDHAM DRAWINGS, SCHEDULES, AND SPECIFICATIONS
 2. REFER TO THE ARCHITECTS AND STRUCTURAL ENGINEERS INFORMATION FOR ADDITIONAL DETAILS
 3. PRINT IN COLOUR
 4. ENSURE ALL FITTINGS INSTALLED ON THE DOMESTIC WATER INSTALLATION ARE WRAS APPROVED
 5. TRACE HEAT ALL EXTERNAL PIPEWORK
 6. WHEN INSTALLING PIPEWORK ON ROOF USE NON-PENETRATIVE SUPPORTS, EG BIGFOOT OR SIMILAR
 7. PROVIDE DRAINAGE TO HUMIDIFIERS USING COPPER PIPEWORK

- TEMPERATURE AND HUMIDITY SENSOR
- HTG - HEATING PIPEWORK
- CHW - CHILLED WATER PIPEWORK
- CWS - COLD WATER SERVICE PIPEWORK
- PIPEWORK DROP/RISE
- ISOLATION VALVE
- PUMP

P02	06/11/20	D2 TENDER	STM
P01	16/10/20	D2 TENDER	SH
•	25/09/20	STAGE 4 - DRAFT ISSUE	SH
rev	date	description	eng

MAX FORDHAM

Max Fordham LLP
Carver's Warehouse
77 Dale Street
Manchester
M1 2HG
T. +44 (0) 161 312 8071
F. +44 (0) 20 7482 0329
maxfordham.com

Registered Office 42-43 Gloucester Crescent London NW1 7PE

architect
DONALD INSALL ASSOCIATES

job title
WALKER ART GALLERY

project leader date scale (at A1)
MD SEPT '20 1:50

drawing title
**PIPED SERVICES
GROUND FLOOR
LAYOUT**

job no dwg no rev
6683 6683-MXF-XX-G-DR-P-20100 / P02