4	d3associates
Mallan Ho	use Bridge End Hexham Northumberland NE46 4DQ

Shotton Outreach Youth Hub

Mallan Ho	use Bridge End Hexham Northumberland NE46 4DQ																		
Project No:	1788	Tender Queries Day Month		12 7	18	25 7													
		Year		23	7 23	23													
QUERY		BY ACTION												ISSUED TO					
Floor vinyl spec as drawing or NBS? (Typo on drawing)			Price as NBS		√														
2001 Site Plan - query items against Schedule of Works			Issue revised Site Plan 2001 P03, Schedule P03	of Works		✓													
Suspended ceiling tile types - Dune only in NBS			Confirm ceiling tiles types as stated in Sche	dule of Works		✓													
How much of arborists report to include?			Arboricultural Method Statement AMS TPP works adjacent ex car park omitted	submitted -			✓												
Is kitchen equipment included in Prov Sum 13.01			Yes - provisional sum				✓												
Confirm 10 No lighting columns as site plan or 12 No as Electrical Plan			12 No as Electrical Specification - Revised 9 2001 P04 issued	Site Plan			✓												
Is the 6m lighting column fixed or rise and fall?			Fixed				✓												
Brickwork scope			4 courses, single skin, top course specials a	s 6.06			✓												
Do we still need to CHAS accreditation	o complete Questionnaire Section E H&S if we hold on?		Yes - all questions of Section E H&S must b	e completed			✓												