



Final Certificate of Analysis

Water Drop Limited
75 Hilmanton
Lower Earley
Reading
Berkshire
RG6 4HN
Tel no. 01189 757322

Job Number : M0005329
Date Produced: 25.06.2018
Date samples submitted : 07.06.2018
Number of Samples: 1

Lab No	Sample Date	Report Date	Sample Description	Customer	Site	Legionella Species	Legionella pneumophila Sg	Legionella pneumophila Sg
						cfu/vol	2-15 cfu/vol	1 cfu/vol
ALSE-17187955	07.06.2018	25.06.2018	M0005329-POU 6 Main Kitchen	Comfort Building Services	The Harlington Centre	W5	W5	W5
						Not Detected	Not Detected	Not Detected

Comments Following our recent extensive flushing, local disinfection and re-sampling, the results are within acceptable parameters with NO Legionella bacteria detected.