



SOAKAWAY SCHEDULE

TYPE	LOWEST INCOMING INVERT LEVEL	EFFECTIVE DEPTH (H)	TOTAL DEPTH (m)	RING DIA. (m)	PIT DIMENSIONS PLAN (L x W) (m)	COVER SIZE (CLEAR OPENING) (mm)	COVER TYPE	COMMENT
SA1	t.b.c.	1,500	2,000	-	2.00 x 2.00	Ø225	B125	SEE DIMS OF SET RUBBLE FILLED SOAKAWAY
SA2	t.b.c.	1,500	2,000	-	2.00 x 2.00	Ø225	B125	SEE DIMS OF SET RUBBLE FILLED SOAKAWAY

1. A Lotrak 1800 geotextile or equivalent surround is required.
2. Soakaways shall be a minimum of 5.00m from any buildings or structures.
3. The Contractor shall immediately notify the Engineer if groundwater is encountered in soakaway pits.
4. A provisional soil infiltration rate of 1, 1 x 10<sup>-5</sup> m/sec has been used for soakaway design.

REV	DESCRIPTION	DATE
-----	-------------	------



Consulting Civil & Structural Engineers  
One Little London Chichester West Sussex PO19 1PP  
Telephone: 01243 786471 Facsimile: 01243 779346  
mail@archibaldshaw.co.uk www.archibaldshaw.co.uk

PROJECT

Mill Lane Storage Unit

SECTION

Site Plan

DRAWN BY	CHECKED BY	DESIGNED BY
----------	------------	-------------

AT

SCALE @ A3	DATE	STATUS
------------	------	--------

1:500	February 2018	Preliminary
-------	---------------	-------------

JOB NO.	DRAWING NO.	REVISION
---------	-------------	----------

28252 S1