



- LEGEND**
- ▼ Proposed finished slab level
- NOTES**
1. All dimensions are in millimetres unless otherwise stated.
  2. Existing ground levels (EGL) are approximate and pending site survey. 9.95egl assumed.
  3. Finished slab levels (FSL) are based upon approximate existing ground levels. Pending site survey.
  4. All calculations and specifications are pending site
  5. This drawing is to be read in conjunction with Canvas Spaces drawings & details.
  6. For setting out, levels etc. refer to Canvas Spaces drawings & details.
  7. Nominal cover to reinforcement to be 40 mm (including fixing tolerance, (a non-infinitesimal change) C = 15 mm) to BS 8500-1 (2006) unless specified otherwise
  8. Type 1 sub-base to be in accordance with the Specification for Highway Work. Compaction of Type 1 sub-base shall be carried out with a vibrating plate compactor having a static pressure not less than 0.2kg/cm2 & operated at the speed of vibration recommended by the manufacturer. Each layer of fill shall be compacted by making a minimum of five passes with the vibrator at a traveling speed not greater than 10m/ min.
  9. Concrete to be Grade C35/45 (formerly Grade C45) to BS 8500. Concrete finishes to be steel troweled to the requirements of Canvas Spaces.
  10. Slab reinforcement shall be mesh reinforcement to BS 4483 and BS 4449. Minimum lap to mesh sheets to be 400mm or B10 loose bars at 200 crs. min. 900mm long min. lap 400mm.

Canvas Spaces Limited  
Polygon Yard, 39a Islington Road  
Bristol BS3 1QB, UK

+44 (0)117 379 0881  
www.canvasspaces.co.uk  
info@canvasspaces.co.uk

Canvas Spaces Limited. Reg Co no. 08723592  
All content © Canvas Spaces Limited

**Site Address**  
Fernie Close  
Newborough  
Peterborough  
PE6 7RH

**Client**  
Newborough and Borough Fen Parish Council

**FERNIE CLOSE SKATEPARK**

**Drawing Title**  
Civil Detial

Scale As Shown		Size A2	
Date 08/09/23	Drn DW	Ckd -	Sgd -

**Status**  
PLANNING

**Drawing no.**  
706-S01-02

**Rev**  
-