

Schedule of buildings, plant quantities and PPM frequency

	Visits per year	12	4	2	2	4	2	1 *
	Specification reference	1.3	1.4	1.5	1.6	1.7	1.8	1.9
Building name	Description	Sentinels and calorifiers	Showers	TMV	Water Softener	Calorifier Dipside	Cold water storage tanks	Outlet Check
EIGL1	Laboratory Block	7	5			2	2	152
EIGL2	Laboratory Block	6	1				4	42
EIGL3	Laboratory Block	3	1	1				34
GIH	Offices	8		1	1			32
Hanlon House	Gym/Fitness rooms	1	4					4
JHB	Offices	4	2	6		1	1	15
KDB	Office/Reception/Conference		4+1 ¹	12	1			42
NGR	Repository	6	1			2		22
PPFPL	Laboratory Block	5				2		46
Publications store	Store	4						
SRMR	Kitchens and meeting rooms	8	1 ¹	7		1		35
TECS	Workshop	4					1	7
Front Gate Security hut				2				
WSB	Offices	4		24			2	56
	Totals	60	14	53	2	8	10	487

NOTES

* all outlets to be checked once a year with circa 8-10% of the total being checked each month

¹ - Rinse spray in kitchen