



- Notes:**
- GENERAL**
- G1. DO NOT SCALE THIS DRAWING. USE ONLY WRITTEN DIMENSIONS. ANY DISCREPANCIES TO BE REPORTED TO THE ENGINEERS. IF IN DOUBT ASK.
- G2. SETTING OUT TO ARCHITECT'S DRAWINGS.
- G3. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTS, ENGINEERS, AND SPECIALISTS DRAWINGS, AND WITH THE SPECIFICATIONS.
- G4. WORKS TO COMPLY WITH ALL RELEVANT BRITISH STANDARDS, CODES OF PRACTICES, EURO CODES AND THE BUILDING REGULATIONS.
- G5. THE CONTRACTOR SHALL BE RESPONSIBLE FOR MAINTAINING THE STRUCTURAL INTEGRITY OF THE WORKS AT ALL TIMES BY THE PROVISION OF ADEQUATE TEMPORARY WORKS.
- G6. ALL DIMENSIONS IN MILLIMETERS (mm), ALL LEVELS IN METRES (m).
- FOUNDATIONS**
- F1. FOUNDATIONS TO BE CENTRAL UNDER WALLS AND 600mm. WIDE EXCEPT WHERE NOTED OTHERWISE ON THE DRAWING. FOUNDATION WIDTH HAS BEEN BASED ON AN ALLOWABLE GROUND BEARING PRESSURE OF 100kN/m² AT A DEPTH OF 1.0m - REFER TO THE SITE INVESTIGATION REPORT AND TRIAL PITS. SUBJECT TO LOCAL AUTHORITY APPROVAL.
- F2. BLINDING AND MASS CONCRETE FILL TO BE GEN1 WITH A CONSISTENCE CLASS S3.
- F3. MASS CONCRETE FOOTINGS TO BE GEN 3 TO B.S 8500 Pt.1. ALL WITH 20mm AGGREGATE AND S3 CONSISTENCY CLASS, AND TO BE IN ACCORDANCE WITH BSEN 206 PART 1 AND BS 8500 PART 1.
- F4. CONCRETE TO SATISFY DESIGN SULPHATE CLASS DS2 AND ACEC CLASS AC-2 TO BRE SPECIAL DIGEST 1, WITH A RECOMMENDED BASIC DESIGN CHEMICAL CLASS DC 1/0.
- F5. ALL FOUNDATIONS TO HAVE A MINIMUM PROJECTION OF 75mm TO BOTH SIDES OF WALL SUPPORTED.
- F6. FOUNDATION DEPTHS AS SPECIFIED ARE MINIMUM. DEPTH TO BE INCREASED TO SUIT LOCAL BEARING STRATA AND 'SOFT SPOTS'.
- F7. ALL FOUNDATIONS TO BE AT MINIMUM 1.0m BELOW EXISTING GROUND LEVEL UNLESS NOTED OTHERWISE
- F8. REINFORCED CONCRETE FOOTINGS TO BE GRADE RC25/30
- F9. ToF LEVEL TO BE 675mm BELOW SSL UNLESS NOTED OTHERWISE

PRELIMINARY

P	1	PRELIMINARY ISSUE	MC	MC	02.10.19
STATUS	REV	DESCRIPTION	DRAWN	CHKBY	DATE
STATUS / REVISION					
P = Preliminary, T = Tender, A = Approval, C = Construction, AB = As Built					
CLIENT					
Trowbridge Town Council					
ARCHITECT					
PKA Architects					
PROJECT TITLE					
Town Park Storage Building					
DRAWING TITLE					
Proposed foundation plan					



Clegg Associates Ltd
Bryer Ash Business Park
Trowbridge
Wiltshire
BA14 8HE

Tel: 01225 541088
www.cleggassociates.co.uk

SCALE @ A1	DRAWN BY	CHECKED BY	DATE
1:50	MC	MC	02/10/19
DRAWING REFERENCE			
PROJECT NUMBER	TYPE	DRAWING NUMBER	STATUS REV.
2019-134	GA	01	P 1