

AW5.2 Price Schedule



SOURCING REFERENCE:	FM150021
SOURCING DOCUMENT TITLE:	Electrical Upgrade: Entebbe, Uganda
BIDDER NAME	[Bidder to add name]

Item Number	Description	Unit	Quantity	List Price	Discounted Price	Total Price	Notes & Comments
A	Main Low Voltage Switch Board		0	£ -	£ -	£ -	
	Free Standing Form 4B Construction with fully Withdrawable type Circuit Breakers. Fault Level: 50kA, Ingress protection: IP52. White in colour. Padlockable outgoers, Bottom Entry. Instrumentation on each incomer, On load indication, Circuit Breaker status - Hours run, Volts, Amps, Kwhr meter, etc. Automatic Load: Voltage and Frequency sensing, Phase rotation, Phase failure, Voltage Imbalance, etc. arranged to start the 1000kVA Generator and transfer the load from the selected Transformer onto Incomer three.	Set	1	£ -	£ -	£ -	
i)	Incomer 1(from 1000kVA TX1): 1600A TP ACB fully withdrawable. TX is duty unit - selected manually. Electrically and Mechanically interlocked to provide selection between the two transformers.			£ -	£ -	£ -	
ii)	Incomer 2(from 1000kVA TX2): 1600A TP ACB fully withdrawable. TX is standby unit - selected manually. Electrically and Mechanically interlocked to provide selection between the two transformers.			£ -	£ -	£ -	
iii)	Power Factor Correction Bank - 600kVar. CT and Controller on each TX P.F to read 1. CT and Controller on Generator P.F to read 0.8.			£ -	£ -	£ -	
iv)	Incomer 3 (from 1000kVA Gen.): 1600A TP ACB fully withdrawable. Arranged to Automatic Load Transfer to Generator if the utility voltage is not correct. Instrumentation on each incomer. On load indication. Circuit breaker status - Hours Run, Volts, Amps, Kwhr meter, etc.			£ -	£ -	£ -	
v)	1x1250A TP ACB - outgoing			£ -	£ -	£ -	
vi)	1 x 630A TP MCCB- outgoing			£ -	£ -	£ -	
vii)	2 x 400A TP MCCB- outgoing			£ -	£ -	£ -	
viii)	2 x 150A TP MCCB- outgoing			£ -	£ -	£ -	
ix)	3 x 63A TP MCCB- outgoing			£ -	£ -	£ -	
x)	1 x 400A TP MCCB- outgoing(SPARE)			£ -	£ -	£ -	
xi)	1 x 150A TP MCCB- outgoing(SPARE)			£ -	£ -	£ -	
xii)	2 x 63A TP MCCB- outgoing(SPARE)			£ -	£ -	£ -	
xiii)	Surge protection for 3-phases			£ -	£ -	£ -	
				£ -	£ -	£ -	
B	Main Distribution Board 1						
	Free Standing Form 4B Construction with fully Withdrawable type Circuit Breakers. Fault Level: 50kA, Ingress protection: IP52. White in colour. Padlockable outgoers, Bottom Entry. Instrumentation on each incomer, On load indication, Circuit Breaker status, Hours run, Volts, Amps, Kwhr meter, etc	Set	1	£ -	£ -	£ -	
xiv)	Incomer: 500A (Adjustable) TP MCCB			£ -	£ -	£ -	
xv)	1 X 200A, TP MCCB - outgoing			£ -	£ -	£ -	
xvi)	5 X 100A, TP MCCB - outgoing			£ -	£ -	£ -	
xvii)	2 X 63A, TP MCCB - outgoing			£ -	£ -	£ -	
xviii)	2 X 63A, TP MCCB - outgoing(SPARE)			£ -	£ -	£ -	
xix)	1 X 32A, TP MCCB - outgoing(SPARE)			£ -	£ -	£ -	
				£ -	£ -	£ -	
C	Training Building Splitter Board						
	Free Standing Form 4B Construction with fully Withdrawable type Circuit Breakers. Fault Level: 50kA, Ingress protection: IP52. White in colour. Padlockable outgoers, Bottom Entry. Instrumentation on each incomer, On load indication, Circuit Breaker status, Hours run, Volts, Amps, Kwhr meter, etc	Set	1	£ -	£ -	£ -	
xx)	Incomer: 500A (Adjustable) TP MCCB			£ -	£ -	£ -	
xxi)	1 X 300A, TP MCCB - outgoing			£ -	£ -	£ -	
xxii)	1 X 63A, TP MCCB - outgoing			£ -	£ -	£ -	
xxiii)	1 X 300A, TP MCCB - outgoing (SPARE)			£ -	£ -	£ -	
				£ -	£ -	£ -	
D	Conductive rubber mat	M	12	£ -	£ -	£ -	
				£ -	£ -	£ -	
E	Transformers						
	2No X 11kV/415V / 1MVA Power Transformers complete with, Filling : oil filled, winding: copper winding, Type of cooling: ONAN cooled, Vector group: DYN II, Mounting: Skid base	No	2	£ -	£ -	£ -	
				£ -	£ -	£ -	
F	Ring Main Unit (RMU)						
	11kV 3 way ring main unit. Make: the supplier to provide all manufacturer details, type: out door, voltage (nominal/max) KV; 11kV/12 Kv, Phase (Nos.); 3 nos	No	2	£ -	£ -	£ -	
				£ -	£ -	£ -	
G	Containerised Unit for Transformer						
	Measuring maximum approximately 1,200 (W) x 3,200 (L) x 2,000 (H).	No	2	£ -	£ -	£ -	
				£ -	£ -	£ -	
TOTAL						£ -	

All prices are firm and fixed.
All prices are exclusive of VAT

TEMPLATE VERSION CONTROL

Version	1.0
Date	13/01/2014
Author	James Aldred
Comment	Final template version