

CSCALE F

- DO NOT SCALE FROM THIS DRAWING. WORK TO MEASURED DIMENSIONS.
- 2. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED
- 3. SVM BSD HAVE NO RESPONSIBILITY FOR ANY USE MADE OF THIS DRAWING OTHER THAN FOR THAT WHICH IT WAS PREPARED AND ISSUED.
- 4. THE INFORMATION ON THIS DRAWING IS INDICATIVE ONLY OF THE DESIGN INTENT. THE CONTRACTOR SHOULD USE THIS AS A BASIS ONLY FOR HIS/HER DESIGN DEVELOPMENT AND THE PRODUCTION OF WORKING DRAWINGS FOR SITE USE. DESIGN DRAWINGS MUST NOT BE USED ON SITE FOR INSTALLATION PURPOSES.
- 5. THE CONTRACTOR IS RESPONSIBLE FOR THE FINAL CO-ORDINATION OF SERVICES AND THE PRODUCTION OF WORKING DRAWINGS.
- 6. ANY DISCREPANCIES, ERRORS OR OMISSIONS ARE TO BE CLARIFIED WITH THE RELEVANT ENGINEER AT THE EARLIEST OPPORTUNITY.
- ALL WORKS ARE TO BE IN ACCORDANCE WITH THE CURRENT RELEVANT STATUTORY REGULATIONS, BUILDINGS REGULATIONS, BRITISH STANDARDS, ACCEPTED CODES OF PRACTICE AND TRADE ASSOCIATION REQUIREMENTS.
- 8. DUCTWORK INSTALLATION TO BE IN ACCORDANCE WITH DW/144.
- 9. FIRE DAMPERS AND ACCESS PANELS TO BE PROVIDED WHEN DUCTS PASS THROUGH FIRE BARRIERS. FIRE DAMPERS TO BE OUT OF AIR STREAM TYPE.
- 10. ALL FAN COIL UNITS DUCTWORK, GRILLES AND PLENUM BOXES SHALL BE SUPPORTED USING DROP ROD FIXING AND UNISTRUT. GRIPPLE WIRE SHALL NOT BE ACCEPTED AS A MEANS OF SUPPORT.
- 11. ACCESS HATCHES SHALL BE PROVIDED IN THE DUCTWORK IN ACCORDANCE WITH DW144, TABLE 25, LEVEL 3.

GNILLE SCHEDOLL							
REF	LOCATION	MANUFACTURER	MODEL	SIZE (mm)	DUTY (I/s)	ACCESSORIES	
EG01	MALE CHANGE	WATERLOO	3HG	250x100	59	OBSS	
EG02	MALE CHANGE	WATERLOO	3HG	250x100	59	OBSS	
EG03	DIS WC	WATERLOO	3HG	100x100	22	OBSS	
EG04	MALE CHANGE	WATERLOO	3HG	250x100	59	OBSS	
EG05	FEMALE WC	WATERLOO	3HG	200x100	31	OBSS	
EG06	FEMALE WC	WATERLOO	3HG	200x100	31	OBSS	
EG07	FEMALE SHWR	WATERLOO	3HG	100x100	23	OBSS	
EG08	GYM	WATERLOO	3HG	400x250	233	OBSS	
EG09	GYM	WATERLOO	3HG	400x250	233	OBSS	
EG10	GYM	WATERLOO	3HG	400x250	233	OBSS	
EG11	GYM	WATERLOO	3HG	400x250	233	OBSS	
EG12	GYM	WATERLOO	3HG	400x250	233	OBSS	
EG13	GYM	WATERLOO	3HG	400x250	233	OBSS	
DTG01	MALE CHANGE	WATERLOO	3HG	400x250	150		
DTG02	MALE CHANGE	WATERLOO	NSA	400x250	150		
DTG03	DIS WC	WATERLOO	NSA	200x100	19		
DTG04	FEMALE CHG	WATERLOO	NSA	200x150	73		
DTG05	FEMALE CHG	WATERLOO	NSA	200x150	73		
		_					

GRILLE SCHEDULE

T2	26.03.20	TENDER ISSUE - AHU RELOCATED	NW	SG
T1	11.03.20	TENDER ISSUE		SG
REV	DATE	DESCRIPTION	BY	СК



CORBY BOROUGH COUNCIL

Project:
SAXILBY BOXING CLUB
CORBY

itle:

MECHANICAL SERVICES
PROPOSED MECHANICAL SERVICES
LAYOUT

	191	T2				
	Drawing No	Rev:				
	1:50	MAR20	SG	NW	CAD CK:	
ĺ	Scale at A1:		Designed:		Design:	Ì

TENDER