

Council of the Isles of Scilly - Ennor Close

Tender Clarification Nr 3 (19/10/2020)

Reference	Item Reference	Query	Clarification
1	Garage Base	Where the garage is to be demolished, do the base/footings need to be grubbed up and removed?	The base and footings can remain insitu.
2	Showers	Where a bathroom is being replaced, does the shower need to be replaced as well?	Yes please; allow to include the replacement of the shower if one is there already.